

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Alarm systems – Intrusion and hold-up systems –
Part 2-5: Intrusion detectors – Combined passive infrared / Ultrasonic detectors**

**Systèmes d'alarme – Systèmes d'alarme contre l'intrusion et les hold-up –
Partie 2-5: Détecteurs d'intrusion – Détecteurs combinés à infrarouges passifs et
à ultrasons**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 62642-2-5

Edition 1.0 2010-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Alarm systems – Intrusion and hold-up systems –
Part 2-5: Intrusion detectors – Combined passive infrared / Ultrasonic detectors**

**Systèmes d'alarme – Systèmes d'alarme contre l'intrusion et les hold-up –
Partie 2-5: Détecteurs d'intrusion – Détecteurs combinés à infrarouges passifs
et à ultrasons**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 13.320

ISBN 978-2-88912-306-3

CONTENTS

FOREWORD.....	4
INTRODUCTION	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions and abbreviations.....	7
3.1 Terms and definitions	7
3.2 Abbreviations.....	8
4 Functional requirements.....	9
4.1 Event processing	9
4.2 Detection	10
4.3 Operational requirements.....	11
4.4 Immunity of the individual technologies to incorrect operation.....	12
4.5 Tamper security	12
4.6 Electrical requirements	13
4.7 Environmental classification and conditions	14
5 Marking, identification and documentation.....	14
5.1 Marking and/or identification	14
5.2 Documentation.....	14
6 Testing.....	15
6.1 General.....	15
6.2 General test conditions	15
6.3 Basic detection test.....	16
6.4 Walk testing	17
6.5 Switch-on delay, time interval between signals and indication of detection.....	20
6.6 Self tests.....	20
6.7 Immunity of individual technologies to incorrect operation	21
6.8 Tamper security.....	22
6.9 Electrical tests.....	24
6.10 Environmental classification and conditions	26
6.11 Marking, identification and documentation	27
Annex A (normative) Dimensions and requirements of the standardised test magnets.....	28
Annex B (normative) General testing matrix	31
Annex C (informative) Walk test diagrams.....	33
Annex D (normative) Procedure for calculation of average temperature difference	36
Annex E (informative) Basic detection target for the basic test of detection capability	38
Annex F (informative) Equipment for walk test velocity control	39
Annex G (informative) Immunity to visible and near infrared radiation – Notes on calibration of the light source.....	40
Annex H (informative) Example list of small tools.....	41
Annex I (informative) Test for resistance to re-orientation of adjustable mountings.....	42
Bibliography.....	43
Figure A.1 – Test magnet – Magnet Type 1	29
Figure A.2 – Test magnet – Magnet Type 2	30

Figure C.1 – Detection across the boundary	33
Figure C.2 – Detection within the boundary	33
Figure C.3 – High velocity and intermittent movement	34
Figure C.4 – Close-in detection	34
Figure C.5 – Significant range reduction	35
Figure I.1 – Re-orientation test	42
Table 1 – Events to be processed by grade	9
Table 2 – Generation of signals or messages	9
Table 3 – General walk test velocity and attitude requirements	10
Table 4 – Tamper security requirements	13
Table 5 – Grade dependencies for electrical requirements	13
Table 6 – Range of materials for masking tests	24
Table 7 – Operational tests	27
Table 8 – Endurance tests	27
Table D.1 – Measurement and calculation of the real average temperature difference between the SWT and the background	36

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 62642-2-5:2010](https://standards.iteh.ai/catalog/standards/sist/490a0a72-a6ae-435d-84d2-51e89babb744/iec-62642-2-5-2010)

<https://standards.iteh.ai/catalog/standards/sist/490a0a72-a6ae-435d-84d2-51e89babb744/iec-62642-2-5-2010>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ALARM SYSTEMS –
INTRUSION AND HOLD-UP SYSTEMS –**

**Part 2-5: Intrusion detectors –
Combined passive infrared / Ultrasonic detectors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62642-2-5 has been prepared by IEC technical committee 79: Alarm and electronic security systems.

This standard is based on EN 50131-2-5 (2008).

The text of this standard is based on the following documents:

FDIS	Report on voting
79/324/FDIS	79/330/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62642 series can be found, under the general title *Alarm systems – Intrusion and hold-up systems*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 62642-2-5:2010](https://standards.iteh.ai/catalog/standards/sist/490a0a72-a6ae-435d-84d2-51e89babb744/iec-62642-2-5-2010)

<https://standards.iteh.ai/catalog/standards/sist/490a0a72-a6ae-435d-84d2-51e89babb744/iec-62642-2-5-2010>

INTRODUCTION

This part 2-5 of the IEC 62642 series of standards gives requirements for combined passive infrared and ultrasonic detectors used in intrusion and hold-up alarm systems. The other parts of this series of standards are as follows:

- Part 1 System requirements
- Part 2-2 Intrusion detectors – Passive infrared detectors
- Part 2-3 Intrusion detectors – Microwave detectors
- Part 2-4 Intrusion detectors – Combined passive infrared / Microwave detectors
- Part 2-5 Intrusion detectors – Combined passive infrared / Ultrasonic detectors
- Part 2-6 Intrusion detectors – Opening contacts (magnetic)
- Part 2-71 Intrusion detectors – Glass break detectors – Acoustic
- Part 2-72 Intrusion detectors – Glass break detectors – Passive
- Part 2-73 Intrusion detectors – Glass break detectors – Active
- Part 3 Control and indicating equipment
- Part 4 Warning devices
- Part 5-3 Requirements for interconnections equipment using radio frequency techniques
- Part 6 Power supplies
- Part 7 Application guidelines
- Part 8 Security fog devices/systems

This standard is for combined passive infrared and ultrasonic detectors (to be referred to as the detector) used as part of intrusion alarm systems installed in buildings. It includes four security grades and four environmental classes.

The purpose of a detector is to detect the broad spectrum infrared radiation emitted by an intruder and, at the same time, to emit ultrasonic radiation over the area being protected, and analyse signals that are returned, to provide the necessary range of signals or messages to be used by the rest of the intrusion alarm system.

The number and scope of these signals or messages will be more comprehensive for systems that are specified at the higher grades.

This standard is only concerned with the requirements and tests for the detector. Other types of detector are covered by other documents identified as IEC 62642-2 series.

ALARM SYSTEMS – INTRUSION AND HOLD-UP SYSTEMS –

Part 2-5: Intrusion detectors – Combined passive infrared / Ultrasonic detectors

1 Scope

This part of the IEC 62642 is for combined passive infrared and ultrasonic detectors installed in buildings and provides for security grades 1 to 4 (see IEC 62642-1), specific or non-specific wired or wire-free detectors, and uses environmental classes I to IV (see IEC 62599-1). This standard does not include requirements for combined passive infra red and ultrasonic detectors intended for use outdoors.

A detector should fulfil all the requirements of the specified grade.

Functions additional to the mandatory functions specified in this standard may be included in the detector, providing they do not influence the correct operation of the mandatory functions.

The International Standard does not apply to system interconnections.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-52, *Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution)*

IEC 62599-1, *Alarm systems – Part 1: Environmental test methods*

IEC 62599-2, *Alarm systems – Part 2: Electromagnetic compatibility – Immunity requirements for components of fire and security alarm systems*

IEC 62642-1, *Alarm systems – Intrusion and hold-up systems – Part 1: System requirements*

IEC 62642-6, *Alarm systems – Intrusion and hold-up systems – Part 6: Power supplies*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62642-1, as well as the following apply.

3.1.1

basic detection target

heat source and/or ultrasonic reflector designed to verify the operation of a detector

3.1.2

combined passive infrared and ultrasonic detector

detector of the broad-spectrum infrared radiation emitted by a human being, with an active ultrasonic emitter and receiver installed in the same housing

3.1.3

incorrect operation

physical condition that causes an inappropriate signal or message from a detector

3.1.4

masking

interference with the detector input capability by the introduction of a physical barrier such as metal, plastics, paper or sprayed paints or lacquers in close proximity to the detector

3.1.5

simulated walk test target

non-human or synthetic heat source or ultrasonic reflector designed to simulate the standard walk test target

3.1.6

standard walk test target

human being of standard weight and height clothed in close fitting clothing appropriate to the simulation of an intruder

3.1.7

walk test

operational test during which a detector is stimulated by the standard walk test target in a controlled environment

3.1.8

walk test attitude, crawling

crawling attitude that consists of the standard walk test target moving with hands and knees in contact with the floor

3.1.9

walk test attitude, upright

upright attitude that consists of the standard walk test target standing and walking with arms held at the sides of the body. The standard walk test target begins and ends a traverse with feet together

3.2 Abbreviations

For the purposes of this document, the abbreviations given in IEC 62642-1, as well as the following apply.

HDPE	high density polyethylene
PIR	passive infrared
EMC	electromagnetic compatibility
SWT	standard walk-test target
BDT	basic detection target

FOV field of view

4 Functional requirements

4.1 Event processing

Detectors shall process the events shown in Table 1. Detectors shall generate signals or messages as shown in Table 2.

Table 1 – Events to be processed by grade

Event	Grade			
	1	2	3	4
Intrusion detection	M	M	M	M
Tamper detection	Op	M	M	M
Masking detection	Op	Op	M	M
Significant reduction of range	Op	Op	Op	M
Low supply voltage	Op	Op	M	M
Total loss of power supply	Op	M	M	M
Local self test	Op	Op	M	M
Remote self test	Op	Op	Op	M
Key M = Mandatory Op = Optional	iTech STANDARD PREVIEW (standards.itech.ai)			

Table 2 – Generation of signals or messages

Event	Signals or messages		
	Intrusion	Tamper	Fault
No event	NP	NP	NP
Intrusion	M	NP	NP
Tamper	NP	M	NP
Masking ^a	M	Op	M
Significant reduction of range ^a	M	Op	M
Low supply voltage	Op	Op	M
Total loss of power supply ^b	M	Op	Op
Local self test pass	NP	NP	NP
Local self test fail	NP	NP	M
Remote self test pass	M	NP	NP
Remote self test fail	NP	NP	M
Key M = Mandatory NP = Not Permitted Op = Optional			
NOTE 1 This permits two methods of signalling a masking or reduction of range event: either by the intrusion signal and fault signal, or by a dedicated masking or reduction of range signal or message. Use of the intrusion signal and fault signal is preferable, as this requires fewer connections between CIE and detector. If multiple events overlap there will be some signal combinations that may be ambiguous. To overcome this ambiguity it is suggested that detectors should not signal 'intrusion' and 'fault' at the same time except to indicate masking. This implies that the detector should prioritise signals, e.g. 1 Intrusion, 2 Fault, 3 Masking.			

NOTE 2 When, in Table 1, an event may optionally generate signals or messages, they are as shown in this table.

NOTE 3 It is accepted that a bus system may send out dedicated signals or messages and does not necessarily have to follow the mapping of Table 2 provided that all of the required events are signalled.

^a An independent signal or message may be provided instead.

^b Alternatively total loss of power supply shall be determined by loss of communication with the detector.

4.2 Detection

4.2.1 Detection performance

The detector shall generate an intrusion signal or message when the standard or simulated walk-test target moves at velocities and attitudes specified in Table 3. For detection across the boundary, the walk-test distance shall be 1,5 m either side of the boundary. For detection within the boundary, the walk-test distance shall be 3,0 m.

Table 3 – General walk test velocity and attitude requirements

Test	Grade 1	Grade 2	Grade 3	Grade 4
Detection across the boundary	Required	Required	Required	Required
Velocity	1,0 ms ⁻¹	1,0 ms ⁻¹	1,0 ms ⁻¹	1,0 ms ⁻¹
Attitude	Upright	Upright	Upright	Upright
Detection within the boundary	Required	Required	Required	Required
Velocity	0,3 ms ⁻¹	0,3 ms ⁻¹	0,2 ms ⁻¹	0,1 ms ⁻¹
Attitude	Upright	Upright	Upright	Upright
Detection at high velocity	Not required	Required	Required	Required
Velocity	N/A	2,0 ms ⁻¹	2,5 ms ⁻¹	3,0 ms ⁻¹
Attitude	N/A	Upright	Upright	Upright
Close-in detection performance	Required	Required	Required	Required
Distance	2,0 m	2,0 m	0,5 m	0,5 m
Velocity	0,5 ms ⁻¹	0,4 ms ⁻¹	0,3 ms ⁻¹	0,2 ms ⁻¹
Attitude	Upright	Upright	Crawling	Crawling
Intermittent movement detection performance^a	Not required	Not required	Required	Required
Velocity	N/A	N/A	1,0 ms ⁻¹	1,0 ms ⁻¹
Attitude	N/A	N/A	Upright	Upright
Significant reduction of specified range^b	Not required	Not required	Not required	Required
Velocity	N/A	N/A	N/A	1,0 ms ⁻¹
Attitude	N/A	N/A	N/A	Upright
^a For grades 3 and 4 detectors, the intermittent movement shall consist of the SWT walking 1 m at a velocity of 1,0 ms ⁻¹ then pausing for 5 s before continuing. The sequence shall be maintained until the SWT has traversed through the entire detection area. This constitutes one walk test. The test shall be repeated in each of the directions shown in Figure C.3.				
^b The means to detect a significant reduction in range may be met either by detectors having the appropriate function (4.2.3) or by suitable system design. Two or more devices (e.g. a detector in conjunction with a camera, active transmitter or additional detector), may cooperate and interconnect with the system to provide means to detect a significant reduction of range.				

4.2.2 Indication of detection

An indicator shall be provided at the detector to indicate when an intrusion signal or message has been generated. At grades 1 and 2 this indicator shall be capable of being enabled and disabled either remotely at Access Level 2 and/or locally after removal of a cover which provides tamper detection as described in Tables 1 and 4. At grades 3 and 4 this indicator shall be capable of being enabled and disabled remotely at Access Level 2.

4.2.3 Significant reduction of range

Grade 4 detectors shall detect significant reduction of range or coverage area due, for example, to deliberate or accidental introduction of objects or obstructions into the coverage area.

Range reduction along the principal axis of detection of more than 50 % shall generate a signal or message within 180 s, according to the requirements of Table 2 and Table 3.

If additional equipment is required to detect significant reduction of range, reference shall be made to this equipment and its operation in the manufacturer's documentation.

4.3 Operational requirements

4.3.1 Time interval between intrusion signals or messages

Detectors using wired interconnections shall be able to provide an intrusion signal or message not more than 15 s after the end of the preceding intrusion signal or message.

Detectors using wirefree interconnections shall be able to provide an intrusion signal or message after the end of the preceding intrusion signal or message within the following times:

Grade 1	300 s;
Grade 2	180 s;
Grade 3	30 s;
Grade 4	15 s.

4.3.2 Switch on delay

The detector shall meet all functional requirements within 180 s of the power supply reaching its nominal voltage as specified by the manufacturer.

4.3.3 Self tests

4.3.3.1 Local self test

The detector shall automatically test itself at least once every 24 h according to the requirements of Tables 1 and 2. If normal operation of the detector is inhibited during a local self-test, the detector inhibition time shall be limited to a maximum of 30 s in any period of 2 h.

4.3.3.2 Remote self test

A detector shall process remote self tests and generate signals or messages in accordance with Tables 1 and 2 within 10 s of the remote self test signal being received, and shall return to normal operation within 30 s of the remote test signal being received.

4.4 Immunity of the individual technologies to incorrect operation

The detector shall be considered to have sufficient immunity to incorrect operation if the following requirements have been met. No intrusion signal or message shall be generated during the tests.

4.4.1 Immunity to air flow

The PIR component of the detector shall not generate any signal or message when air is blown over the face of the detector.

4.4.2 Immunity to visible and near infrared radiation

The PIR component of the detector shall not generate any signal or message when a car headlamp is swept across the front window or lens through two panes of glass.

4.4.3 Immunity to ultrasonic signal interference by extraneous sound sources

The ultrasonic component of the combined detector shall not generate an intrusion signal or message due to the operation of a sound source mounted nearby.

4.5 Tamper security

Tamper security requirements for each grade of detector are shown in Table 4.

4.5.1 Resistance to and detection of unauthorised access to components and means of adjustment

All components, means of adjustment and access to mounting screws, which, when interfered with, could adversely affect the operation of the detector, shall be located within the detector housing. Such access shall require the use of an appropriate tool and depending on the grade as specified in Table 4 shall generate a tamper signal or message before access can be gained.

It shall not be possible to gain such access without generating a tamper signal or message or causing visible damage.

4.5.2 Detection of removal from the mounting surface

A tamper signal or message shall be generated if the detector is removed from its mounting surface, in accordance with Table 4.

4.5.3 Resistance to, or detection of, re-orientation

When the torque given in Table 4 is applied to the detector it shall not rotate more than 5°. Alternatively, when the torque given in Table 4 is applied, a tamper signal or message shall be generated before the detector has rotated by 5°.

4.5.4 Immunity to magnetic field interference

It shall not be possible to inhibit any signals or messages with a magnet of grade dependence according to Table 4. The magnet types shall be as described in Annex A.

4.5.5 Detection of masking

Means shall be provided to detect inhibition of the operation of the detector by masking according to the requirements of Table 4.

The maximum response time for the masking detection device shall be 180 s. Masking shall be signalled according to the requirements of Table 2. The signals or messages shall remain

for at least as long as the masking condition is present. A masking signal or message shall not be reset while the masking condition is still present. Alternatively the masking signal or message shall be generated again within 180 s of being reset if the masking condition is still present.

NOTE From a system design point of view it would be preferable for masked detectors to automatically reset after the masking condition is removed.

No masking signal or message shall be generated by normal human movement at 1 ms^{-1} at a distance equal to or greater than 1 m.

For detectors where detection of masking may be remotely disabled, the detection of masking shall operate when the I&HAS is unset; it is not required to operate when the I&HAS is set.

Table 4 – Tamper security requirements

Requirement	Grade 1	Grade 2	Grade 3	Grade 4
Resistance to access to the inside of the detector	Required	Required	Required	Required
Detection of access to the inside of the detector	Not Required	Required	Required	Required
Removal from the mounting surface wired detectors	Not required	Not Required	Required	Required
Removal from the mounting surface wirefree detectors	Not required	Required	Required	Required
Resistance to, or detection of, re-orientation - for detectors mounted on brackets only	Not required	Required	Required	Required
Applied torque		2 Nm	5 Nm	10 Nm
Magnetic field immunity	Not required	Required	Required	Required
Magnet type defined in Annex A	Type 1	Type 1	Type 2	Type 2
Masking detection	Not required	Not required	Required	Required

4.6 Electrical requirements

4.6.1 Grade dependencies

The grade dependencies appear in Table 5. These requirements do not apply to detectors having Type C power supplies. For these detectors, refer to IEC 62642-6.

Table 5 – Grade dependencies for electrical requirements

Test	Grade 1	Grade 2	Grade 3	Grade 4
Detector current consumption	Required	Required	Required	Required
Input voltage range	Required	Required	Required	Required
Slow input voltage rise	Not required	Required	Required	Required
Input voltage ripple	Not required	Required	Required	Required
Input voltage step change	Not required	Required	Required	Required

4.6.2 Detector current consumption

The detector's quiescent and maximum current consumption shall not exceed the figures claimed by the manufacturer at the nominal input voltage.