

TECHNICAL SPECIFICATION



**Rotating electrical machines –
Part 27-2: On-line partial discharge measurements on the stator winding
insulation of rotating electrical machines**

WITHDRAWN

IEC/TS 60034-27-2:2012
<https://standards.iteh.ai/catalog/standards/iec/ce/f1/bcb-02de-4885-852d-dc6f6e38fd86/iec-ts-60034-27-2-2012>





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

IEC TS 60034-27-2:2012

<https://standards.iteh.ai/catalog/standards/iec/ce/116cb-02de-4885-852d-dc6f6e38fd86/iec-ts-60034-27-2-2012>

TECHNICAL SPECIFICATION



**Rotating electrical machines –
Part 27-2: On-line partial discharge measurements on the stator winding
insulation of rotating electrical machines**

<https://standards.iteh.ai/catalog/standards/iec/ce/116cb-02de-4885-852d-dc6f6e38fd86/iec-ts-60034-27-2-2012>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XA**

ICS 29.160

ISBN 978-2-8322-0056-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	9
4 Nature of PD in rotating machines	11
4.1 Basics of PD	11
4.2 Types of PD in rotating machines	12
4.2.1 General	12
4.2.2 Internal discharges	12
4.2.3 Slot discharges.....	13
4.2.4 Discharges in the end-winding.....	13
4.2.5 Conductive particles	13
4.3 Arcing and sparking.....	14
4.3.1 General	14
4.3.2 Arcing at broken conductors	14
4.3.3 Vibration sparking.....	14
5 Noise and disturbance.....	14
5.1 General.....	14
5.2 Noise and disturbance sources.....	14
5.3 Frequency domain separation	15
5.4 Time domain separation	16
5.5 Combination of frequency and time domain separation.....	17
5.6 Gating.....	17
5.7 Pattern recognition separation.....	18
6 Measuring techniques and instruments.....	18
6.1 General.....	18
6.2 Pulse propagation in windings	19
6.3 Signal transfer characteristics	19
6.4 PD sensors	22
6.4.1 General	22
6.4.2 Design of PD sensors	22
6.4.3 Reliability of PD Sensors	23
6.5 PD measuring device	23
6.6 PD measuring parameters	23
6.6.1 General	23
6.6.2 PD magnitude.....	23
6.6.3 Additional PD parameters.....	24
7 Installation of PD on-line measuring systems.....	24
7.1 General.....	24
7.2 Installation of PD sensors.....	24
7.3 Outside access point and cabling	25
7.4 Installation of the PD measuring device.....	26
7.5 Installation of operational data acquisition systems	26
8 Normalization of measurements	27

8.1	General	27
8.2	Normalization for low frequency systems	27
8.2.1	General	27
8.2.2	Normalization procedure	27
8.3	Normalization / sensitivity check for high & very high frequency systems	29
8.3.1	Specification for the electronic pulse generation	29
8.3.2	Configuration of the machine	30
8.3.3	Sensitivity check	30
9	Measuring procedures	30
9.1	General	30
9.2	Machine operating parameters	31
9.3	Baseline measurement	31
9.3.1	General	31
9.3.2	Recommended test procedure	31
9.4	Periodic on-line PD measurements	32
9.5	Continuous on-line PD measurements	33
10	Visualization of measurements	33
10.1	General	33
10.2	Visualization of trending parameters	33
10.3	Visualization of PD patterns	34
11	Interpretation of on-line measurements	37
11.1	General	37
11.2	Evaluation of basic trend parameters	37
11.3	Evaluation of PD patterns	38
11.3.1	General	38
11.3.2	PD pattern interpretation	38
11.4	Effect of machine operating factors	39
11.4.1	General	39
11.4.2	Machine operating factors	39
11.4.3	Steady state load conditions	39
11.4.4	Transient load conditions	40
12	Test report	41
Annex A (informative) Examples of Phase Resolved Partial Discharge (PRPD) pattern		44
Bibliography		55
Figure 1 – Time domain disturbance separation by time of pulse arrival		16
Figure 2 – Combined time and frequency domain disturbance separation (TF-map)		17
Figure 3 – Idealized frequency response of a PD pulse at the PD source and at the machine terminals; Frequency response of different PD measuring systems: a) low frequency range, b) high frequency range, c) very high frequency range		21
Figure 4 – Measuring object, during normalization		28
Figure 5 – Arrangement for sensitivity check		29
Figure 6 – Recommended test procedure with consecutive load and temperature conditions		32
Figure 7 – Example of visualization of trending parameters		34
Figure 8 – Example of a Φ -q-n partial discharge pattern, with colour code for the pulse number H(n)/s		35

Figure 9 – Example of a three phase, phase shifted Φ -q-n plot	36
Figure A.1 – Stylized examples of PD phase resolved patterns	44
Figure A.2 – Example of internal void discharges PRPD pattern, recorded during laboratory simulation.....	45
Figure A.3 – Example of internal delamination PRPD pattern, recorded during laboratory simulation.....	46
Figure A.4 – Example of delamination between conductor and insulation PRPD pattern, recorded during laboratory simulation	47
Figure A.5 – Slot partial discharges activity and corresponding PRPD pattern, recorded during laboratory simulation.....	47
Figure A.6 – Corona activity at the S/C and stress grading coating, and corresponding PRPD pattern, recorded during laboratory simulation.....	48
Figure A.7 – Surface tracking activity along the end arm and corresponding PRPD pattern, recorded during laboratory simulation	48
Figure A.8 – Gap type discharge activities and corresponding PRPD patterns, recorded during laboratory simulations	49
Figure A.9 – Example of internal void discharges PRPD pattern, recorded on-line	50
Figure A.10 – Example of internal delamination PRPD pattern, recorded on-line.....	51
Figure A.11 – Example of delamination between conductor and insulation PRPD pattern, recorded on-line.....	51
Figure A.12 – Degradation caused by slot partial discharges activity and corresponding PRPD pattern recorded on-line	52
Figure A.13 – Degradation caused by corona activity at the S/C and stress grading coating and corresponding PRPD pattern, recorded on-line	53
Figure A.14 – Surface tracking activity along the end arm and corresponding PRPD pattern, recorded on-line.....	53
Figure A.15 – Degradation caused by gap type discharges and corresponding PRPD patterns, recorded on-line.....	54
Figure A.16 – PRPD pattern recorded on-line, illustrating multiple PD sources	54

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ROTATING ELECTRICAL MACHINES –

Part 27-2: On-line partial discharge measurements on the stator winding insulation of rotating electrical machines

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC/TS 60034-27-2, which is a technical specification, has been prepared by IEC technical committee 2: Rotating machinery.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
2/1636/DTS	2/1649/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

NOTE A table of cross-references of all IEC TC 2 publications can be found on the IEC TC 2 dashboard on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

IEC TS 60034-27-2:2012

<https://standards.iteh.ai/catalog/standards/iec/ce/116cb-02de-4885-852d-dc6f6e38fd86/iec-ts-60034-27-2-2012>

INTRODUCTION

For many years, the measurement of partial discharges (PD) has been employed as a sensitive means of assessing the quality of new insulation as well as a means of detecting localized sources of PD in used electrical winding insulation arising from operational stresses in service. Compared with other dielectric tests (i.e. the measurement of dissipation factor or insulation resistance) the differentiating character of partial discharge measurements allows localized weak points of the insulation system to be identified. Especially on-line PD measurements are not only sensitive to partial discharges but also to various arcing and sparking phenomena.

With regard to condition assessment of rotating machines, the measurement of partial discharges can provide information on:

- points of weakness in the insulation system;
- degradation processes;
- maintenance measures and intervals between overhauls.

Although the PD testing of rotating machines has gained widespread acceptance, it has emerged from several studies that not only are there many different methods of measurement in existence but also the criteria and methods of analysing and finally assessing the measured data are often very different and not really comparable. Consequently, there is a need to give some guidance to those users who are considering the use of PD measurements to assess the condition of their insulation systems.

Partial discharge testing of stator windings can be divided into two broad groups:

- a) off-line measurements, in which the stator winding is isolated from the power system and a separate power supply is employed to energize the winding;
- b) on-line measurements, in which the rotating machine is operating normally and connected to the power system.

Both of these approaches have advantages and disadvantages with respect to one another. A detailed discussion of PD off-line testing is provided in IEC/TS 60034-27, whereas this technical specification is confined to on-line techniques. The approach to deal with PD on- and off-line measurement techniques in two different technical specifications is considered necessary to render each specification sufficiently concise to be of use by non-specialists in the field of PD measurement.

PD on-line measurements are recorded with the rotating machine experiencing all of the operating stresses; thermal, electrical, environmental and mechanical. On-line PD testing has the following advantages:

- the voltage distribution across the winding is the same as during operation;
- the measurements are made at operating temperature;
- normal mechanical forces are present.

Due to the realistic stress impact on the winding during measurement and due to the fact that the measurement is performed during normal operation, on-line PD testing has become very popular. Since no service interruption is required, once the PD sensors are installed during a scheduled unit outage, and no external power source is needed, on-line testing is usually cost effective compared to off-line PD measurement. Condition changes of the stator winding insulation system can be identified and evaluated at an early stage based on a real-time condition assessment and thus condition-based and predictive maintenance strategies can be improved.

Empirical limits verified in practice can be used as a basis for evaluating test results. Furthermore, PD trend evaluation and comparisons with machines of similar design and similar

insulation system measured under similar conditions, using the same measuring equipment, are recommended to ensure reliable assessment of the condition of the stator winding insulation.

This technical specification does not deal with online PD measurements on converter driven electrical machines because different measuring techniques are needed to distinguish between noise from the converter and PD from the winding. For this purpose IEC/TS 61934 may apply.

Limitations

On-line PD tests on stator windings produce comparative, rather than absolute measurements. This creates a fundamental limitation for the interpretation of PD data, and implies that simple limits for allowable PD cannot be established unless many precautions are taken. For the same reasons, PD acceptance criteria for new or rewound stator windings cannot be established unless many precautions are taken. The reasons for the difficulty to set absolute limits for PD include:

- There are many types of PD sensors as well as recording and analyzing instruments. Generally they are incompatible and will produce different results for the same PD activity.
- Even with the same measuring system, partial discharges will interact with the winding capacitance, inductance and/or surge impedance to produce different voltage and current pulses. Thus PD measurements from machines with different ratings and/or winding connections may produce different PD results, even though the actual amount of damage may be the same.
- Different types of defects can produce different PD magnitudes, even with the same amount of damage.
- PD may occur close or far from the PD sensor. In general if the PD is physically far from the PD sensor, it will produce a smaller response at the PD sensor due to attenuation.

Users should also be aware that there is no evidence that the time to failure of the stator winding insulation can be estimated using any PD quantity, even in combination with other electrical tests. Also, determining the root cause of an insulation deterioration process using pattern recognition, especially if more than one process is occurring, is still somewhat subjective, although the technology is evolving rapidly.

Noise and disturbance may have a great impact on the detected signals, especially for on-line PD measurements. Cross-coupling of PD and noise on one phase can obscure PD on another phase. With some measuring systems, this can make objective interpretation of the test results difficult.

Users of PD measurement should be aware that, due to the principles of the method, not all insulation-related problems in stator windings can be detected by measuring partial discharges, e.g. insulation failures involving continuous leakage currents due to conductive paths between different elements of the insulation or pulse-less discharge phenomena.

ROTATING ELECTRICAL MACHINES –

Part 27-2: On-line partial discharge measurements on the stator winding insulation of rotating electrical machines

1 Scope

This part of IEC 60034, which is a technical specification, provides a common basis for

- measuring techniques and instruments;
- the arrangement of the installation;
- normalization and sensitivity assessment;
- measuring procedures;
- noise reduction;
- the documentation of results;
- the interpretation of results;

with respect to partial discharge on-line measurements on the stator winding insulation of non-converter driven rotating electrical machines with rated voltage of 3 kV and up. This technical specification covers PD measuring systems and methods detecting electrical PD signals. The same measuring devices and procedures can also be used to detect electrical sparking and arcing phenomena.

NOTE The main differences between on-line measurements and off-line measurements are due to a different voltage distribution along the winding and various thermal and mechanical effects related to the operation, like vibration, contact arcing or temperature gradients between stator copper and stator iron core. Furthermore, especially for hydrogen-cooled machines the gas and the gas pressure is different for off- and on-line PD measurements.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

IEC/TS 60034-27, *Rotating electrical machines – Part 27: Off-line partial discharge measurements on the stator winding insulation of rotating electrical machines*

3 Terms and definitions

For the purposes of this document the general terms and definitions for partial discharge measurements given in IEC 60270 apply, together with the following.

3.1

off-line measurement

measurement taken with the rotating machine at standstill, the machine being disconnected from the power system

Note 1 to entry: The necessary test voltage is applied to the winding from a separate voltage source.

3.2

on-line measurement

measurement taken with the rotating machine in normal operation

3.3

periodic on-line PD measurement

on-line PD measurement performed on the machine at regular intervals

3.4

continuous on-line PD measurement

on-line PD measurement performed on the machine with a measuring device continuously acquiring PD data

3.5

stress control coating

paint or tape on the surface of the groundwall insulation that extends beyond the conductive slot portion coating in high-voltage stator bars and coils

Note 1 to entry: The stress control coating reduces the electric field stress along the winding overhang to below a critical value that would initiate PD on the surface. The stress control coating overlaps the conductive slot portion coating to provide electrical contact between them.

3.6

conductive slot coating

conductive paint or tape layer in intimate contact with the groundwall insulation in the slot portion of the coil side, often called 'semiconductive' coating

Note 1 to entry: This coating together with adequate slot design provides electrical contact to the stator core, without shorting the core laminations.

3.7

corona discharge

visible partial discharge adjacent to the surface of a conductor in gases

3.8

slot discharges

discharges that occur between the outer surface of the slot portion of a coil or bar and the grounded core laminations due to high voltage

3.9

vibration sparking

interrupted surface currents between the outer surface of the slot portion of a bar and the grounded core laminations due to axially induced voltages on the conductive slot coating combined with bar vibrations

3.10

internal discharges

discharges that occur within the insulation system

3.11

surface discharges

discharges that occur on the surface of the insulation or on the surface of winding components in the winding overhang or the active part of the machine winding

3.12

pulse magnitude distribution

number of pulses within a series of equally-spaced windows of pulse magnitude during a pre-defined measuring time

3.13**pulse phase distribution**

number of pulses within a series of equally-spaced windows of phase during a predefined measuring time

3.14**phase resolved partial discharge pattern**

PD distribution map of PD magnitude vs. a.c. cycle phase position, for visualization of the PD behaviour during a predefined measuring time

3.15**PD sensor**

general type of transducer, which can be used to detect PD signals from the machine winding

Note 1 to entry: A PD sensor typically consists of a high voltage coupling capacitor of low inductance design and a low voltage coupling device in series.

3.16**coupling device**

usually an active or passive four-terminal network that converts the input currents to output voltage signals

Note 1 to entry: These signals are transmitted to the measuring device by a transmission system. The frequency response of the coupling device is normally chosen at least so as to efficiently prevent the test voltage frequency and its harmonics from reaching the measuring device.

3.17**resistance temperature detector****RTD**

temperature detector inserted into the stator winding, usually between the top and bottom bar or between embedded coil sides in a given slot

3.18**largest repeatedly occurring PD magnitude Q_m**

the largest magnitude recorded by a measuring system which has the pulse train response in accordance with 4.3.3 of IEC 60270, or the magnitude associated with a PD pulse repetition rate of a specified number of pulses per second, which can be directly inferred from a pulse magnitude distribution.

Note 1 to entry: A recommended pulse repetition rate is 10 pulses or more per second.

4 Nature of PD in rotating machines**4.1 Basics of PD**

Generally, partial discharges (PD) can develop at locations where the dielectric properties of insulating materials are inhomogeneous. At such locations, the local electrical field strength may be enhanced. Due to local electrical over-stressing this may lead to a local, partial breakdown. This partial breakdown is not a total breakdown of the insulation system. PD in general requires a gas volume to develop, e.g. in gas filled voids embedded in the insulation, adjacent to conductors or at insulation interfaces.

A partial discharge can occur when the local field strength exceeds the dielectric strength of the insulating material. This process may result in numerous PD pulses during one cycle of the applied voltage.

The amount of charge transferred in the discharge is closely related to the specific properties of the inhomogeneity such as the dimensions, the actual breakdown voltage and the specific dielectric properties of the materials involved, e.g. surface properties, kind of gas, gas pressure, etc.

Stator winding insulation systems for high voltage machines will normally have some PD activity, but are inherently resistant to partial discharges due to their inorganic mica components. However, significant PD in these machines is usually more a symptom of insulation deficiencies, like manufacturing problems or in-service deterioration, rather than being a direct cause of failure. Nevertheless, depending on the individual processes, PD in machines may also directly attack the insulation and thus influence the ageing process. The time to failure or failure probability may not always correlate with PD levels, but depends significantly on other factors, for example operating temperature, wedging conditions, bar vibrations, degree of contamination, etc.

The measurement and the analysis of the specific PD behaviour can be efficiently used for quality control of new windings and winding components and for early detection of insulation deficiencies caused by thermal, electrical, ambient and mechanical ageing factors in service, which might result in an insulation fault.

The main differences between on-line measurements and off-line measurements are due to a different voltage distribution along the winding and various thermal and mechanical effects related to the operation, like vibration, contact arcing or temperature gradients between stator copper and stator iron core. Furthermore, especially for hydrogen-cooled machines the gas and the gas pressure is different for off- and on-line PD measurements.

4.2 Types of PD in rotating machines

4.2.1 General

Partial discharges may develop throughout the stator winding insulation system due to specific manufacturing technologies, manufacturing deficiencies, normal in-service ageing, or abnormal ageing. Machine design, the nature of the materials used, manufacturing methods, operating conditions, etc. can profoundly affect the quantity, location, characteristics, evolution and the significance of PD. For a given machine, the existing PD sources may be identified and distinguished in many cases by their characteristic PD behaviour.

4.2.2 Internal discharges

4.2.2.1 Internal voids

Although manufacturing processes are designed to minimize internal voids, inevitably there is some void content. For example in a resin impregnated mica tape insulation system, that is commonly used in high voltage rotating machines, the mica in the insulation system prevents the partial discharges from developing into a complete breakdown. As long as internal voids are small and do not significantly enlarge, operational reliability is not reduced.

4.2.2.2 Internal delamination

Internal delamination within the main insulation can be caused by imperfect curing of the insulation system during manufacturing or by mechanical or thermal over-stressing during operation. Large voids may develop over a large surface resulting in discharges of relatively high energy, which may significantly attack the insulation. In particular, delamination will reduce the thermal conductivity of the insulation, which might lead to accelerated ageing or even a thermal runaway. Thus, delamination needs careful consideration when PD activity is being assessed.

4.2.2.3 Delamination between conductors and insulation

Thermal cycling may cause delamination at the interface of the conductor and the main insulation. This delamination can result in partial discharges which can relatively rapidly result in failure especially in multi-turn coils.