

INTERNATIONAL
STANDARD

ISO
6946

First edition
1996-08-15

**Building components and building
elements — Thermal resistance and thermal
transmittance — Calculation method**

iTeh STANDARD PREVIEW

(standards.iteh.ai)

*Composants et parois de bâtiments — Résistance thermique et coefficient
de transmission thermique — Méthode de calcul*

<https://standards.iteh.ai/catalog/standards/sist/b26e7d1d-c3d8-407b-89ee-357314a7804d/iso-6946-1996>



Reference number
ISO 6946:1996(E)

Contents

Page

1	Scope	1
2	Normative references	1
3	Definitions and symbols	1
4	Principles	3
5	Thermal resistances	4
6	Total thermal resistance	9
7	Thermal transmittance	12

Annexes

A	Surface resistance	13
B	Thermal resistance of unventilated airspaces	15
C	Calculation of the thermal transmittance of components with tapered layers	18
D	Corrections to thermal transmittance	21
E	Examples of corrections for air gaps	23

iTeh STANDARD PREVIEW

(standards.iteh.ai)

ISO 6946:1996

<https://standards.iteh.ai/catalog/standards/sist/b26e7d81-c3d8-407b-89ee-357314a7804d/iso-6946-1996>

© ISO 1996

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case Postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

iTeh STANDARD PREVIEW

(standards.itCEN.ai)
International Standard ISO 6946 was prepared by the European Committee for Standardization (CEN) in collaboration with ISO/TC 163, *Thermal insulation*, Subcommittee SC 2, *Calculation methods*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

<https://standards.iteh.ai/catalog/standards/sist/b26e7d1d-c3d8-407b-89ee-357314a7804d/iso-6946-1996>

This first edition cancels and replaces ISO 6946-1:1986. ISO 6946-2:1986 was withdrawn in 1995.

Annexes A, B, C and D form an integral part of this International Standard. Annex E is for information only.

Introduction

The thermal transmittance calculated according to this standard is suitable for determining heat flow through building components that are within the scope of this standard.

For most purposes heat flows can be calculated with the following temperatures:

- internal: dry resultant temperature;
- external: air temperature.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[ISO 6946:1996](#)

<https://standards.iteh.ai/catalog/standards/sist/b26e7d1d-c3d8-407b-89ee-357314a7804d/iso-6946-1996>

1 Scope

This standard gives the method of calculation of the thermal resistance and thermal transmittance of building components and building elements, excluding doors, windows and other glazed units, components which involve heat transfer to the ground, and components through which air is designed to permeate.

The calculation method is based on the appropriate design thermal conductivities or design thermal resistances of the materials and products involved.

The method applies to components and elements consisting of thermally homogeneous layers (which can include air layers).

The standard also gives an approximate method that can be used for inhomogeneous layers, except cases where an insulating layer is bridged by metal.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 10456:—¹⁾, *Thermal insulation — Building materials and products — Determination of declared and design thermal values.* [ISO 6946:1996](https://www.iso.org/obp/ui/#iso:code:357314a7804d/iso-6946-1996)

ISO 7345:1987, *Thermal insulation — Physical quantities and definitions.*

3 Definitions and symbols

3.1 Definitions

For the purposes of this standard, the following definitions and those given in ISO 7345 apply.

3.1.1 building element: Major part of a building such as a wall, floor or roof.

1) To be published.

3.1.2 building component: Building element or a part of it.

NOTE - In this standard the word "component" is used to indicate both element and component.

3.1.3 design thermal value: Design thermal conductivity or design thermal resistance.

NOTE - A given product can have more than one design value, for different applications or environmental conditions.

3.1.4 design thermal conductivity: Value of thermal conductivity of a building material or product under specific external and internal conditions which can be considered as typical of the performance of that material or product when incorporated in a building component.

3.1.5 design thermal resistance: Value of thermal resistance of a building product under specific external and internal conditions which can be considered as typical of the performance of that product when incorporated in a building component.

3.1.6 thermally homogeneous layer: Layer of constant thickness having thermal properties which are uniform or which may be regarded as being uniform.

3.2 Symbols and units

STANDARD PREVIEW

Symbol	Quantity (standards.iteh.ai)	Unit
A	area	m^2
R	design thermal resistance ISO 6946:1996	$m^2 \cdot K/W$
R_g	thermal resistance of airspace	$m^2 \cdot K/W$
R_{se}	external surface resistance	$m^2 \cdot K/W$
R_{si}	internal surface resistance	$m^2 \cdot K/W$
R_T	total thermal resistance (environment to environment)	$m^2 \cdot K/W$
R'_T	upper limit of total thermal resistance	$m^2 \cdot K/W$
R''_T	lower limit of total thermal resistance	$m^2 \cdot K/W$
R_u	thermal resistance of unheated space	$m^2 \cdot K/W$
U	thermal transmittance	$W/(m^2 \cdot K)$
d	thickness	m
h	heat transfer coefficient	$W/(m^2 \cdot K)$
λ	design thermal conductivity	$W/(m \cdot K)$

4 Principles

The principle of the calculation method is to:

- a) obtain the thermal resistance of each thermally homogeneous part of the component;
- b) combine these individual resistances so as to obtain the total thermal resistance of the component, including (where appropriate) the effect of surface resistances.

Thermal resistances of individual parts are obtained according to 5.1.

The values of surface resistance given in 5.2 are appropriate in most cases. Annex A gives detailed procedures for low-emissivity surfaces, specific external wind speeds, and non-planar surfaces.

Air layers may be regarded as thermally homogeneous for the purposes of this standard. Values of the thermal resistance of large air layers with high-emissivity surfaces are given in 5.3, and annex B gives procedures for other cases.

The resistances of the layers are combined as follows:

- a) for components consisting of thermally homogeneous layers, obtain the total thermal resistance according to 6.1 and the thermal transmittance according to clause 7;
- b) for components having one or more thermally inhomogeneous layers, obtain the total thermal resistance according to 6.2 and the thermal transmittance according to clause 7;
- c) for components containing a tapered layer, obtain the thermal transmittance and/or the total thermal resistance according to annex C.

Finally, corrections are applied to the thermal transmittance if appropriate according to annex D, to allow for the effects of air gaps in insulation, mechanical fasteners penetrating an insulation layer, and precipitation on inverted roofs.

The thermal transmittance so calculated applies between the environments on either side of the component concerned, for example internal and external environments, two internal environments in the case of an internal partition, internal environment and an unheated space. Simplified procedures are given in 5.4 for treating an unheated space as a thermal resistance.

5 Thermal resistances

5.1 Thermal resistance of homogeneous layers

Design thermal values can be given as either design thermal conductivity or design thermal resistance. If thermal conductivity is given, obtain the thermal resistance of the layer from:

$$R = \frac{d}{\lambda} \tag{1}$$

where

- d is the thickness of the material layer in the component;
- λ is the design thermal conductivity of the material, either calculated according to ISO/DIS 10456.2 or obtained from tabulated values.

NOTE - The thickness d may be different from the nominal thickness (e.g. when a compressible product is installed in a compressed state, d is less than the nominal thickness). If relevant, d should also make appropriate allowance for thickness tolerances (e.g. when they are negative).

Thermal resistance values used in intermediate calculations shall be calculated to at least 3 decimal places.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

5.2 Surface resistances

Use the values in table 1 for plane surfaces in the absence of specific information on the boundary conditions. The values under "horizontal" apply to heat flow directions $\pm 30^\circ$ from the horizontal plane. For non-planar surfaces or for specific boundary conditions use the procedures in annex A.

Table 1 - Surface resistances (in m²·K/W)

	Direction of heat flow		
	Upwards	Horizontal	Downwards
R_{si}	0,10	0,13	0,17
R_{se}	0,04	0,04	0,04

NOTE - The values in table 1 are design values. For the purposes of declaration of the thermal transmittance of components and other cases where values independent of heat flow direction are required, it is recommended that the values for horizontal heat flow are used.

5.3 Thermal resistance of air layers

The values given in this subclause apply to an air layer which:

- is bounded by two faces which are effectively parallel and perpendicular to the direction of heat flow and which have emissivities not less than 0,8;
- has a thickness (in the direction of heat flow) of less than 0,1 times each one of the other two dimensions, and not greater than 0,3 m;

NOTE - A single thermal transmittance should not be calculated for components containing air layers thicker than 0,3 m. Rather, heat flows should be calculated by performing a heat balance (see ISO/DIS 13789, *Thermal performance of buildings - Transmission heat loss coefficient - Calculation method*).

- has no air interchange with the internal environment.

If the above conditions do not apply, use the procedures in annex B.

5.3.1 Unventilated air layer

An unventilated air layer is one in which there is no express provision for air flow through it. Design values of thermal resistance are given in table 2. The values under "horizontal" apply to heat flow directions $\pm 30^\circ$ from the horizontal plane.

**Table 2 - Thermal resistance (in $m^2 \cdot K/W$) of unventilated air layers:
high emissivity surfaces**

Thickness of air layer mm	Direction of heat flow		
	Upwards	Horizontal	Downwards
0	0,00	0,00	0,00
5	0,11	0,11	0,11
7	0,13	0,13	0,13
10	0,15	0,15	0,15
15	0,16	0,17	0,17
25	0,16	0,18	0,19
50	0,16	0,18	0,21
100	0,16	0,18	0,22
300	0,16	0,18	0,23

NOTE - Intermediate values may be obtained by linear interpolation.

An air layer having no insulation layer between it and the external environment but with small openings to the external environment shall also be considered as an unventilated air layer, if these openings are not arranged so as to permit air flow through the layer and they do not exceed:

- 500 mm² per m length for vertical air layers
- 500 mm² per m² of surface area for horizontal air layers.¹⁾

NOTE - Drain openings (weep holes) in the form of open vertical joints in the outer leaf of a masonry cavity wall are not regarded as ventilation openings.

5.3.2 Slightly ventilated air layer

A slightly ventilated air layer is one in which there is provision for limited air flow through it from the external environment by openings within the following ranges:

- > 500 mm² but ≤ 1500 mm² per m length for vertical air layers
- > 500 mm² but ≤ 1500 mm² per m² of surface area for horizontal air layers.¹⁾

The design thermal resistance of a slightly ventilated air layer is one half of the corresponding value in table 2. If, however, the thermal resistance between the air layer and the external environment exceeds 0,15 m²·K/W, it shall be replaced by the value 0,15 m²·K/W.

iTeh STANDARD PREVIEW

5.3.3 Well ventilated air layer (standards.iteh.ai)

A well ventilated air layer is one for which the openings between the air layer and the external environment exceed: <https://standards.iteh.ai/catalog/standards/sist/b26e7d1d-c3d8-407b-89ee-357314a7804d/iso-6946-1996>

- 1500 mm² per m length for vertical air layers
- 1500 mm² per m² of surface area for horizontal air layers.¹⁾

The total thermal resistance of a building component containing a well-ventilated air layer shall be obtained by disregarding the thermal resistance of the air layer and all other layers between the air layer and external environment, and including an external surface resistance corresponding to still air (i.e. equal to the internal surface resistance of the same component).

¹⁾ For vertical air layers the range is expressed as the area of openings per metre length. For horizontal air layers it is expressed as the area of openings per square metre area.

5.4 Thermal resistance of unheated spaces

When the external envelope of the unheated space is not insulated the following simplified procedures, treating the unheated space as a thermal resistance, may be applied.

NOTE - ISO/DIS 13789, *Thermal performance of buildings - Transmission heat loss coefficient - Calculation method*, gives general, and more precise, procedures for the calculation of heat transfer from a building to the external environment via unheated spaces, and should be used when a more accurate result is required. For crawl spaces below suspended floors see ISO/DIS 13370, *Thermal performance of buildings - Heat transfer via the ground - Calculation method*.

5.4.1 Roof spaces

For a roof structure consisting of a flat, insulated ceiling and a pitched roof, the roof space may be regarded as if it were a thermally homogeneous layer with thermal resistance as given in table 3.

Table 3 - Thermal resistance of roof spaces

Characteristics of roof		R_u m ² ·K/W
1	Tiled roof with no felt, boards or similar	0,06
2	Sheeted roof, or tiled roof with felt or boards or similar under the tiles	0,2
3	As 2 but with aluminium cladding or other low emissivity surface at underside of roof	0,3
4	Roof lined with boards and felt	0,3

NOTE - The values in table 3 include the thermal resistance of the ventilated space and the thermal resistance of the (pitched) roof construction. They do not include the external surface resistance (R_{se}).

5.4.2 Other spaces

When the building has a small unheated space attached to it, the thermal transmittance between the internal and external environments can be obtained by treating the unheated space together with its external construction components as if it were an additional homogeneous layer with thermal resistance R_u given by:

$$R_u = 0,09 + 0,4 \frac{A_i}{A_u} \quad (2)$$

subject to $R_u \leq 0,5 \text{ m}^2\cdot\text{K/W}$, where

- A_i is the total area of all components between the internal environment and the unheated space;
- A_e is the total area of all components between the unheated space and the external environment.

NOTES

- 1 Examples of small unheated spaces include garages, store rooms and conservatories.
- 2 If there is more than one component between the internal environment and the unheated space, R_u should be included in the calculation of the thermal transmittance of each such component.

ITEH STANDARD PREVIEW

(standards.iteh.ai)

ISO 6946:1996

<https://standards.iteh.ai/catalog/standards/sist/b26e7d1d-c3d8-407b-89ee-357314a7804d/iso-6946-1996>