

TECHNICAL REPORT

RAPPORT TECHNIQUE



**Effects of current on human beings and livestock –
Part 4: Effects of lightning strokes**

**Effets du courant sur le corps humain et sur les animaux domestiques –
Partie 4: Effets de la foudre**

<https://standards.iteh.ai/catalog/standards/sis/4294003f-4695-411a-ab5c-51efb044e6e4/iec-tr-60479-4-2011>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL REPORT

RAPPORT TECHNIQUE



**Effects of current on human beings and livestock –
Part 4: Effects of lightning strokes**

**Effets du courant sur le corps humain et sur les animaux domestiques –
Partie 4: Effets de la foudre**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

S

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope and object.....	6
2 Normative references.....	6
3 Terms and definitions.....	6
4 Physics of lightning.....	9
5 Interaction of strokes with human beings and livestock.....	10
5.1 General.....	10
5.2 Description of direct strike.....	10
5.3 Description of contact voltage.....	11
5.4 Description of side flash.....	12
5.5 Description of step-voltage.....	13
5.6 Description of streamer shock.....	15
5.7 Description of flashover.....	16
6 Effects of lightning strokes on the body of human beings and livestock.....	16
6.1 General.....	16
6.2 Physiological effects.....	16
6.3 Pathophysiological effects.....	17
6.4 Thermal effects.....	17
6.5 Comparison between effects of electric shock derived from electrical systems and lightning.....	17
6.6 Percentage occurrence.....	17
Bibliography.....	20
Figure 1 – Categorization of lightning [4].....	10
Figure 2 – Direct stroke.....	11
Figure 3 – Contact voltage.....	12
Figure 4 – Side flash.....	13
Figure 5 – Step voltage.....	14
Figure 6 – Step voltage on quadrupeds.....	14
Figure 7 – Step voltage with side flash.....	15
Figure 8 – Upward streamer current.....	16
Table 1 – Causes of lightning death and most typical reported consequent disorders [11-16], [20].....	18
Table 2 – Differences between low voltage and high voltage injuries from electrical systems, and lightning injuries [1], [11-16], [20].....	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –**Part 4: Effects of lightning strokes**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 60479-4, which is a technical report, has been prepared by technical committee No.64: Electrical installations and protection against electric shock.

This second edition cancels and replaces the first edition, published in 2004 and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- the report has been completed with additional information on the influences and effects of natural electricity in the form of lightning strokes during thunderstorms;
- the definitions and technical terms have been updated;

- the explanation of the basic physical mechanisms for the dynamics of lightning where specified;
- the references to the relevant literature and the list of bibliography are updated;
- figures showing the current path during different interactions of lightning with the victim's body are updated.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
64/1772/DTR	64/1804/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60479 series, under the general title *Effects of current on human beings and livestock*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 60479-1, IEC 60479-2 and IEC 60479-3 deal with the effect of electric shock derived from electrical systems on the bodies of human beings and livestock. This part of IEC 60479, which is a technical report, describes the influence and effect of natural electricity in the form of lightning strokes during thunderstorms. Lightning current can consist of several uni-polar and/or bi-polar impulses with different peak values and durations; Clause 6 of IEC/TS 60479-2:2007[24]¹ does not cover these effects.

The interaction of a lightning stroke with the victim's body is quite different from the usual experience with electric shock derived from electrical systems. The pathway often includes the head in lightning accidents. The importance of the cranial orifices as points of entry of lightning current has been noted, and from these the proximity of the pathway to the brainstem. The brain stem includes the respiratory centre, in contrast with pathways of shock current arising from electrical systems. In particular it should be pointed out that differences exist between accidents caused by a direct flash compared with those interactions which are caused by step voltages. Even very short single impulses of lightning can cause cardiopulmonary arrest [5], [6], [15] and [16].

The intense electric interactions with living organisms are very dangerous but, surprisingly in many cases, not always lethal. It is accepted that more than 90 % of lightning accidents involving humans are not fatal [1], [12]. Corresponding reliable data for livestock is not known. There is a large variation in outcome due to different environments, different activities of people and knowledge of first aid and quality of medical care [1], [5].

It has been necessary, therefore, to create a separate standard concerning the special effects of lightning strokes. The physical behaviour of lightning is shown as a basis. The interaction with a living body is then described, followed by the consequences for the life of the victim.

IEC TR 60479-4:2011

<https://standards.iteh.ai/catalog/standards/sis/429403f-4695-411a-ab5c-51e1b044c6e4/iec-tr-60479-4-2011>

¹ References in square brackets refer to the bibliography.

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –

Part 4: Effects of lightning strokes

1 Scope and object

This part of IEC 60479, which is a technical report, summarizes the basic parameters for lightning and their variability insofar as they apply to human beings and livestock.

The possible direct and indirect interactions of strikes with bodies of living beings are indicated and the resulting effects caused by lightning currents for the organism are described.

The object of this report is to show the differences of effects on human beings and livestock due to lightning strokes versus those effects of electric shocks derived from electrical systems.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TS 60479-1:2005, *Effects of current on human beings and livestock – Part 1: General aspects*

<https://standards.iteh.ai/catalog/standards/sis/429403f-4695-411a-ab5c-51e1b044c6e4/iec-tr-60479-4-2011>

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC/TS 60479-1, in addition to the following definitions, apply.

3.1 Definitions of technical terms

3.1.1

lightning flash

atmospheric discharge consisting of one or more strokes

3.1.2

lightning stroke

single electrical discharge in a lightning flash

3.1.3

lightning channel

conducting path of the lightning current

3.1.4

stepped and connecting leader

stepped leader stepping down from a cloud and a connecting leader stepping up from points of field concentration beneath, noting that they are low current non-luminous processes leading to the return stroke when the two connect

3.1.5**main stroke**

return stroke

bright lightened stroke with strong current discharge, which is initiated at that moment when the stepped and connecting leader comes into contact with the earth

3.1.6**downward flash**

lightning flash initiated by a downward leader from a cloud to earth

3.1.7**upward flash**

lightning flash initiated by an upward leader from earth to cloud; that part of a stroke when the leader grows from earth to cloud

3.1.8**continuing current**

mean current of the long-lasting component of the lightning current

3.1.9**peak value of current**

maximum value of the lightning current

NOTE Values are given in Table A.2 and Figure A.5 of IEC 62305-1:2010 [7].

3.1.10**flash charge**

time integral of the lightning current for the entire lightning duration

NOTE This value ranges from 0,2 °C to 350 °C for the majority of positive and negative lightning strokes [7].

3.1.11**impulse charge**

short stroke charge

time integral of the lightning current for the impulse part of the lightning duration

NOTE This value ranges from 0,22 °C to 150 °C for the majority of positive and negative lightning strokes [7].

3.1.12**specific energy**

energy dissipated by the lightning current in a unit resistance

NOTE It is the integral of the square of the lightning current for the duration of the lightning. This value ranges from $6 \times 10^3 \text{ J}/\Omega$ to $1,5 \times 10^7 \text{ J}/\Omega$ for the majority of positive and negative lightning strokes [7].

3.1.13**average steepness of current wave front**

average rate of change of current calculated over 10 % to 90 % of peak amplitude of the wave front [7]

NOTE This value ranges from 0,2 kA/ μs to 99 kA/ μs for the majority of positive and negative lightning strokes.

3.1.14**stroke duration**

Time from the initiation of an atmospheric discharge until the time that particular stroke has been extinguished (the range of 3.1.5) and is 15 μs to 2000 μs for the majority of positive and negative lightning strokes [7]

3.1.15

stroke interval

time interval between the beginnings of successive strokes

3.1.16

total flash duration

Time from the beginning the first stroke to the end of the last stroke with a time range of 0,1 ms to 1100 ms for the majority of positive and negative lightning flashes [7]

NOTE 1 Experience shows that the statistical distribution of the parameters of total flash duration as expressed by Definition 3.1.16, can be assumed to have a logarithmic normal distribution.

NOTE 2 A flash is made up of a number of strokes. A continuing current may result and continue for some time. The duration of the flash is therefore dependent on the stroke duration, the number of strokes of the flash and the duration of any continuing current. All of these are variable and statistically described.

3.2 Definitions of interactions

3.2.1

direct stroke

interaction whereby the tip of the stepped and connecting leader attaches directly to the living being (see Figure 2)

3.2.2

contact voltage

potential difference between accessible points when touched simultaneously by a living being (see Figure 3)

NOTE In some texts this has been erroneously referred to as “contact potential” or “touch voltage”

3.2.3

side flash

electric arc between two objects, at least one of which is contacted by lightning (see Figures 4 and 7)

3.2.4

step voltage

voltage on the earth's surface between two points

[IEC 60050-195:1998, 195-05-12, modified] [25]

NOTE The possible resulting currents are shown in Figures 5 and 7. .

3.2.5

streamer current

current flowing through an individual as that individual serves as the starting point for an upward streamer which ultimately does not join a stepped leader to form a conducting channel (see Figure 8)

3.2.6

flashover

electric arc over the surface of the body carrying a significant proportion of the current

NOTE It may occur with the other combinations above (see Figure 2).

3.3 Definitions of effects on organisms

3.3.1

physiological effects

reaction due to external electrical stimulation of excitable cells, such as all kinds of skeletal muscle, smooth muscle of arteries and veins, cardiac muscle, nerves and all the structures of the brain

NOTE These effects are transient and stimulate the tissue within the limits of physiological function.

3.3.2

pathophysiological effects

stimulatory or inhibitory effects which lead to reversible or irreversible dysfunction of the affected structures of the organism

NOTE 1 These effects are of long duration and are produced by stimuli outside usual physiological magnitudes

NOTE 2 This group of effects includes keraunoparalysis which is a transient paralysis of the muscular structures in the line of the current. Its cause is uncertain.

3.3.3

thermal effect

pathophysiological effect of electrical current which results from local and transient heating of the affected structures up to temperatures where parts of cells and organelles become denatured

NOTE The effect of evaporation remains to be proved [17].

4 Physics of lightning

The explanation of the basic physical mechanisms for the onset and the dynamics of lightning is very complicated. Recent explanation takes into account that a tripolar layered cloud is generated by microscopic charge transfer between soft hail particles (also called graupel) and ice crystals [3].

Lightning is a transient, high-current discharge whose path length is measured in kilometres. Well over half of all flashes occur wholly within the cloud and are called intra-cloud (IC) discharges. Cloud-to-ground (CG) lightning has been studied more extensively than other forms of lightning because of its practical importance (for instance, as a cause for injuries and death, disturbances in power and communication systems and the ignition of forest fires) and because lightning below a cloud is more easily studied with optical techniques. Cloud-to-cloud and cloud-to-air discharges occur less frequently than either IC or CG lightning. All discharges other than CG are often combined under the general term "cloud discharges".

Four different types of discharges between cloud and earth have been identified (Figure 1). Negative CG flashes probably account for about 90 % of the CG discharges world-wide (Figure 1a), and less than 10 % of lightning discharges are initiated by a downward-moving positive leader (Figure 1c) [4]. Ground-to-cloud discharges are initiated by leaders that move upward from the earth (Figure 1b et 1d). These upward-initiated flashes are relatively rare and usually occur from mountain peaks and tall man-made structures [3].

Other important physical parameters are the specific energy per stroke, the average steepness of current rise within a stroke, as well as the stroke duration and total flash duration where there is more than one stroke in a flash.

The mechanical effects are related to the peak value of the current and specific energy. The thermal effects are related to the specific energy when resistive coupling is involved and to the total charge or impulse charge when arcs develop. The highest peak values, specific energy and impulse energy occur in positive lightning strokes.

The inductive coupling is related to the steepness of the lightning current front. The highest value of this parameter occurs in subsequent negative strokes [5].

Thunder accompanies lightning and is generated by super-heated air at the channel, which causes air pressure waves.




Figure 1a – Lightning begins with a negative charged leader moving downwards




Figure 1b – Lightning has a positively charged leader, and hence this type effectively lowers negative charge to earth




Figure 1c – Discharges are initiated by a downward moving positive leader



Figure 1d – The leader is charged negatively and effectively lowers positive charge (reprinted from [4])

Figure 1 – Categorization of lightning [4]

5 Interaction of strokes with human beings and livestock


5.1 General

The possible interaction of lightning with human beings and livestock depends on the resulting time course and pathway of the current in the body and on its surface. As the temporal and spatial current distribution of strokes varies, so the effects on living organisms are different. The effects of magnetic fields derived from the lightning stroke upon a living organism are not thought to be significant [23].

5.2 Description of direct strike

When the tip of the downward stepped leader has reached a height of some tens of metres above ground level, the resulting field strength attains a critical value so that a short upward streamer can be initiated from a conductive object or victim. The flow of current of the whole discharge goes direct via the victim's body (Figure 2).

A description of direct lightning stroke interaction is given in 5.6.



IEC 989/04

Key

- i_B body current
 i_s surface flashover current

Figure 2 – Direct stroke**5.3 Description of contact voltage**

When an object, not necessarily metallic, is struck by lightning, points on its surface are raised in potential. When a person contacts one of these points and another, possibly earth, to complete a circuit, partial lightning current will flow through that person. This contact voltage is determined by a resistive and an inductive component [5] (Figure 3).

$$u = i_L R + L di_L / dt$$

where

- u is the resulting contact voltage;
 i_L is the current through a vertical structure;
 R is the resistance between the points of contact;
 L is the inductance between the points of contact.