

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 5-19: Application layer service definition – Type 19 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-19: Définition des services de la couche application – Eléments
de Type 19**

IEC 61158-5-19:2010

<https://standards.iteh.ai/standards/iec/61158-5-19:2010>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 5-19: Application layer service definition – Type 19 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-19: Définition des services de la couche application – Eléments
de Type 19**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 25.04.40; 35.100.70; 35.110

ISBN 978-2-88912-863-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
1.1 Overview.....	7
1.2 Specifications.....	8
1.3 Conformance.....	8
2 Normative references.....	8
3 Terms, definitions, abbreviations, symbols and conventions.....	9
3.1 ISO/IEC 7498-1 terms.....	9
3.2 ISO/IEC 8822 terms.....	9
3.3 ISO/IEC 9545 terms.....	9
3.4 ISO/IEC 8824 terms.....	9
3.5 Fieldbus application-layer specific definitions.....	9
3.6 Abbreviations and symbols.....	11
3.7 Conventions.....	11
4 Concepts.....	14
5 Data type ASE.....	14
5.1 Bitstring types.....	15
5.2 Unsigned types.....	15
5.3 Integer types.....	16
5.4 Floating Point types.....	17
5.5 Structure types.....	17
6 Communication model specification.....	17
6.1 Concepts.....	17
6.2 ASEs.....	18
6.3 ARs.....	30
6.4 Summary of AR classes.....	31
6.5 Permitted FAL services by AREP role.....	32
Bibliography.....	33
Table 1 – Read service parameters.....	19
Table 2 – Write service parameters.....	20
Table 3 – Read service parameters.....	22
Table 4 – Write service parameters.....	22
Table 5 – Notify service parameters.....	23
Table 6 – Get network status service parameters.....	24
Table 7 – Get device status service parameters.....	25
Table 8 – Network status change report service parameters.....	25
Table 9 – Station status AR change report service parameters.....	26
Table 10 – Set device status service parameters.....	26
Table 11 – Enable RTC service parameters.....	27
Table 12 – Enable hotplug service parameters.....	28
Table 13 – Notify RTC service parameters.....	29
Table 14 – Disable RTC service parameters.....	29

Table 15 – AREP (SVC) class summary.....	31
Table 16 – AREP (RTC-MS) class summary	31
Table 17 – AREP (RTC-CC) class summary.....	32
Table 18 – FAL services by AR type	32

Withdrawing

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 5-19: Application layer service definition –
Type 19 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE 1 Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the profile parts. Use of the various protocol types in other combinations may require permission of their respective intellectual-property-right holders.

International Standard IEC 61158-5-19 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2007. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- increasing the number of supported devices (511 instead of 254);

- introducing a communication version identification;
- adding a mechanism for remote address allocation;
- introducing enhanced parameter addressing (32 bit instead of 16 bit);
- restructuring control and status word;
- improving the redundancy and hotplug features;
- improving the error handling;
- adding a multiplexing protocol (SMP: Type 19 Messaging Protocol).

This bilingual version published in 2012-01 corresponds to the English version published in 2010-08.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/606/FDIS	65C/620/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version has not been voted upon.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

NOTE 2 The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

Withdrawing

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

<https://standards.iteh.ai/standards/iec/61158-5-19-2010>

<https://standards.iteh.ai/standards/iec/61158-5-19-2010>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-19: Application layer service definition – Type 19 elements

1 Scope

1.1 Overview

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 19 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This standard specifies the structure and services of the fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the application layer services as defined in this standard.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60559, *Binary floating-point arithmetic for microprocessor systems*

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-3-16:2007, *Industrial communication networks – Fieldbus specifications – Part 3-16: Data-link layer service definition – Type 16 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824, *Information Technology – Open Systems Interconnection – Specification of Abstract Syntax Notation One (ASN.1)*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10646-1, *Information technology – Universal Multiple-Octet Coded Character Set (UCS) – Architecture and Basic Multilingual Plane*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

3 Terms, definitions, abbreviations, symbols and conventions

For the purposes of this document, the following terms as defined in these publications apply:

3.1 ISO/IEC 7498-1 terms

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.2 ISO/IEC 8822 terms

- a) abstract syntax
- b) presentation context

3.3 ISO/IEC 9545 terms

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.4 ISO/IEC 8824 terms

- a) object identifier
- b) type

3.5 Fieldbus application-layer specific definitions

3.5.1

coded character set; code

set of unambiguous rules that establish a character set and one-to-one relationship between the characters of the set and their representation by one or more bit combinations

3.5.2

cross communication

direct data transfer between slave devices (without active involvement of master)

3.5.3

cycle time

duration of a communication cycle

3.5.4

cyclic data

part of a telegram, which does not change its meaning during cyclic operation of the network

3.5.5

device

a slave in the communication network, (e.g., a power drive system as defined in the IEC 61800 standard family, I/O stations as defined in the IEC 61131 standard family).

3.5.6

device status

four adjacent octets inside the acknowledge telegram containing status information for each device

3.5.7

element

part of IDNs – each IDN has 7 elements, whereas each one has a specific meaning (e.g., number, name, data)

3.5.8

hot plug

possibility to open the communication network and insert or remove slaves while the network is still in real-time operation

3.5.9

identification number

designation of operating data under which a data block is preserved with its attribute, name, unit, minimum and maximum input values, and the data

3.5.10

loopback

mode by which a device passes on a received telegram to the same port and to the other port, either changed or unchanged

3.5.11

master

node, which assigns the other nodes (i.e., slaves) the right to transmit

3.5.12

physical layer

first layer of the ISO-OSI reference model

3.5.13

protocol

convention about the data formats, time sequences, and error correction in the data exchange of communication systems

3.5.14

service channel

SVC

non real-time transmission of information upon master request during RT channel

3.5.15**slave**

node, which is assigned the right to transmit by the master

3.5.16**station**

node

3.5.17**topology**

physical network architecture with respect to the connection between the stations of the communication system

3.6 Abbreviations and symbols

AHS	Service transport handshake of the device (acknowledge HS)
AP	Application Process
APO	Application Object
AR	Application Relationship
AREP	Application Relationship End Point
ASE	Application Service Element
CC-data	Cross Communication
Cnf	Confirmation
DA	Destination address
DAT	Duration of acknowledge telegram
FAL	Fieldbus Application Layer
ID	Identification Number
IDN	Identification Number
Ind	Indication
MS	Master Slave
NRC	Non Real Time Channel
Req	Request
Rsp	Response
RTC	Real Time Channel
RTE	Real Time Ethernet

3.7 Conventions**3.7.1 Overview**

The FAL is defined as a set of object-oriented ASEs. Each ASE is specified in a separate subclause. Each ASE specification is composed of two parts, its class specification, and its service specification.

The class specification defines the attributes of the class. The attributes are accessible from instances of the class using the Object Management ASE services specified in Clause 5 of this standard. The service specification defines the services that are provided by the ASE.

3.7.2 General conventions

This standard uses the descriptive conventions given in ISO/IEC 10731.

3.7.3 Conventions for class definitions

Class definitions are described using templates. Each template consists of a list of attributes for the class. The general form of the template is shown below:

FAL ASE:		ASE Name
CLASS:		Class name
CLASS ID:		#
PARENT CLASS:		Parent class name
ATTRIBUTES:		
1	(o)	Key Attribute: numeric identifier
2	(o)	Key Attribute: name
3	(m)	Attribute: attribute name(values)
4	(m)	Attribute: attribute name(values)
4.1	(s)	Attribute: attribute name(values)
4.2	(s)	Attribute: attribute name(values)
4.3	(s)	Attribute: attribute name(values)
5.	(c)	Constraint: constraint expression
5.1	(m)	Attribute: attribute name(values)
5.2	(o)	Attribute: attribute name(values)
6	(m)	Attribute: attribute name(values)
6.1	(s)	Attribute: attribute name(values)
6.2	(s)	Attribute: attribute name(values)
SERVICES:		
1	(o)	OpsService: service name
2.	(c)	Constraint: constraint expression
2.1	(o)	OpsService: service name
3	(m)	MgtService: service name

- (1) The "FAL ASE:" entry is the name of the FAL ASE that provides the services for the class being specified.
- (2) The "CLASS:" entry is the name of the class being specified. All objects defined using this template will be an instance of this class. The class may be specified by this standard, or by a user of this standard.
- (3) The "CLASS ID:" entry is a number that identifies the class being specified. This number is unique within the FAL ASE that will provide the services for this class. When qualified by the identity of its FAL ASE, it unambiguously identifies the class within the scope of the FAL. The value "NULL" indicates that the class cannot be instantiated. Class IDs between 1 and 255 are reserved by this standard to identify standardized classes. They have been assigned to maintain compatibility with existing national standards. CLASS IDs between 256 and 2048 are allocated for identifying user defined classes.
- (4) The "PARENT CLASS:" entry is the name of the parent class for the class being specified. All attributes defined for the parent class and inherited by it are inherited for the class being defined, and therefore do not have to be redefined in the template for this class.

NOTE The parent-class "TOP" indicates that the class being defined is an initial class definition. The parent class TOP is used as a starting point from which all other classes are defined. The use of TOP is reserved for classes defined by this standard.

- (5) The "ATTRIBUTES" label indicate that the following entries are attributes defined for the class.
 - a) Each of the attribute entries contains a line number in column 1, a mandatory (m) / optional (o) / conditional (c) / selector (s) indicator in column 2, an attribute type label in column 3, a name or a conditional expression in column 4, and optionally a list of enumerated values in column 5. In the column following the list of values, the default value for the attribute may be specified.