

INTERNATIONAL STANDARD

Industrial communication networks – Fieldbus specifications –
Part 6-18: Application layer protocol specification – Type 18 elements
(standards.iteh.ai)

IEC 61158-6-18:2010

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-e0257d03b5cc/iec-61158-6-18-2010>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD PREVIEW

(standards.iteh.ai)

IEC 61158-6-18:2010

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c->

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c->



IEC 61158-6-18

Edition 2.0 2010-08

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 6-18: Application layer protocol specification – Type 18 elements**

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-e0257d03b5cc/iec-61158-6-18-2010>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XA**

ICS 25.04.40; 35.100.70; 35.110

ISBN 978-2-88912-132-8

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 General.....	8
1.2 Specifications.....	8
1.3 Conformance.....	9
2 Normative references	9
3 Terms and definitions	9
3.1 Terms and definitions from other ISO/IEC standards	9
3.2 Other terms and definitions	10
3.3 Abbreviations and symbols.....	16
3.4 Additional abbreviations and symbols for type 18	16
3.5 Conventions	17
4 Abstract syntax.....	17
4.1 M1 device manager PDU abstract syntax	17
4.2 M2 device manager PDU abstract syntax	17
4.3 S1 device manager PDU abstract syntax.....	18
4.4 S2 device manager PDU abstract syntax.....	18
4.5 M1 connection manager PDU abstract syntax.....	18
4.6 M2 connection manager PDU abstract syntax.....	19
4.7 S1 connection manager PDU abstract syntax	19
4.8 S2 connection manager PDU abstract syntax.....	20
4.9 M1 cyclic transmission PDU abstract syntax.....	20
4.10 M2 cyclic transmission PDU abstract syntax.....	20
4.11 S1 cyclic transmission PDU abstract syntax	21
4.12 S2 cyclic transmission PDU abstract syntax	21
4.13 Acyclic transmission PDU abstract syntax	21
5 Transfer syntax	22
5.1 M1 device manager PDU encoding.....	22
5.2 M2 device manager PDU encoding.....	25
5.3 S1 device manager PDU encoding	26
5.4 S2 device manager PDU encoding	26
5.5 M1 connection manager PDU encoding	27
5.6 M2 connection manager PDU encoding	31
5.7 S1 connection manager PDU encoding.....	32
5.8 S2 connection manager PDU encoding.....	33
5.9 M1 cyclic transmission PDU encoding	33
5.10 M2 cyclic transmission PDU encoding	35
5.11 S1 cyclic transmission PDU encoding.....	36
5.12 S2 cyclic transmission PDU encoding.....	37
5.13 Acyclic transmission PDU encoding.....	38
6 Structure of FAL protocol state machines	45
7 AP-context state machine.....	47
8 FAL service protocol machine (FSPM).....	47
8.1 Overview	47
8.2 FAL service primitives	47

9	AR protocol machine (ARPM)	48
9.1	Overview	48
9.2	M1 master ARPM	49
9.3	M2 master ARPM	53
9.4	Slave ARPM	56
10	DLL mapping protocol machine (DMPM)	59
10.1	Overview	59
10.2	Primitives received from the ARPM	59
10.3	Indications received from the DL	59
	Bibliography	60
	Figure 1 – Parameter block 1 command parameter field	40
	Figure 2 – Parameter block 2 command parameter field	41
	Figure 3 – Relationships among protocol machines and adjacent layers	46
	Figure 4 – ARPM M1 master AR state diagram	49
	Figure 5 – ARPM M2 master AR state diagram	53
	Figure 6 – ARPM slave AR state diagram	56
	Table 1 – M1 device manager attribute format	17
	Table 2 – M2 device manager attribute format	17
	Table 3 – S1 device manager attribute format	18
	Table 4 – S2 device manager attribute format	18
	Table 5 – M1 connection manager attribute format	18
	Table 6 – M2 connection manager attribute format	19
	Table 7 – S1 connection manager attribute format	20
	Table 8 – S2 connection manager attribute format	20
	Table 9 – M1 cyclic transmission attribute format	20
	Table 10 – M2 cyclic transmission attribute format	21
	Table 11 – S1 cyclic transmission attribute format	21
	Table 12 – S2 cyclic transmission attribute format	21
	Table 13 – Acyclic transmission attribute format	21
	Table 14 – M1 device manager attribute encoding	23
	Table 15 – M2 device manager attribute encoding	25
	Table 16 – S1 device manager attribute encoding	26
	Table 17 – S2 device manager attribute encoding	27
	Table 18 – M1 connection manager attribute encoding	28
	Table 19 – M2 connection manager attribute encoding	31
	Table 20 – S1 connection manager attribute encoding	32
	Table 21 – S2 connection manager attribute encoding	33
	Table 22 – M1 cyclic transmission attribute encoding	34
	Table 23 – M2 cyclic transmission attribute encoding	36
	Table 24 – S1 cyclic transmission attribute encoding	36
	Table 25 – S2 cyclic transmission attribute encoding	38
	Table 26 – Acyclic transmission – message data encoding	38

Table 27 – Command header format	39
Table 28 – Command codes	39
Table 29 – System information command parameter field	42
Table 30 – System information command parameter field	42
Table 31 – System information command parameter field	42
Table 32 – System information command parameter field	43
Table 33 – Line test command parameter field	43
Table 34 – Memory read command parameter field	44
Table 35 – Memory write command parameter field	45
Table 36 – FSPM events	48
Table 37 – M1 master state-event table 1 – events	51
Table 38 – M1 master state-event table 2 – receipt of FSPM service primitives	51
Table 39 – M1 master state-event table 3 – receipt of DMPM service primitives	53
Table 40 – M2 master state-event table 1 – events	54
Table 41 – M2 master state-event table 2 – receipt of FSPM service primitives	55
Table 42 – M2 master state-event table 3 – receipt of DMPM service primitives	55
Table 43 – S1 connect monitoring time	57
Table 44 – S2 connect monitoring time	57
Table 45 – Slave state-event table 1 – events	58
Table 46 – Slave state-event table 2 – receipt of FSPM service primitives	58
Table 47 – Slave state-event table 3 – receipt of DMPM service primitives	58
Table 48 – ARPM to DL mapping	59
Table 49 – DL to ARPM mapping	59

STANDARD PREVIEW
 (standards site)
<https://standards.iec.org/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-0257d03b5cc4ec-61158-6-18-2010>
 IEC 61158-6-18:2010

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 6-18: Application layer protocol specification –
Type 18 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard IEC 61158-6-18 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2007. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- editorial corrections;
- addition of cyclic data segmenting.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/607/FDIS	65C/621/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

NOTE The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 61158-6-18:2010

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-e0257d03b5cc/iec-61158-6-18-2010>

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementers and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the profile parts. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning Type 18 elements and possibly other types given in subclause 4.5, 5.5, 6.9.2 and 9.2.2 as follows:

3343036/Japan	[MEC]	“Network System for a Programmable Controller”
5896509/USA	[MEC]	“Network System for a Programmable Controller”
246906/Korea	[MEC]	“Network System for a Programmable Controller”
19650753/Germany	[MEC]	“Network System for a Programmable Controller”

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

[MEC] Mitsubishi Electric Corporation
Corporate Licensing Division
7-3, Marunouchi 2-chome, Chiyoda-ku,
Tokyo 100-8310, Japan

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (http://www.iec.ch/tctools/patent_decl.htm) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-18: Application layer protocol specification – Type 18 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs”.

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 18 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard specifies interactions between remote applications and defines the externally visible behavior provided by the Type 18 fieldbus application layer in terms of

- a) the formal abstract syntax defining the application layer protocol data units conveyed between communicating application entities;
- b) the transfer syntax defining encoding rules that are applied to the application layer protocol data units;
- c) the application context state machine defining the application service behavior visible between communicating application entities;
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this standard is to define the protocol provided to

- a) define the wire-representation of the service primitives defined in IEC 61158-5-18, and
- b) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the Type 18 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

1.2 Specifications

The principal objective of this standard is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-18.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in the IEC 61158-6 series.

1.3 Conformance

This standard does not specify individual implementations or products, nor do they constrain the implementations of application layer entities within industrial automation systems. Conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158-5-18:2010¹, *Industrial communication networks – Fieldbus specifications – Part 5-18: Application layer service definition – Type 18 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

3 Terms and definitions

3.1 Terms and definitions from other ISO/IEC standards

3.1.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 ISO/IEC 8822 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8822 apply:

¹ to be published.

- a) abstract syntax
- b) presentation context

3.1.3 ISO/IEC 9545 terms

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.1.4 ISO/IEC 8824-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8824-1 apply:

- a) object identifier
- b) type

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.2 Other terms and definitions

For the purposes of this document, the following terms and definitions apply.

<https://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-e0257d03b5cc/iec-61158-6-18-2010>

3.2.1 alarm

activation of an event that shows a critical state

3.2.2 alarm ack

acknowledgment of an event that shows a critical state

3.2.3 application

function or data structure for which data is consumed or produced

3.2.4 application layer interoperability

capability of application entities to perform coordinated and cooperative operations using the services of the FAL

3.2.5 application objects

multiple object classes that manage and provide a run time exchange of PDUs across the network and within the network device

3.2.6 application process

part of a distributed application on a network, which is located on one device and unambiguously addressed

3.2.7

application process identifier

distinguishes multiple application processes used in a device

NOTE Application process identifier is assigned by PROFIBUS International (PI).

3.2.8

application process object

component of an application process that is identifiable and accessible through an FAL application relationship

NOTE Application process object definitions are composed of a set of values for the attributes of their class (see the definition for Application Process Object Class Definition). Application process object definitions may be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to dynamically create and delete application objects and their corresponding definitions.

3.2.9

application process object class

a class of application process objects defined in terms of the set of their network-accessible attributes and services

3.2.10

application relationship

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation. This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities

3.2.11

application relationship application service element

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.2.12

application relationship endpoint

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

NOTE Each application process involved in the application relationship maintains its own application relationship endpoint.

3.2.13

attribute

description of an externally visible characteristic or feature of an object

NOTE The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behavior of an object. Attributes are divided into class attributes and instance attributes.

3.2.14

backup

status of the IO AR, which indicates that it, is in the standby state

3.2.15

behavior

indication of how an object responds to particular events

3.2.16

class

a set of objects, all of which represent the same kind of system component

NOTE A class is a generalization of an object; a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

3.2.17

class attributes

attribute that is shared by all objects within the same class

3.2.18

class code

unique identifier assigned to each object class

3.2.19

class specific service

service defined by a particular object class to perform a required function which is not performed by a common service

NOTE A class specific object is unique to the object class which defines it.

3.2.20

clear

status of the IO controller, which indicates that the control algorithm is currently not running

3.2.21

cyclic

repetitive in a regular manner

3.2.22

device

physical hardware connected to the link

NOTE A device may contain more than one node.

3.2.23

device ID

a vendor assigned device type identification

3.2.24

device profile

a collection of device dependent information and functionality providing consistency between similar devices of the same device type

3.2.25

diagnosis data object

object(s) which contains diagnosis information referenced by device/slot/subslot/index

3.2.26

diagnosis information

all data available at the server for maintenance purposes

3.2.27

endpoint

one of the communicating entities involved in a connection

3.2.28

engineering

abstract term that characterizes the client application or device responsible for configuring an automation system via interconnecting data items

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61158-6-18:2010](#)

<http://standards.iteh.ai/catalog/standards/sist/2d549c4c-7bbc-47c1-a24c-e0257d03b5cc/iec-61158-6-18-2010>

3.2.29**error**

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

3.2.30**error class**

general grouping for related error definitions and corresponding error codes

3.2.31**error code**

identification of a specific type of error within an error class

3.2.32**event**

an instance of a change of conditions

3.2.33**frame**

denigrated term for DLPPDU, unit of data transfer on a link

3.2.34**identification data object**

object(s) that contain information about device, module and sub-module manufacturer and type referenced by device/slot/subslot/index

3.2.35**implicit AR endpoint**

AR endpoint that is defined locally within a device without use of the create service

3.2.36**index**

address of a record data object within an application process

3.2.37**instance**

the actual physical occurrence of an object within a class that identifies one of many objects within the same object class

3.2.38**instance attributes**

attribute that is unique to an object instance and not shared by the object class

3.2.39**instantiated**

object that has been created in a device

3.2.40**interface**

collection of FAL class attributes and services that represents a specific view on the FAL class

3.2.41**invocation**

act of using a service or other resource of an application process

NOTE Each invocation represents a separate thread of control that may be described by its context. Once the service completes, or use of the resource is released, the invocation ceases to exist. For service invocations, a