

INTERNATIONAL STANDARD



~~Design criteria of~~ Overhead transmission lines – Design criteria

(<https://standards.iteh.ai>)
Document Preview

[IEC 60826:2017](#)

<https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

[IEC 60826:2017](https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017)

<https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017>



IEC 60826

Edition 4.0 2017-02
REDLINE VERSION

INTERNATIONAL STANDARD



~~Design criteria of~~ Overhead transmission lines – Design criteria

(<https://standards.iteh.ai>)
Document Preview

[IEC 60826:2017](https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017)

<https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.20

ISBN 978-2-8322-3960-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	7
1 Scope	9
2 Normative references	9
3 Terms, definitions, symbols and abbreviations	9
3.1 Terms and definitions	9
3.2 Symbols and abbreviations	12
4 General	15
4.1 Objective	15
4.2 System design	15
4.3 System reliability	16
5 General design criteria	16
5.1 Methodology	16
5.1.1 General	16
5.1.2 Reliability requirements	17
5.1.3 Security requirements	20
5.1.4 Safety requirements	20
5.2 Climatic Load-strength requirements	20
5.2.1 Limit Climatic loads	20
5.2.2 Design requirements for the system	21
5.2.3 Design-equation formula for each component	21
6 Loadings	22
6.1 Description	22
6.2 Climatic loads, wind and associated temperatures	23
6.2.1 General	23
6.2.2 Field of application	23
6.2.3 Terrain roughness	23
6.2.4 Reference wind speed V_R	24
6.2.5 Assessment of meteorological measurements	25
6.2.6 Determination from gradient wind velocities	26
6.2.7 Combination of wind speed and temperatures	26
6.2.8 Number of supports subjected in wind action, effect of length of line	27
6.2.9 Unit action of the wind speed on any line component or element	27
6.2.10 Evaluation of wind loads on line components and elements	28
6.3 Climatic loads, ice without wind	36
6.3.1 Description	36
6.3.2 Ice data	36
6.3.3 Evaluation of yearly maximum ice load by means of meteorological data analysis	37
6.3.4 Reference limit ice load	37
6.3.5 Temperature during icing	39
6.3.6 Loads on support	39
6.4 Climatic loads, combined wind and ice loadings	41
6.4.1 General	41
6.4.2 Combined probabilities – Principle proposed	41
6.4.3 Determination of ice load	42
6.4.4 Determination of coincident temperature	42

6.4.5	Determination of wind speed associated with icing conditions.....	42
6.4.6	Drag coefficients of ice-covered conductors.....	43
6.4.7	Determination of loads on supports.....	44
6.5	Loads for construction and maintenance (safety loads).....	45
6.5.1	General.....	45
6.5.2	Erection of supports.....	45
6.5.3	Construction stringing and sagging.....	46
6.5.4	Maintenance loads.....	46
6.6	Loads for failure containment (security requirements).....	47
6.6.1	General.....	47
6.6.2	Security requirements.....	47
6.6.3	Security related loads – Torsional, longitudinal and additional security measures.....	47
7	Strength of components and limit states.....	49
7.1	General.....	49
7.2	General equations/formulas for the strength of components.....	49
7.2.1	General.....	49
7.2.2	Values of strength factor Φ_N	50
7.2.3	General basis for strength coordination.....	51
7.2.4	Strength factor Φ_S related to the coordination of strength.....	52
7.2.5	Methods for calculating strength coordination factors Φ_S	52
7.3	Data related to the calculation of components.....	53
7.3.1	Limit states for line components.....	53
7.3.2	Strength data of line components.....	56
7.3.3	Support design strength.....	57
7.3.4	Foundation design strength.....	58
7.3.5	Conductor and ground wire design criteria.....	58
7.3.6	Insulator string design criteria.....	58
Annex A (informative)	Technical information– Strength of line components.....	60
A.1	Calculation of characteristic strength.....	78
Annex B (informative)	Formulas of curves and figures.....	87
B.1	General.....	87
B.2	Formula for G_C – Figure 4.....	87
B.3	Formula for G_L – Figure 5.....	87
B.4	Formula for G_t – Figure 6.....	87
B.5	Formula for C_{xt} – Figure 8 (flat-sided members).....	87
B.6	Formula for C_{xt} – Figure 9 (round-sided members).....	88
B.7	Formulas for C_{xtc} – Figure 10.....	88
Annex C (informative) Statistical distribution and their application in probabilistic design of transmission lines.....		
Annex C (informative)	Atmospheric icing.....	89
C.1	General.....	89
C.2	Precipitation icing.....	89
C.2.1	Freezing rain.....	89
C.2.2	Wet snow.....	89
C.3	Dry ice.....	90
C.4	In-cloud icing.....	90
C.5	Physical properties of ice.....	91
C.6	Meteorological parameters controlling ice accretion.....	91

C.7	Terrain influences	92
C.7.1	In-cloud icing	92
C.7.2	Precipitation icing	92
C.8	Guidelines for the implementation of an ice observation program	92
C.9	Ice data	94
C.9.1	Influence of height and conductor diameter.....	94
C.9.2	The effect of icing on structures.....	95
C.10	Combined wind and ice loadings	95
C.10.1	Combined probabilities	95
C.10.2	Drag coefficients of ice-covered conductors.....	96
Annex D (informative)	Application of statistical distribution functions to load and strength of overhead lines.....	97
Annex E (informative)	Effect of span variation on load-strength relationship – Calculation of span use factor.....	105
E.1	General.....	105
E.2	Effect of use factor on load reduction and its calculation	106
Annex F (normative)	Conductor tension limits	124
F.1	General.....	124
F.2	Limits for lines with short spans	125
F.3	Recommended conductor limit tensions	125
F.3.1	Initial tension limit.....	125
F.3.2	Maximum final tension limit.....	126
F.4	Benefits from reducing conductor tensions.....	126
Annex G (informative)	Methods of calculation for wind speed up effects due to local topography.....	127
G.1	Application	127
G.2	Notes on application	128
Bibliography		130
Figure 1	– Diagram of a transmission line	16
Figure 2	– Transmission line design methodology	17
Figure 3	– Relationship between meteorological wind velocities at a height of 10 m depending on terrain category and on averaging period	26
Figure 4	– Combined wind factor G_C for conductors for various terrain categories and heights above ground	29
Figure 5	– Span factor G_L	30
Figure 6	– Combined wind factor G_t applicable to supports and insulator strings.....	31
Figure 7	– Definition of the angle of incidence of wind	33
Figure 8	– Drag coefficient C_{xt} for lattice supports made of flat sided members	33
Figure 9	– Drag coefficient C_{xt} for lattice supports made of rounded members.....	34
Figure 10	– Drag coefficient C_{xtc} of cylindrical elements having a large diameter	35
Figure 11	– Factor K_D related to the conductor diameter.....	38
Figure 12	– Factor K_h related to the conductor height.....	39
Figure 13	– Typical support types	40
Figure 14	– Equivalent cylindrical shape of ice deposit	44
Figure 15	– Simulated longitudinal conductor load (case of a single circuit support).....	48
Figure 16	– Diagram of limit states of line components	49

Figure A.1 – Relations between load and strength
Figure A.2 – Relations between loads and strengths
Figure A.3 – Failure probability $P_f = (1 - P_s)$ for various distributions of Q and R, for $T = 50$ years
Figure A.4 – Failure probability $P_f = (1 - P_s)$ for various distributions of Q and R, for $T = 150$ years
Figure A.5 – Failure probability $P_f = (1 - P_s)$ for various distributions of Q and R, for $T = 500$ years
Figure A.6 – Coordination of strength by using different exclusion limits
Figure A.8 – Wind action on conductors and resultant wind load on support
Figure B.1 – Fitting of Gumbel distribution with wind data histogram
Figure B.2 – Fitting of Gumbel distribution with yearly minimum temperature histogram
Figure B.3 – Fitting of Gamma distribution with ice load histogram
Figure B.4 – Fitting data from in-cloud icing with Gumbel distribution
Figure B.5 – Fitting of Weibull distribution with strength data of lattice supports
Figure C.1 – Probability density function of standardized normal distribution
Figure C.2 – Probability density function of standardized log-normal distribution
Figure C.3 – Probability density function of standardized Gumbel distribution
Figure C.4 – Probability density function of standardized Weibull distribution for parameter $p_3 = 0,5; 1,0$ and $2,0$
Figure C.5 – Probability density function of standardized Gamma distribution for parameter $p_3 = 0,5; 1,0$ and $2,0$
Figure C.6 – Probability density function of standardized beta distribution for parameters $r = 5,0$, $t = 5,5; 6,0$ and $7,0$
Figure C.1 – Type of accreted in-cloud icing as a function of wind speed and temperature	91
Figure C.2 – Strategy flow chart for utilizing meteorological data, icing models and field measurements of ice loads	93
Figure G.1 – Diagram of typical topographical cross-section	128
Table 1 – Reliability levels for transmission lines	18
Table 2 – Default γ_T factors for adjustment of climatic loads in relation to return period T versus 50 years	21
Table 3 – Design requirements for the system	21
Table 4 – Classification of terrain categories	24
Table 5 – Factors describing wind action depending on terrain category	25
Table 6 – Correction factor τ of dynamic reference wind pressure q_0 due to altitude and temperatures	28
Table 7 – Drag coefficient of polygonal pole sections	35
Table 8 – Drag coefficient of structures having a triangular section	36
Table 9 – Statistical parameters of ice loads	38
Table 10 – Non-uniform ice loading conditions	41
Table 11 – Return period of combined ice and wind load	42
Table 12 – Drag coefficients of ice-covered conductors	43
Table 13 – Additional security measures	49

Table 14 – Number of supports subjected to maximum load intensity during any single occurrence of a climatic event.....	50
Table 15 – Strength factor ϕ_N related to the number N of components or elements subjected to the critical load intensity.....	51
Table 16 – Values of ϕ_{S2}	52
Table 17 – Typical strength coordination of line components	52
Table 18 – Damage and failure limits of supports.....	54
Table 19 – Damage and failure limits of foundations	55
Table 20 – Damage and failure limits of conductors and ground wires	55
Table 21 – Damage and failure limit of interface components.....	56
Table 22 – Default values for strength coefficients of variation (COV).....	57
Table 23 – u factors for log-normal distribution function for $e = 10\%$	57
Table 24 – Value of quality factor ϕ_Q for lattice towers.....	58
Table A.1 – Yearly reliability corresponding to various assumptions of load and strength...	117
Table A.1 – Values of u_e associated to exclusion limits.....	79
Table A.2 – Relationship between reliability levels and return periods of limit loads	125
Table A.3 – Typical strength coordination	129
Table A.4 – Values of central safety factor α and strength coordination factor ϕ_S required to insure that component R_2 will fail after component R_1 with a 90 % probability.....	137
Table A.5 – Strength factor ϕ_N related to N components in series subjected to the critical load.....	143
Table A.7 – Definition of terrain category.....	151
Table A.9 – Values of reference wind speed V_R.....	157
Table B.2 – Parameters of Weibull distribution.....	199
Table B.3 – Statistical parameters \bar{U} and σ_U of wind span variation	203
Table B.4 – Statistical parameters \bar{U} and σ_U of weight span variation.....	205
Table B.6 – Use factor coefficient γ_U for different strength coefficients of variation.....	211
Table B.5 – Values of use factor coefficient γ_U as a function of U and N for $v_R = 0,10$	209
Table C.1 – Physical properties of ice	91
Table C.2 – Values of u_1 for given values of function $F_{(u_1)} = I(u_1, p_3 - 1)$.....	235
Table C.2 – Meteorological parameters controlling ice accretion	91
Table C.3 – Approximate values of ice weights on lattice structures.....	95
Table C.4 – Combined wind and ice loading conditions	95
Table C.5 – Drag coefficients and density of ice-covered conductors	96
Table D.1 – Parameters C_1 and C_2 of Gumbel distribution	98
Table D.2 – Ratios of x / \bar{x} for a Gumbel distribution function, T return period in years of loading event, n number of years with observations, v_x coefficient of variation	101
Table E.1 – Use factor coefficient γ_U.....	107
Table F.1 – Variation of conductor sag with catenary parameter C.....	125
Table F.2 – Conductor tensioning – recommended catenary parameter limits	126
Table G.1 – Values of μ and γ.....	128

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**DESIGN CRITERIA OF OVERHEAD TRANSMISSION LINES –
DESIGN CRITERIA**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60826 has been prepared by IEC technical committee 11: Overhead lines.

This fourth edition cancels and replaces the third edition published in 2003. It constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

This standard has been further simplified by removing many informative annexes and theoretical details that can now be found in CIGRE Technical Brochure 178 and referred to as needed in the text of the standard. Many revisions have also been made that reflect the users experience in the application of this standard, together with information about amplification of wind speed due to escarpments. The annexes dealing with icing data have also been updated using new work by CIGRE.

The text of this standard is based on the following documents:

FDIS	Report on voting
11/251/FDIS	11/252/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

~~DESIGN CRITERIA OF OVERHEAD TRANSMISSION LINES –~~ DESIGN CRITERIA

1 Scope

This International Standard specifies the loading and strength requirements of overhead lines derived from reliability-based design principles. These requirements apply to lines 45 kV and above, but can also be applied to lines with a lower nominal voltage.

This document also provides a framework for the preparation of national standards dealing with overhead transmission lines, using reliability concepts and employing probabilistic or semi-probabilistic methods. These national standards will need to establish the local climatic data for the use and application of this standard, in addition to other data that are country-specific.

Although the design criteria in this standard apply to new lines, many concepts can be used to address the **design and** reliability requirements for refurbishment, **upgrading** and uprating of existing lines.

This document does not cover the detailed design of line components such as ~~towers~~ **supports**, foundations, conductors or insulators **strings**.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60652:~~2002~~, *Loading tests on overhead line structures*

IEC 61089:~~1994~~, *Round wire concentric lay overhead electrical stranded conductors*

IEC 61773:~~1996~~, *Overhead lines – Testing of foundations for structures*

IEC 61774:~~1997~~, *Overhead lines – Meteorological data for assessing climatic loads*

IEC 61284:~~1997~~, *Overhead lines – Requirements and tests for fittings*

3 Terms, definitions, symbols and abbreviations

For the purposes of this document, the following terms, definitions, symbols and abbreviations apply.

3.1 Terms and definitions

3.1.1

characteristic strength

guaranteed strength, minimum strength, minimum failing load

R_c

strength value guaranteed in appropriate standards

Note 1 to entry: This value usually corresponds to an exclusion limit, from 2 % to 5 %, with 10 % being an upper practical (and conservative) limit.

3.1.2 coefficient of variation

COV

ratio of the standard deviation to the mean value

Note 1 to entry: The *COV* of load and strength are respectively denoted by v_Q and v_R .

3.1.3 components

different parts of a transmission line system having a specified purpose

Note 1 to entry: Typical components are ~~towers~~ supports, foundations, conductors and insulator strings.

3.1.4 damage limit (of a component) serviceability limit state

strength limit of a component corresponding to a defined limit of permanent (or inelastic) deformation of this component which leads to damage to the system if it is exceeded

Note 1 to entry: This limit is also called the serviceability limit state in building codes based on limit states design.

3.1.5 damage state (of the system)

state where the system needs repairing because one of its components has exceeded its damage limit

Note 1 to entry: The system needs repairing because it is not capable of fulfilling its task under design loads or because design clearances may be reduced (e.g. conductor to ground).

3.1.6 elements

different parts of a component

[IEC 60826:2017](https://standards.iteh.ai/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017)

<https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017>

Note 1 to entry: For example, the elements of a steel lattice tower are steel angles, plates and bolts.

3.1.7 exclusion limit

e %

value of a variable taken from its distribution function and corresponding to a probability of e % of not being exceeded

3.1.8 failure limit (of a component) ultimate limit state

strength limit of a component which leads to the failure of the system if this limit is exceeded

Note 1 to entry: If this strength limit is exceeded, the system will reach a state called “ultimate limit state” as defined in building codes based on limit states design.

3.1.9 failure state (of the system)

state of a system in which a major component has failed because one of its components has reached its failure limit (such as by rupture, buckling, overturning)

Note 1 to entry: This state leads to the termination of the ability of the line to transmit power and needs to be repaired.

3.1.10 intact state

state in which a system can accomplish its required function and can sustain limit loads

3.1.11 limit load

Q_T
climatic load corresponding to a return period, T , used for design purposes without additional load factors

Note 1 to entry: Refer to 5.2.1.

3.1.12 load factor

γ
factor to be multiplied by the limit load in order to design line components

3.1.13 operating period

general measure of useful (or economical) life

Note 1 to entry: Typical operating periods of transmission lines vary from 30 years to 80 years.

3.1.14 reference wind speed

V_R
wind speed at 10 m in height, corresponding to an averaging period of 10 min and having a return period T

Note 1 to entry: When this wind speed is taken in a terrain type B, which is the most common case in the industry, the reference wind speed is identified as V_{RB} .

3.1.15 reference ice load

g_R or t_R
reference limit ice loads (g_R is a unit ice weight and t_R is a uniform radial ice thickness around the conductor) having a return period T

<https://standards.iteh.ai/>

<https://standards.iteh.ai/catalog/standards/iec/cc7566ec-6b1c-4d30-b6f3-4856b2976572/iec-60826-2017>

3.1.16 reliability (structural)

probability that a system performs a given task, under a set of operating conditions, during a specified time

Note 1 to entry: Reliability is thus a measure of the success of a system in accomplishing its task. The complement to reliability is the probability of failure or unreliability.

3.1.17 return period (of a climatic event)

T
average occurrence in years of a climatic event having a defined intensity

Note 1 to entry: The inverse of the return period is the yearly frequency which corresponds to the probability of exceeding this climatic event in a given year.

3.1.18 safety

ability of a system not to cause human injuries or loss of lives

Note 1 to entry: In this document, safety relates mainly to protection of workers during construction and maintenance operations. The safety of the public and of the environment in general is covered by national regulations.

3.1.19 security (structural)

ability of a system to be protected from a major collapse (cascading effect) if a failure is triggered in a given component

Note 1 to entry: Security is a deterministic concept as opposed to reliability which is a probabilistic concept.

3.1.20 strength factor

Φ

factor applied to the characteristic strength of a component

Note 1 to entry: This factor takes into account the coordination of strength, the number of components subjected to maximum load, quality and statistical parameters of components.

3.1.21 system

set of components connected together to form the transmission line

3.1.22 task

function of the system (transmission line), i.e. to transmit power between its two ends

3.1.23 unavailability

inability of a system to accomplish its task

Note 1 to entry: Unavailability of transmission lines results from structural unreliability as well as from failure due to other events such as landslides, impact of objects, sabotage, defects in material, etc.

3.1.24 use factor

U

ratio of the actual load (as built) to limit load of a component

Note 1 to entry: For tangent ~~towers~~ supports, it is virtually equal to the ratio of actual to maximum design spans (wind or weight) and for angle ~~towers~~ supports; it also includes the ratio of the sines of the half angles of deviation (actual to design angles).

3.2 Symbols and abbreviations

a	Unit action of wind speed on line elements (Pa or N/m ²)
A_c	Wind force on conductors (N)
A_i	Wind force on insulators (N)
A_t	Wind force acting on a tower panel made of steel angles, A_{tc} for cylindrical tower members (N)
B_i	Reduction factor of the reference wind speed for wind and ice combinations
C_x	Drag coefficient (general form)
C_i	Drag coefficient of ice covered conductors (C_{iL} for low probability and C_{iH} for a high probability)
C_{xc}	Drag coefficient of conductors
C_{xi}	Drag coefficient of insulators
C_{xt}	Drag coefficient of supports C_{xt1} , C_{xt2} for each tower face (C_{xtc} on cylindrical tower members)
COV	Coefficient of variation, also identified as v_x (ratio of standard deviation to mean value)