



IEEE

IEC/IEEE/PAS 63547

Edition 1.0 2011-09

PUBLICLY AVAILABLE SPECIFICATION

Interconnecting distributed resources with electric power systems

(<https://standards.iteh.ai>)

Document Preview

IEC/IEEE PAS 63547:2011

<https://standards.iteh.ai/catalog/standards/iec/63547-2011-0a28-479c-8c64-4efce927e983/iec-ieee-pas-63547-2011>

WITHDRAWN



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2003 IEEE

All rights reserved. IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Inc.

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the IEC Central Office.

Any questions about IEEE copyright should be addressed to the IEEE. Enquiries about obtaining additional rights to this publication and other information requests should be addressed to the IEC or your local IEC member National Committee.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

The Institute of Electrical and Electronics Engineers, Inc
3 Park Avenue
US-New York, NY10016-5997
USA
Email: stds-info@ieee.org
Web: www.ieee.org

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11



IEEE

IEC/IEEE/PAS 63547

Edition 1.0 2011-09

PUBLICLY AVAILABLE SPECIFICATION

Interconnecting distributed resources with electric power systems

(<https://standards.iteh.ai>)

Document Preview

IEC/IEEE PAS 63547:2011

<https://standards.iteh.ai/catalog/standards/iec/63547-2011-0a28-479c-8c64-4efce927e983/iec-ieee-pas-63547-2011>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

V

ICS 29.240.99

ISBN 978-2-88912-687-3

CONTENTS

FOREWORD.....	4
IEEE INTRODUCTION.....	7
1 Overview	8
1.1 Scope	8
1.2 Purpose.....	8
1.3 Limitations.....	8
2 References.....	9
3 Definitions and acronyms.....	9
3.1 Definitions	9
3.2 Acronyms	12
4 Interconnection technical specifications and requirements.....	12
4.1 General requirements	13
4.1.1 Voltage regulation	13
4.1.2 Integration with Area EPS grounding.....	13
4.1.3 Synchronization.....	13
4.1.4 Distributed resources on distribution secondary grid and spot networks.....	13
4.1.5 Inadvertent energization of the Area EPS.....	14
4.1.6 Monitoring provisions.....	14
4.1.7 Isolation device	14
4.1.8 Interconnect integrity.....	14
4.2 Response to Area EPS abnormal conditions.....	14
4.2.1 Area EPS faults.....	14
4.2.2 Area EPS reclosing coordination.....	15
4.2.3 Voltage.....	15
4.2.4 Frequency.....	15
4.2.5 Loss of synchronism.....	16
4.2.6 Reconnection to Area EPS.....	16
4.3 Power quality.....	16
4.3.1 Limitation of dc injection.....	16
4.3.2 Limitation of flicker induced by the DR.....	16
4.3.3 Harmonics.....	16
4.4 Islanding.....	17
4.4.1 Unintentional islanding.....	17
4.4.2 Intentional islanding.....	17
5 Interconnection test specifications and requirements.....	17
5.1 Design test.....	17
5.1.1 Response to abnormal voltage and frequency.....	18
5.1.2 Synchronization.....	18
5.1.3 Interconnect integrity test.....	19
5.1.4 Unintentional Islanding.....	19
5.1.5 Limitation of dc injection.....	20
5.1.6 Harmonics.....	20
5.2 Production tests.....	20
5.3 Interconnection installation evaluation.....	20

5.3.1	Grounding integration with Area EPS	20
5.3.2	Isolation device	21
5.3.3	Monitoring provisions	21
5.3.4	Area EPS faults	21
5.3.5	Area EPS reclosing coordination	21
5.4	Commissioning tests	21
5.4.1	Unintentional islanding functionality test	22
5.4.2	Cease to energize functionality test.....	22
5.5	Periodic interconnection tests.....	22
Annex A (informative)	Bibliography.....	23
Annex B (informative)	IEEE List of Participants	24
Figure 1	– Relationship of interconnection terms	10
Figure 2	– Schematic of interconnection	11
Table 1	– Interconnection system response to abnormal voltages	15
[IEC IN SOME COUNTRIES CLAUSE: Table 2	– Interconnection system response to abnormal frequencies].....	16
[IEC IN SOME COUNTRIES CLAUSE: Table 3	– Maximum harmonic current distortion in percent of current (I^a)]	17
Table 4	– Sequence for conducting design test.....	18
Table 5	– Synchronization parameter limits for synchronous interconnection to an EPS, or an energized local EPS to an energized Area EPS	19
[IEC IN SOME COUNTRIES CLAUSE: Table 6	– Maximum harmonic voltage distortion in percent of rated voltage for synchronous machines].....	20

IEC/IEEE PAS 63547:2011

<https://standards.iteh.ai/catalog/standards/iec/63547-2011-0a28-479c-8c64-4efce927e983/iec-ieee-pas-63547-2011>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INTERCONNECTING DISTRIBUTED RESOURCES
WITH ELECTRIC POWER SYSTEMS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

A PAS is a technical specification not fulfilling the requirements for a standard, but made available to the public.

IEC/IEEE-PAS 63547 was submitted by the IEEE (The Institute of Electrical and Electronics Engineers) and has been processed by IEC technical committee 8: Systems aspects for electrical energy supply.

It is based on IEEE Std 1547TM-2003. It is published as a double-logo PAS.

The text of this PAS is based on the following document:

This PAS was approved for publication by the P-members of the committee concerned as indicated in the following document:

Draft PAS	Report on voting
8/1296/PAS	8/1299/RVD

Following publication of this PAS the technical committee or subcommittee concerned may transform it into an International Standard.

This PAS shall remain valid for an initial maximum period of 3 years starting from the publication date. The validity may be extended for a single period up to a maximum of 3 years, at the end of which it shall be published as another type of normative document, or shall be withdrawn.

IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems

Sponsor

Standards Coordinating Committee 21

(Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage)

Approved 12 June 2003 **IEEE-**

SA Standards Board

iTeh Standards

(<https://standards.itih.ai>)

Document Preview

IEC/IEEE PAS 63547:2011

<https://standards.itih.ai/catalog/standards/iec/63547-2011-0a28-479c-8c64-4efce927e983/iec-ieee-pas-63547-2011>

Abstract: This standard is the first in the 1547 series of interconnection standards and is a benchmark milestone demonstrating the open consensus process for standards development. Traditionally, utility electric power systems (EPS--grid or utility grid) were not designed to accommodate active generation and storage at the distribution level. As a result, there are major issues and obstacles to an orderly transition to using and integrating distributed power resources with the grid. The lack of uniform national interconnection standards and tests for interconnection operation and certification, as well as the lack of uniform national building, electrical, and safety codes, are understood. IEEE Std 1547 and its development demonstrate a model for ongoing success in establishing additional interconnection agreements, rules, and standards, on a national, regional, and state level. IEEE Std 1547 has the potential to be used in federal legislation and rule making and state public utilities commission (PUC) deliberations, and by over 3000 utilities in formulating technical requirements for interconnection agreements for distributed generators powering the electric grid.

This standard focuses on the technical specifications for, and testing of, the interconnection itself. It provides requirements relevant to the performance, operation, testing, safety considerations, and maintenance of the interconnection. It includes general requirements, response to abnormal conditions, power quality, islanding, and test specifications and requirements for design, production, installation evaluation, commissioning, and periodic tests. The stated requirements are universally needed for interconnection of distributed resources (DR), including synchronous machines, induction machines, or power inverters/converters and will be sufficient for most installations. The criteria and requirements are applicable to all DR technologies, [IEC IN SOME COUNTRIES CLAUSE: with aggregate capacity of 10 MVA or less at the point of common coupling], interconnected to electric power systems at typical primary and/or secondary distribution voltages. Installation of DR on radial primary and secondary distribution systems is the main emphasis of this document, although installation of DR on primary and secondary network distribution systems is considered. [IEC IN SOME COUNTRIES CLAUSE: This standard is written considering that the DR is a 60 Hz source].

Keywords: certification; codes; commissioning; dc injection; design, field, installation, production tests; communications; diesel generators; distributed generation, power; resources; electric distribution systems; dispersed generation, storage; energy storage; faults; flicker; fuel cells; generators; grid; harmonics; IEEE; induction machines; inverters; interconnection requirements and specifications; islanding; microturbines; monitoring and control; paralleling; power converters, networks, quality; photovoltaic power systems; point of common coupling; public utility commissions; reclosing coordination; regulations; rule making, federal, national, regional, state; standards; synchronous machines; testing; utilities; wind energy systems.

IEEE INTRODUCTION

(This introduction is not part of IEEE Std 1547-2003, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.)

IEEE Std 1547-2003 is the first of a series of standards being developed by Standards Coordinating Committee 21 on Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage (SCC21) concerning distributed resources interconnection. The titles of the additional documents in that series follow.

- IEEE P1547.1TM Draft Standard For Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems
- IEEE P1 547.2TM Draft Application Guide for IEEE Std 1547-2003, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems
- IEEE P1 547.3TM Draft Guide for Monitoring, Information Exchange, and Control of Distributed Resources Interconnected with Electric Power Systems

This first publication of IEEE Std 1547-2003 is an outgrowth of the changes in the environment for production and delivery of electricity and builds on prior IEEE recommended practices and guidelines developed by SCC21 [IEC IN SOME COUNTRIES CLAUSE: e.g., IEEE Std 929TM-2000, IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems], and Standards Coordinating Committee 23 on Dispersed Storage and Generation (e.g., IEEE Std 1001TM-1988, Guide for Interfacing Dispersed Storage and Generation Facilities with Electric Utility Systems).

Traditionally, utility electric power systems (EPS) were not designed to accommodate active generation and storage at the distribution level. The technologies and operational concepts to properly integrate distributed resources (DR) into the existing EPS continue to be further developed to fully realize benefits and to avoid negative impacts on system reliability and safety.

There is a critical need to have a single document of consensus standard technical requirements for DR interconnection rather than having to conform to numerous local practices and guidelines. This standard addresses that critical need by providing uniform criteria and requirements relevant to the performance, operation, testing, safety considerations, and maintenance of the interconnection.

The intent of this standard is to define the technical requirements in a manner that can be universally adopted. The universality relates not only to the technical aspects, but also to the adoption of this standard as being pertinent across a number of industries and institutions, e.g., hardware manufacturers, utilities, energy service companies, codes and standards organizations, regulators and legislators, and other interested entities.

This standard focuses on the technical specifications for, and testing of, the interconnection itself, and not on the types of the DR technologies. This standard aims to be technology neutral, although cognizant that the technical attributes of DR and the types of EPSs do have a bearing on the interconnection requirements. The addition of DR to an EPS will change the system and its response in some manner. Although this standard establishes criteria and requirements for interconnection, this standard is not a design handbook nor is it an application guideline. This standard provides the minimum functional technical requirements that are universally needed to help assure a technically sound interconnection. Any additional local requirements should not be implemented to the detriment of the functional technical requirements of this standard.

It is beyond the scope of this standard to address the methods used for performing EPS impact studies, mitigating limitations of the Area EPS, or for addressing the business or tariff issues associated with interconnection.

INTERCONNECTING DISTRIBUTED RESOURCES WITH ELECTRIC POWER SYSTEMS

1 Overview

This standard provides interconnection technical specifications and requirements, and test specifications and requirements. Additionally, there is a bibliography included as Annex A that lists citations referred to in this standard for informative purposes, but that are not required to be used in conjunction with this standard.

1.1 Scope

This standard establishes criteria and requirements for interconnection of distributed resources (DR) with electric power systems (EPS).

1.2 Purpose

This standard provides a uniform standard for interconnection of distributed resources with electric power systems. It provides requirements relevant to the performance, operation, testing, safety considerations, and maintenance of the interconnection.

The requirements shall be met at the point of common coupling (PCC), although the devices used to meet these requirements can be located elsewhere. This standard applies to interconnection based on the aggregate rating of all the DR units that are within the Local EPS. The functions of the interconnection system hardware and software that affect the Area EPS are required to meet this standard regardless of their location on the EPS.

The stated specifications and requirements, both technical and testing, are universally needed for interconnection of DR, including synchronous machines, induction machines, or power inverters/converters, and will be sufficient for most installations.¹

1.3 Limitations

The criteria and requirements in this document are applicable to all distributed resource technologies, [IEC IN SOME COUNTRIES CLAUSE: with aggregate capacity of 10 MVA or less at the PCC], interconnected to EPSs at typical primary and/or secondary distribution voltages. Installation of DR on radial primary and secondary distribution systems is the main emphasis of this standard, although installation of DR on primary and secondary network distribution systems is considered. [IEC IN SOME COUNTRIES CLAUSE: This standard is written considering that the DR is a 60 Hz source].

- This standard does not define the maximum DR capacity for a particular installation that may be interconnected to a single PCC or connected to a given feeder.
- This standard does not prescribe DR self-protection or all operating requirements for DR units.
- This standard does not address planning, designing, operating, or maintaining the Area EPS.
- This standard does not apply to automatic transfer schemes in which load is transferred between the DR and the EPS in a momentary make-before-break

¹ Additional technical requirements and/or tests may be necessary for some limited situations.

operation provided the duration of paralleling the sources is less than 100 ms, except as noted in 4.1.4.

2 References

[IEC IN SOME COUNTRIES CLAUSE: The following standards shall be used in conjunction with this standard. When the stated version of the following standards is superseded by an approved revision, then that revision shall apply.

The applicability of the following standards is determined by the specific requirements stated in this standard, such as requiring certain sections.

ANSI C84.1-1995, *Electric Power Systems and Equipment – Voltage Ratings (60 Hz)*.²

IEEE Std C37.90.1TM-2002, *IEEE Standard Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus*.^{3,4}

IEEE Std C37.90.2TM-1995, *IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers*

IEEE Std C62.41.2TM-2002, *IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000 V and less) AC Power Circuits*

IEEE Std C62.45TM-2002, *IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000 V and Less) AC Power Circuits*

NEMA MG 1-1998, *Motors and Generators*, Revision 2.⁵]

3 Definitions and acronyms

For purposes of this standard, the following terms and definitions apply. [IEC IN SOME COUNTRIES CLAUSE: IEEE 1 00TM, *The Authoritative Dictionary of IEEE Standards Terms*, Seventh Edition [IEC IN SOME COUNTRIES CLAUSE: B4],⁶ should be referenced for terms not defined in this clause].

3.1 Definitions

3.1.1

area electric power system operator (Area EPS Operator)

the entity responsible for designing, building, operating, and maintaining the Area EPS

3.1.2

cease to energize

cessation of energy outflow capability

² ANSI publications are available from the Sales Department, American National Standards Institute, 25 West 43rd Street, 4th Floor, New York, NY 10036, USA (<http://www.ansi.org/>).

³ The IEEE standards or products referred to in Clause 2 are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.

⁴ IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-133 1, USA (<http://standards.ieee.org/>).

⁵ NEMA publications are available from Global Engineering Documents, 15 Inverness Way East, Englewood, Colorado 80112, USA (<http://global.ihs.com/>).

⁶ The numbers in brackets correspond to those of the bibliography in Annex A.