

INTERNATIONAL STANDARD



**Low-voltage fuses –
Part 2: Supplementary requirements for fuses for use by authorized persons
(fuses mainly for industrial application) – Examples of standardized systems of
fuses A to K**

iTeh Standards
Document Preview

[IEC 60269-2:2013](https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013)

<https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International
Standards
Document Preview

[IEC 60269-2:2013](https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013)

<https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013>



IEC 60269-2

Edition 5.2 2024-06
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**Low-voltage fuses –
Part 2: Supplementary requirements for fuses for use by authorized persons
(fuses mainly for industrial application) – Examples of standardized systems of
fuses A to K**

iTeh Standards
<https://standards.iteh.ai/>
Document Preview

[IEC 60269-2:2013](#)

<https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.50

ISBN 978-2-8322-9247-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	15
INTRODUCTION.....	17
1 General scope.....	18
1.1 Scope.....	18
1.2 Normative references	18
Fuse system A – Fuses with fuse-links with blade contacts (NH fuse system).....	20
1 General.....	20
1.1 Scope.....	20
2 Terms and definitions	20
3 Conditions for operation in service.....	21
4 Classification.....	21
5 Characteristics of fuses	21
5.2 Rated voltage	21
5.3.1 Rated current of the fuse-link.....	21
5.3.2 Rated current of the fuse-holder	21
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	21
5.6 Limits of time-current characteristics	21
5.6.1 Time-current characteristics, time-current zones and overload curves	21
5.6.2 Conventional times and currents.....	21
5.6.3 Gates	22
5.7.2 Rated breaking capacity	22
6 Markings	22
6.1 Markings of fuse-holders	22
6.2 Markings of fuse-links.....	23
7 Standard conditions for construction.....	23
7.1 Mechanical design.....	23
7.1.2 Connections, including terminals	23
7.1.3 Fuse-contacts.....	24
7.1.6 Construction of fuse-bases	24
7.1.7 Construction of a fuse-link	24
7.2 Insulating properties and suitability for insulation	25
7.7 I^2t characteristics.....	25
7.8 Overcurrent discrimination of fuse-links	26
7.9 Protection against electric shock	26
8 Tests	27
8.1.4 Arrangement of the fuse and dimensions	27
8.1.6 Testing of fuse-holders	27
8.2.4 Acceptability of test results.....	28
8.2.5 Resistance to tracking	28
8.3 Verification of temperature rise and power dissipation	28
8.3.1 Arrangement of the fuse and dimensions	28
8.3.2 Measurement of the temperature rise	28
8.5.5 Test method	29

8.5.8 Acceptability of test results	
8.7.4 Verification of overcurrent discrimination selectivity	30
8.9 Verification of resistance to heat	31
8.9.1 Fuse-base	32
8.9.2 Fuse-links with gripping-lugs of moulded material or of metal fixed in moulded material	32
8.10 Verification of non-deterioration of contacts	33
8.10.1 Arrangement of the fuse	33
8.10.2 Test method	35
8.10.3 Acceptability of test results	36
8.11 Mechanical and miscellaneous tests	38
FIGURES	41
Annex AA (informative) Special test for cable overload protection	61
AA.1 Arrangement of the fuse	61
AA.2 Test method and acceptability of test results	61
Fuse system B – Fuses with striker fuse-links with blade contacts (NH fuse system)	62
1.1 Scope	62
5.2 Rated voltage	62
5.3.1 Rated current of the fuse-link	63
5.3.2 Rated current of the fuse-holder	63
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	63
5.6 Limits of time-current characteristics	63
5.7.2 Rated breaking capacity	63
7.1 Mechanical design	63
7.1.2 Connections, including terminals	63
7.1.3 Fuse-contacts	63
7.1.7 Construction of a fuse-link	64
7.2 Insulating properties and suitability for insulation	64
7.7 I^2t characteristics	64
7.8 Overcurrent discrimination of "gG" fuse-links	64
7.9 Protection against electric shock	64
8.1.6 Testing of fuse-holders	64
8.3 Verification of temperature rise and power dissipation	64
8.7.4 Verification of overcurrent discrimination	65
8.9 Verification of resistance to heat	65
8.9.1 Fuse-base	65
FIGURES	67
Fuse system C – Fuse-rails (NH fuse system)	74
1.1 Scope	74
5.2 Rated voltage	74
5.3.2 Rated current	74
5.5.1 Rated acceptable power dissipation	74
7.1 Mechanical design	75
7.1.2 Connections, including terminals	75

7.2	Insulating properties	75
8.1.6	Testing of fuse-holders	75
8.3	Verification of temperature rise and power dissipation	76
8.3.1	Arrangement of the fuse	76
8.9	Verification of resistance to heat	77
8.9.1	Fuse-base	77
8.10	Verification of non-deterioration of contacts	77
8.10.1	Arrangement of the fuse	77
FIGURES	79

Fuse system D – Fuse-bases for busbar mounting (40 mm system) (NH fuse system)	84
1.1	Scope	84
5.2	Rated voltage	84
5.3.2	Rated current	85
5.5.2	Rated acceptable power dissipation of tandem fuse-bases	85
6	Markings	85
7	Standard conditions for construction	85
7.1	Mechanical design	85
7.1.2	Connections, including terminals	85
7.1.5	Construction of a fuse-base for busbar mounting	86
7.2	Insulating properties and suitability for insulation	86
8	Tests	86
8.3	Verification of temperature rise and power dissipation	86
8.3.1	Arrangement of the fuse	86
8.9.1	Fuse-base	87
8.10	Verification of non-deterioration of contacts	87
8.10.1	Arrangement of the fuse	87
8.10.2	Test method	88
8.11	Mechanical and miscellaneous tests	88
FIGURES	89

Fuse system E – Fuses with fuse-links for bolted connections (BS bolted fuse system)	96
1	General	96
1.1	Scope	96
2	Terms and definitions	96
3	Conditions for operation in service	96
4	Classification	96
5	Characteristics of fuses	96
5.3.1	Rated current of the fuse-link	96
5.3.2	Rated current of the fuse-holder	96
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	97
5.6	Limits of time-current characteristics	97
5.6.1	Time-current characteristics, time-current zones and overload curves	97
5.6.2	Conventional times and currents	97

5.6.3	Gates	97
5.7.2	Rated breaking capacity	97
6	Markings	97
6.1	Markings of fuse-holders	98
6.2	Markings of fuse-links.....	98
7	Standard conditions for construction.....	98
7.1	Mechanical design.....	98
7.1.2	Connections including terminals	98
7.2	Insulating properties and suitability for insulation	98
7.9	Protection against electric shock	98
8	Tests	98
8.3	Verification of temperature rise and power dissipation	98
8.3.1	Arrangement of the fuse	98
8.3.3	Measurement of the power dissipation of the fuse-link.....	98
8.4	Verification of operation	99
8.4.1	Arrangement of the fuse	99
8.5	Verification of breaking capacity.....	99
8.5.1	Arrangement of the fuse	99
8.5.8	Acceptability of test results.....	99
8.9	Verification of resistance to heat	99
8.10	Verification of non-deterioration of contacts.....	99
8.10.1	Arrangement of the fuse	99
8.10.2	Test method	99
8.10.3	Acceptability of the results.....	100
8.11	Mechanical and miscellaneous tests.....	100
FIGURES	101
https://standards.iteh.ai/catalog/standards/iec/7667c665-69f9-4d84-a043-f0793f08b05a/iec-60269-2-2013		
	Fuse system F – Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)	110
1	General	110
1.1	Scope.....	110
2	Terms and definitions	110
3	Conditions for operation in service.....	110
4	Classification	110
5	Characteristics of fuses	110
5.2	Rated voltage	110
5.3.1	Rated current of the fuse-link.....	111
5.3.2	Rated current of the fuse-holder	111
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	111
5.6	Limits of time-current characteristics	112
5.6.1	Time-current characteristics, time-current zones and overload curves	112
5.6.2	Conventional times and currents.....	112
5.6.3	Gates	113
5.7.2	Rated breaking capacity	113
6	Markings	113
6.1	Markings of fuse-holders	113
6.2	Markings of fuse-links.....	114

7	Standard conditions for construction.....	114
7.1	Mechanical design.....	114
7.1.2	Connections including terminals	114
7.2	Insulating properties and suitability for insulation	114
7.7	I^2t characteristics	115
7.8	Overcurrent discrimination of "gG" fuse-links.....	115
7.9	Protection against electric shock	115
8	Tests.....	115
8.1.6	Testing of fuse-holders.....	116
8.3.1	Arrangement of the fuse	116
8.7.4	Verification of overcurrent discrimination	118
8.9	Verification of resistance to heat	119
8.10	Verification of non-deterioration of contacts.....	119
8.10.1	Arrangement of the fuse	119
8.10.2	Test method	119
8.10.3	Acceptability of test results.....	120
FIGURES	121

Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)	125
1	General.....	125
1.1	Scope.....	125
2	Terms and definitions.....	125
3	Conditions for operation in service.....	125
4	Classification.....	125
5	Characteristics of fuses.....	125
5.2	Rated voltage.....	126
5.3.1	Rated current of the fuse-link.....	126
5.3.2	Rated current of the fuse-holder	126
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	126
5.6.1	Time-current characteristics, time-current zones	126
5.6.2	Conventional times and currents.....	126
5.6.3	Gates	126
5.7.2	Rated breaking capacity	127
6	Markings	127
6.1	Markings of fuse-holders	127
6.2	Markings of fuse-links.....	127
7	Standard conditions for construction.....	127
7.1	Mechanical design.....	127
7.1.2	Connections including terminals	127
7.2	Insulating properties and suitability for insulation	128
7.7	I^2t characteristics.....	128
7.9	Protection against electric shock	128
8	Tests.....	128
8.3.3	Measurement of the power dissipation of the fuse-link.....	128
8.4.1	Arrangement of the fuse	129

8.5.1	Arrangement of the fuse	129
8.7.4	Verification of overcurrent discrimination	129
8.9	Verification of resistance to heat	129
8.10	Verification of non-deterioration of contacts.....	129
8.10.1	Arrangement of the fuse	129
8.10.2	Test method	130
8.10.3	Acceptability of test results.....	130
8.11	Mechanical and miscellaneous tests.....	130
FIGURES	131

Fuse system H – Fuses with fuse-links having "gD" and "gN" characteristics (class J, class T, and class L time delay and non time delay fuse types).....

		136
1	General	136
1.1	Scope.....	136
2	Terms and definitions	136
3	Conditions for operation in service.....	136
4	Classification.....	136
5	Characteristics of fuses	136
5.2	Rated voltage	136
5.3.1	Rated current of the fuse-link.....	137
5.3.2	Rated current of the fuse-holder	137
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	137
5.6	Limits of the time-current characteristics	137
5.6.1	Time-current characteristics, time-current zones	137
5.6.2	Conventional times and currents.....	137
5.6.3	Gates	137
5.7.2	Rated breaking capacity	138
6	Markings	138
6.1	Markings of fuse-holders	138
6.2	Markings of fuse-links.....	138
7	Standard conditions for construction.....	138
7.1	Mechanical design.....	138
7.2	Insulating properties and suitability for insulation	138
7.5	Breaking capacity	138
7.6	Cut-off current characteristics.....	139
7.7	I^2t characteristics.....	139
7.8	Overcurrent discrimination.....	140
7.9	Protection against electric shock	140
8	Tests	140
8.3	Verification of temperature rise and power dissipation	140
8.3.1	Arrangement of the fuse	140
8.4	Verification of operation	141
8.4.1	Arrangement of the fuse	141
8.5.4	Recovery voltage.....	142
8.6	Verification of cut-off current characteristics.....	142
8.7	Verification of I^2t characteristics and overcurrent discrimination.....	143
8.9	Verification of resistance to heat	143

8.10	Verification of non-deterioration of contacts.....	143
8.10.1	Arrangement of the fuse	143
8.10.2	Test method	144
8.10.3	Acceptability of test results.....	144
8.11	Mechanical and miscellaneous tests.....	144
8.11.2	Miscellaneous tests	144
FIGURES	145
Fuse system I – gU fuse-links with wedge tightening contacts.....		158
1	General	158
1.1	Scope.....	158
2	Terms and definitions	158
3	Conditions for operation in service.....	159
3.9	Discrimination of fuse-links.....	159
4	Classification.....	159
5	Characteristics of fuses	159
5.2	Rated voltage	159
5.3.1	Rated current of the fuse-link.....	159
5.5	Rated power dissipation of a fuse-link	159
5.6.1	Time-current characteristics, time-current zones	159
5.6.2	Conventional times and currents.....	160
5.6.3	Gates	160
5.7.2	Rated breaking capacity	160
5.8	Cut-off current and I^2t characteristics.....	160
6	Markings	160
6.1	Markings of fuse-holders	160
6.2	Markings of fuse-links.....	160
7	Standard conditions for construction.....	160
7.1	Mechanical design.....	160
7.2	Insulating properties and suitability for insulation	160
7.5	Breaking capacity	160
7.7	I^2t characteristics.....	161
7.8	Overcurrent discrimination of the fuse-links.....	161
8	Tests	161
8.1.1	Kind of tests	161
8.3.1	Arrangement of the fuse	161
8.3.3	Measurement of the power dissipation of the fuse-link.....	162
8.4.1	Arrangement of the fuse	162
8.5.1	Arrangement of the fuse	162
8.5.2	Characteristics of the test circuit.....	162
8.5.5	Test method	162
8.5.8	Acceptability of test results.....	162
8.7.3	Verification of compliance for fuse-links at 0,01 s	163
8.9	Verification of resistance to heat	163
8.11	Mechanical and miscellaneous tests.....	163
FIGURES	164

Fuse system J – Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)		172
1	General	172
1.1	Scope.....	172
2	Terms and definitions	172
3	Conditions for operation in service.....	172
4	Classification.....	172
5	Characteristics of fuses	172
5.2	Rated voltage	172
5.3.1	Rated current of the fuse-link.....	173
5.3.2	Rated current of the fuse-holder	173
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	173
5.6	Limits of the time-current characteristics	173
5.6.1	Time-current characteristics, time-current zones	173
5.6.2	Conventional times and currents.....	173
5.6.3	Gates	173
5.7.2	Rated breaking capacity	173
6	Markings	174
6.1	Markings of fuse-holders	174
6.2	Markings of fuse-links.....	174
7	Standard conditions for construction.....	174
7.1	Mechanical design.....	174
7.2	Insulating properties and suitability for insulation	174
7.5	Breaking capacity	174
7.6	Cut-off current characteristics.....	174
7.7	I^2t characteristics.....	174
7.8	Overcurrent discrimination.....	175
7.9	Protection against electric shock	175
8	Tests	175
8.3	Verification of temperature rise and power dissipation	175
8.3.1	Arrangement of the fuse	175
8.4	Verification of operation	176
8.4.1	Arrangement of the fuse	176
8.5.4	Recovery voltage.....	176
8.6	Verification of cut-off current characteristics	176
8.7	Verification of I^2t characteristics and overcurrent discrimination.....	177
8.9	Verification of resistance to heat	178
8.10	Verification of non-deterioration of contacts.....	178
8.10.1	Arrangement of the fuse	178
8.10.2	Test method	178
8.10.3	Acceptability of test results.....	178
8.11	Mechanical and miscellaneous tests.....	178
8.11.2	Miscellaneous tests	179
FIGURES		180

Fuse system K – gK fuse-links with blade contacts for bolted connections – High current fuse-link ratings from 1 250 A up to 4 800A (Master fuse-links)		190
1	General	190
1.1	Scope.....	190
2	Terms and definitions	190
3	Conditions for operation in service.....	190
3.9	Discrimination of fuse-links.....	190
4	Classification.....	190
5	Characteristics of fuses	190
5.2	Rated voltage	191
5.3.1	Rated current of the fuse-link.....	191
5.3.2	Rated current of the fuse-holder	191
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	191
5.6	Limits of the time-current characteristics	191
5.6.1	Time-current characteristics, time-current zones	191
5.6.2	Conventional times and currents.....	192
5.6.3	Gates	192
5.7.2	Rated breaking capacity	192
6	Markings	192
6.2	Markings of fuse-links.....	193
7	Standard conditions for construction.....	193
7.1	Mechanical design.....	193
7.1.3	Fuse-contacts.....	193
7.6	Cut-off current characteristics.....	193
7.7	I^2t characteristics	193
7.8	Over-current selectivity of “gK” fuse-links	193
7.9	Protection against electric shock	193
8	Tests.....	194
8.3	Verification of temperature rise and power dissipation	194
8.3.1	Arrangement of the fuse	194
8.4.1	Arrangement of the fuse	194
8.6	Verification of cut-off current characteristics.....	194
8.7	Verification of I^2t characteristics and over-current selectivity	195
8.9	Verification of resistance to heat	196
8.10	Verification of non-deterioration of contacts.....	196
8.10.1	Arrangement of the fuse	196
8.10.2	Test method	196
8.10.3	Acceptability of test results.....	196
FIGURES		197
Bibliography.....		204
Figure 101 – Fuse-links with blade contacts (1 of 3)		41
Figure 102 – Fuse-bases for fuse-links with blade contacts.....		47
Figure 103 – Replacement handle.....		48
Figure 104 – Time-current zones for “gG” fuse-links (1 of 5)		49
Figure 105 – Dummy fuse-link according to 8.3.4.1, 8.9.1 and 8.10		54

Figure 106 – Measuring points according to 8.3.4 of IEC 60269-1, 8.3.4.1, 8.3.4.2 and 8.10.2 of fuse system A	55
Figure 107 – Test knife according to 8.5.5.1.2	55
Figure 108 – Example of a measuring device for determining the withdrawal forces according to 8.9.1 and 8.11.1.2.....	56
Figure 109 – Facility for verifying the mechanical strength of gripping-lugs (see 8.11.1.8).....	57
Figure 110 – Measuring points according to 8.10.2	58
Figure 111 – Reference fuse-base	59
Figure 112 – Design mark for isolated gripping-lugs.....	60
Figure 201 – Fuse-links with blade contacts with striker (1 of 4).....	67
Figure 202 – Fuse-bases for fuse-links with blade contacts with striker (1 of 3)	71
Figure 301 – Fuse-rails for fuse-links with blade contacts (1 of 3)	79
Figure 302 – Test arrangement for fuse-rails (1 of 2)	82
Figure 401 – Busbar mounting bases, 1 pole	89
Figure 402 – Busbar mounting bases, 3 pole	90
Figure 403 – Busbar mounting base, size 00, 2 × 3 pole (tandem fuse-base).....	91
Figure 404 – Test arrangement for single-pole and triple-pole fuse-bases for busbar-mounting according to 8.3.1.....	92
Figure 405 – Test arrangement for two single-pole and six single-pole fuse-bases in tandem arrangement for busbar-mounting according to 8.3.1.....	93
Figure 406 – Test arrangement for the verification of the peak withstand current	94
Figure 407 – Dummy fuse-link	95
Figure 501 – Fuse-links for bolted connection – Sizes A, B, C and D (1 of 2).....	101
Figure 502 – Typical fuse-holder (1 of 2).....	103
Figure 503 – Time-current zones for "gG" fuse-link	105
Figure 504 – Time-current zones for "gG" fuse-link	106
Figure 505 – Power dissipation test rig	107
Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2)	108
Figure 601 – Fuse-links with cylindrical caps	121
Figure 602 – Fuse-links with cylindrical contact caps with striker – Additional dimensions for sizes 14 × 51 and 22 × 58 only.....	122
Figure 603 – Base for fuse-links with cylindrical caps (1 of 2)	123
Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3	131
Figure 702 – Typical fuse-holder.....	132
Figure 703 – Time-current zones for "gG" fuse-links	133
Figure 704 – Time-current zones for "gG" fuse-links	134
Figure 705 – Power dissipation test rig	135
Figure 801 – Class J fuse-links (1 A to 600 A)	145
Figure 802 – Class L fuse-links (700 A to 6 000 A)	146
Figure 803 – Fuse-base and contacts for class J fuse-links 1 A to 600 A	147
Figure 804 – Fuse-base and contacts for class L fuse-links 700 A to 6 000 A	148
Figure 805 – Class T fuse-links (1 A to 1 200 A)	149
Figure 806 – Fuse-base and contacts for class T fuse-links 1 A to 1 200 A	150
Figure 807 – Temperature test arrangement	151

Figure 808 – Time-current zones for "gN" fuse-links	152
Figure 809 – Time-current zones for "gN" fuse-links	153
Figure 810 – Time-current zones for "gN" fuse-links	154
Figure 811 – Time-current zones for "gD" fuse-links	155
Figure 812 – Time-current zones for "gD" fuse-links	156
Figure 813 – Time-current zones for "gD" fuse-links	157
Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A	164
Figure 902 – Time-current zones for current ratings 160 A and 315 A	165
Figure 903 – Time-current zones for current ratings 250 A and 500 A	166
Figure 904 – Time-current zones for current ratings 200 A and 400 A	167
Figure 905 – Dimensions for fuse-links with L type and U type tags	168
Figure 906 – Power dissipation test rig	169
Figure 907 – Breaking capacity test rig (1 of 2)	170
Figure 1001 – Class CC fuse-links (1 A to 30 A)	180
Figure 1002 – Fuse-base and contacts for class CC fuse-links 1 A to 30 A	180
Figure 1003 – Class CC dummy fuse-link dimensions	181
Figure 1004 – Temperature test arrangement	182
Figure 1005 – Time-current zones for class CC "gN" fuses	183
Figure 1006 – Time-current zones for class CC "gN" fuses	184
Figure 1007 – Time-current zones for class CC "gN" fuses	186
Figure 1008 – Time-current zones for class CC "gD" fuses	187
Figure 1009 – Time-current zones for class CC "gD" fuses	188
Figure 1010 – Time-current zones for class CC "gD" fuses	189
Figure 1101 – "gK" fuse-links (1 of 2)	197
Figure 1102 – Connecting dimensions for "gK" fuse-links (1 of 3)	199
Figure 1103 – Dummy fuse-link	201
Figure 1104 – Time-current zones for "gK" fuse system K (1 of 2)	202
Table 101 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A	22
Table 102 – Gates for specified pre-arcing and operating times of "gG" fuse-links	22
Table 103 – Minimum rated breaking capacities	22
Table 104 – Marking of fuse-links	23
Table 105 – Minimum cross-sectional ranges of unprepared conductors	24
Table 106 – Pre-arcing and operating I^2t values at 0,01 s for "gG" fuse-links	25
Table 107 – Maximum operating I^2t values for "aM" fuse-links	26
Table 108 – Pre-arcing I^2t values for discrimination of gG fuse-links	26
Table 109 – Survey of tests on fuse-holders and number of fuse-holders to be tested	27
Table 110 – Rated impulse withstand voltage	27
Table 111 – Torque to be applied to the terminal screws	28
Table 112 – Test currents	29
Table 113 – Test currents and I^2t limits for discrimination selectivity test	31
Table 114 – Torques to be applied when no values are given by the manufacturer	34