

Edition 1.0 2011-06

# **PUBLICLY AVAILABLE SPECIFICATION PRE-STANDARD** colour inside Luminaire performance -Part 1: General requirements



#### THIS PUBLICATION IS COPYRIGHT PROTECTED

#### Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland Email: inmail@iec.ch Web: www.iec.ch

#### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

#### **About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Catalogue of IEC publications: <u>www.iec.ch/searchpub</u>

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications

IEC Just Published: www.iec.ch/online\_news//ustpub

Stay up to date on all new IEC publications. Just Published details wice a month all new publications released. Available on-line and also by email.

Electropedia: <u>www.electropedia.org</u>

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

Customer Service Centre: <a href="http://www.iec.ch/webstore/custserv">www.iec.ch/webstore/custserv</a>
If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch Tel.: +41 22 919 02 11 Fax: +41 22 919 03 00



Edition 1.0 2011-06

colour inside

## PUBLICLY AVAILABLE SPECIFICATION

### **PRE-STANDARD**

Luminaire performance – A Part 1: General requirements

https://standards.iteh

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PRICE CODE

ICS 29.140.40

ISBN 978-2-88912-567-8

#### CONTENTS

FOREWORD			
INTRODUCTION			
1	Scope	6	
2	Normative references		
3	Terms and definitions	6	
4	General requirements	7	
5	Light sources and components of luminaires8		
6	Photometric data		
7	Electrical data		
8	Luminaire efficacy data	9	
9	Environmental data	9	
	9.1 Materials information	9	
	9.2 Maintenance instructions	9	
	9.3 Disassembly instructions	9	
Annex A (normative) Use of regional standards			
Annex B (normative) Measurement method of total power of luminaires and associated			
Anney C (informative). Symbols to assist the communication of identications for			
maintenance through life and end of life recycling			
Bibliography			
IEC 25 6272 22011			
https://standards.iten/ur/aut/2/standards/s/2/05-6008-15C6-42C0-0101-116d19/03459/lec-			
$\bigwedge \setminus \setminus \setminus \bigvee$			

#### INTERNATIONAL ELECTROTECHNICAL COMMISSION

#### LUMINAIRE PERFORMANCE -

#### Part 1: General requirements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter keferred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, EC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and EC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

A PAS is a technical specification not fulfilling the requirements for a standard, but made available to the public.

IEC-PAS 62722-1 has been processed by subcommittee 34D: Luminaires, of IEC technical committee 34: Lamps and related equipment.

The text of this PAS is based on the following document:	This PAS was approved for publication by the P-members of the committee concerned as indicated in the following document
Draft PAS	Report on voting
34D/998/PAS	34D/1014/RVD

Following publication of this PAS, which is a pre-standard publication, the technical committee or subcommittee concerned may transform it into an International Standard.

This PAS shall remain valid for an initial maximum period of 3 years starting from the publication date. The validity may be extended for a single period up to a maximum of 3 years, at the end of which it shall be published as another type of normative document, or shall be withdrawn.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.



#### INTRODUCTION

The first edition of a performance PAS for luminaires (general requirements) acknowledges the need for defining performance data to be provided, the presentation of this data, the basis of its measurement, and the associated tolerances that may be reasonably expected. Information to support responsible environmental use is also included. Part 2 sections to this Part 1 will be introduced where additional performance requirements for specific types of light source are required.

The provisions in the PAS represent the technical knowledge of experts from the fields of the luminaire industry and associated components such as lamps and controlgear.



#### LUMINAIRE PERFORMANCE -

#### Part 1: General requirements

#### 1 Scope

This PAS covers specific performance and environmental requirements for luminaires, incorporating electric light sources for operation from supply voltages up to 1 000 V where claims of operational performance are made. Unless otherwise detailed performance data covered under the scope of this PAS are for the luminaires in a condition representative of new manufacture, with any specified initial aging procedures completed.

IEC/PAS 62722-1 covers requirements for luminaires to support energy efficient use and responsible environmental management to the end of life. The object of this Part 1 is to provide a set of requirements which are considered to be generally applicable to most types of luminaires. Where additional performance requirements for specific types of light source are relevant, these are specified in the IEC 62722-2 series. The IEC 62722-2 series may also cover a wider scope of performance aspects appropriate to the particular light source technology.

NOTE The structure of these performance standards also allows for the possibility of Part 3 standards to be introduced in the future should standardisation of performance criteria linked to specific luminaire applications be determined as necessary (e. g. floodlighting, street lighting, etc.).

It is the intention that the requirements of this Rart 1 are to be met by the provision of information and data provided by the luminaire manufacturer (or responsible vendor). Conformity is considered to be met by the provision of the requested information. Any verification of data is to be conducted by the measurement requirements of this PAS.

Semi-luminaires are not covered under the scope of this PAS. Luminaires shall be complete.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CIE 121:1996, The photometry and goniophotometry of luminaires

CIE 121-SP1:2009, The photometry and goniophotometry of luminaires – Supplement 1: Luminaires for emergency lighting

IEC 60598-1, Luminaires – Part 1: General requirements and tests

IEC 60598-2 (all parts), Luminaires – Part 2: Particular requirements

NOTE Annex A provides details of regional standards the use of which are preferred in some countries.

#### 3 Terms and definitions

For the purposes of all sections of this Part 1, the definitions given in the IEC 60598 series and relevant Part 2 sections apply together with the following:

#### 3.1

#### input power

electrical power from the mains supply consumed by the light source(s), controlgear and any control circuit in the luminaire, measured in watts which includes any parasitic power when the luminaire is turned on

#### 3.2

#### parasitic power

electrical power from the mains supply consumed by the charging circuit of emergency lighting luminaires and the standby power for controlgear and control devices in the luminaire when light sources are not operating, measured in watts

#### 3.3

#### standby losses

electrical power from the mains supply consumed by the luminaire during the period with light sources not operating, measured in watts

NOTE For emergency lighting luminaires this does not include the emergency lighting charging power.

#### 3.4

#### rated emergency lighting charging power

electrical power from the mains supply consumed by the charging circuit of emergency luminaires, measured in watts

#### 3.5

#### luminaire efficacy

ratio of the luminaires total lumen output versus its rated input power, excluding any parasitic power losses, expressed as lumens per watt

#### 3.6

#### light output ratio (of a luminaire)

LOR

ratio of the total flux of the luminaire, measured under specified practical conditions with its own lamps and equipment, to the sum of the individual luminous fluxes of the same light sources when operated outside the luminaire with the same equipment, under specified conditions

#### 3.7

#### rated value

quantitative value for a characteristic of a luminaire for specific operating conditions specified in this PAS, or in applicable standards, or assigned by the manufacturer or responsible vendor

#### 3.8

#### test voltage

voltage at which tests are carried out

#### 4 General requirements

**4.1** Luminaires shall meet the requirements of the IEC 60598-2 standards that are appropriate to their design.

**4.2** Luminaires shall meet all requirements of this Part 1 and where applicable also the additional requirements of the Part 2 section appropriate to the type of light source used by the luminaire. Where detailed in a Part 2 section alternative methods of measurement or limits to those given in this Part 1 may be specified.

**4.3** Where it is specified by this standard that data is to be provided, this data may be supplied by the manufacturer in printed or electronic formats, via the manufacturer's catalogues, website, or similar.

#### 5 Light sources and components of luminaires

Any light sources and components delivered with the luminaire shall comply with the requirements of the IEC performance standards that are appropriate to them.

#### 6 Photometric data

Photometric data shall be available for all variations of the luminaire and any optical attachments or accessories that the luminaire has been specified for use with.

Photometric data shall be provided for luminaires in accordance with an established international or regional format as appropriate for the type of luminaire, and with luminous intensity distribution data according to the luminaires intended application. Data shall be available in electronic file format to facilitate its use by lighting design software.

NOTE 1 Information regarding acceptable regional standards for photometric data formats is given in Annex A.

When measured in accordance with CIE 121 or CIE 121-SP1 the light output ratio (LOR) of the luminaire shall not vary by more than -10% of the rated value. The distribution of luminous intensity shall generally be in accordance with that declared by the manufacturer (method of comparison under consideration).

NOTE 2 The allowed photometric variations detailed are to take account of manufacturing tolerances. When measurements are made additional allowance for laboratory measurement uncertainty also needs to be considered.

All photometric data shall be declared for the luminaire operating at its rated supply voltage.

NOTE 3 For the photometric performance of emergency luminaires when operating in emergency mode see also IEC 60598-2-22.

Luminaires for tungsten filament lamps may be photometrically rated, electrically rated and efficacy-rated with lamps of any wattage not exceeding the marked maximum, and any technology (e. g. halogen, self-ballasted compact fluorescent or self-ballasted LED), if these lamps are covered by an available IEC safety standard and are shown to comply with that standard. For these luminaires the number of lamps, their technology and their wattage shall be given in the luminaire manufacturer's catalogue, website or similar.

NOTE 4 The use of an LCOS code according to IEC 61231 is also acceptable.

#### 7 Electrical data

Electrical supply data shall be provided for the luminaire and shall include the following:

- a) rated supply voltage;
- b) rated input power;
- c) rated parasitic power of the controls only during the time with the light sources off (standby losses);
- d) rated emergency lighting charging power.

When measured at its rated supply voltage, under conditions specified by Annex B, the electrical values shall not exceed the rated values declared by the manufacturer by more than 10 %.