

INTERNATIONAL STANDARD



**Electromagnetic compatibility (EMC) –
Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker
in public low-voltage supply systems, for equipment with rated current ≤ 16 A
per phase and not subject to conditional connection**

[IEC 61000-3-3:2013](https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013)

<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

www.standards.iteh.ai/
<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>

<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>



IEC 61000-3-3

Edition 3.2 2021-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**Electromagnetic compatibility (EMC) –
Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker
in public low-voltage supply systems, for equipment with rated current ≤ 16 A
per phase and not subject to conditional connection**

[IEC 61000-3-3:2013](https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013)

<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.100.10

ISBN 978-2-8322-9622-6

Warning! Make sure that you obtained this publication from an authorized distributor.

REDLINE VERSION



**Electromagnetic compatibility (EMC) –
Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker
in public low-voltage supply systems, for equipment with rated current ≤ 16 A
per phase and not subject to conditional connection**

[IEC 61000-3-3:2013](https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013)

<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Assessment of voltage changes, voltage fluctuations and flicker	10
4.1 Assessment of a relative voltage change, $d(t)$	10
4.2 Assessment of the short-term flicker value, P_{st}	11
4.2.1 General	11
4.2.2 Flickermeter	11
4.2.3 Simulation method.....	11
4.2.4 Analytical method	11
4.2.5 Use of $P_{st} = 1$ curve	12
4.3 Assessment of long-term flicker value, P_{lt}	12
5 Limits	12
6 Test conditions	13
6.1 General	13
6.2 Measurement uncertainty	14
6.3 Test supply voltage	14
6.4 Reference impedance.....	14
6.5 Observation period.....	15
6.6 General test conditions.....	15
Annex A (normative) Application of limits and type test conditions for specific equipment.....	19
Annex B (normative) Test conditions and procedures for measuring d_{max} voltage changes caused by manual switching	29
Annex C (informative) Determination of steady state voltage and voltage change characteristics, as defined in IEC 61000-4-15:2010	30
Annex D (informative) Input relative voltage fluctuation $\Delta V/V$ for $P_{st} = 1,0$ at output [IEC/TR 61000-3-7:2008]	35
Bibliography.....	36
Figure 1 – Reference network for single-phase and three-phase supplies derived from a three-phase, four-wire supply.....	16
Figure 2 – Curve for $P_{st} = 1$ for rectangular equidistant voltage changes	17
Figure 3 – Shape factors F for double-step and ramp-voltage characteristics.....	17
Figure 4 – Shape factors F for rectangular and triangular voltage characteristics	18
Figure 5 – Shape factor F for motor-start voltage characteristics having various front times.....	18
Figure C.1 – Evaluation of $U_{hp}(t)$	34
Table 1 – Assessment method	11
Table A.1 – Test conditions for hotplates	19
Table A.2 – Electrode parameters	25

Table A.3 – Frequency factor R related to repetition rate "r".....	26
Table C.1 – Test specification for $d_c - d_{\max} - t_d(t) > 3,3 \%$ (from Table 12 of IEC 61000-4-15: 2010).....	33
Table C.2 – Test specification for $d_c - d_{\max} - t_d(t) > 3,3 \%$ (from Table 13 of IEC 61000-4-15: 2010).....	33
Table D.1 – Input relative voltage fluctuation $\Delta V/V$ for $P_{st} = 1,0$ at output	35

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61000-3-3:2013](https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013)

<https://standards.iteh.ai/catalog/standards/sist/f9332e58-c6f5-42f1-86ff-dd165c9fe868/iec-61000-3-3-2013>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –**Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 61000-3-3 edition 3.2 contains the third edition (2013-05) [documents 77A/809/FDIS and 77A/816/RVD], its amendment 1 (2017-05) [documents 77A/952/FDIS and 77A/960/RVD] and its amendment 2 (2021-03) [documents 77A/1075/CDV and 77A/1093/RVC] and its corrigendum (2022-01).

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61000-3-3 has been prepared by subcommittee 77A: EMC – Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility.

This standard forms part 3-3 of IEC 61000 series of standards. It has the status of a product family standard.

This third edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) This edition takes account of the changes made in IEC 61000-4-15:2010.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IEC 61000-3-3:2013

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 9: Miscellaneous

Each part is further subdivided into sections which are to be published either as International Standards or as Technical Reports.

These standards and reports will be published in chronological order and numbered accordingly.

INTRODUCTION to the corrigendum

During the final editing of the text for IEC 61000-3-3:2013/AMD2:2021 (Edition 3), a mistake occurred and the sentence “Plt shall not be evaluated” is not displayed as a separate paragraph. As a result, this could lead to a wrong interpretation of the text and to wrong Pass/Fail results. This corrigendum is needed to clarify that the text “Plt shall not be evaluated” applies to all equipment in Clause A.16.

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection

1 Scope

This part of IEC 61000 is concerned with the limitation of voltage fluctuations and flicker impressed on the public low-voltage system.

It specifies limits of voltage changes which may be produced by an equipment tested under specified conditions and gives guidance on methods of assessment.

This part of IEC 61000 is applicable to electrical and electronic equipment having an input current equal to or less than 16 A per phase, intended to be connected to public low-voltage distribution systems of between 220 V and 250 V line to neutral at 50 Hz, and not subject to conditional connection.

Equipment which does not comply with the limits of this part of IEC 61000 when tested with the reference impedance Z_{ref} of 6.4, and which therefore cannot be declared compliant with this part, may be retested or evaluated to show conformity with IEC 61000-3-11. Part 3-11 is applicable to equipment with rated input current ≤ 75 A per phase and subject to conditional connection.

The tests according to this part are type tests. Particular test conditions are given in Annex A and the test circuit is shown in Figure 1.

NOTE 1 The limits in this standard relate to the voltage changes experienced by consumers connected at the interface between the public supply low-voltage network and the equipment user's installation. Consequently, if the actual impedance of the supply at the supply terminals of equipment connected within the equipment user's installation exceeds the test impedance, it is possible that supply disturbance exceeding the limits could occur.

NOTE 2 The limits in this standard are based mainly on the subjective severity of flicker imposed on the light from 230 V 60 W coiled-coil filament lamps by fluctuations of the supply voltage. For systems with nominal voltage less than 220 V line to neutral and/or frequency of 60 Hz, the limits and reference circuit values are under consideration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TR 60725, *Consideration of reference impedances and public supply impedances for use in determining disturbance characteristics of electrical equipment having a rated current ≤ 75 A per phase*

IEC 60974-1, *Arc welding equipment – Part 1: Welding power sources*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-4-15:2010, *Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

flicker

impression of unsteadiness of visual sensation induced by a light stimulus whose luminance or spectral distribution fluctuates with time

[SOURCE: IEC 60050-161:1990, 161-08-13]

3.2

voltage change characteristic

$d(t)$

time function of the relative r.m.s. voltage change evaluated as a single value for each successive half period between zero-crossings of the source voltage, except during time intervals in which the voltage is in a steady-state condition for at least 1 s

Note 1 to entry: For detailed information about the evaluation of a voltage change characteristic and the definition of a steady state condition see Annex C and IEC 61000-4-15:2010.

3.3

d_c

maximum steady state voltage change during an observation period

Note 1 to entry: For detailed information about the calculation of d_c see Annex C and IEC 61000-4-15:2010.

3.4

d_{\max}

maximum absolute voltage change during an observation period

Note 1 to entry: For detailed information about the calculation of d_{\max} see Annex C and IEC 61000-4-15:2010.

3.5

T_{\max}

maximum time duration during the observation period that the voltage deviation $d(t)$ exceeds the limit for d_c

Note 1 to entry: During a voltage change characteristic the time duration T_{\max} is accumulated until a new steady state condition is established.

Note 2 to entry: The T_{\max} limit evaluation in this standard is generally intended to evaluate the inrush current pattern of the equipment under test. Thus, as soon as a new steady state condition is established, the T_{\max} evaluation is ended. When a new voltage change occurs that exceeds the limit for d_c , a new T_{\max} evaluation is started. The maximum duration that $d(t)$ exceeds the limit for d_c for any of the individual T_{\max} evaluations during the observation period, is used for the comparison against the T_{\max} limit, and is reported for the test.

3.6

nominal test voltage

U_n

nominal test voltage used to calculate percentages for the various directly measured parameters

Note 1 to entry: If no steady state condition is achieved during the observation period, U_n is used for the calculation of d_{\max} and T_{\max} .

Note 2 to entry: U_n is not necessarily equal to the nominal voltage of the public supply.

3.7

P_{st}

short-term flicker severity

Note 1 to entry: If not specified differently, the P_{st} evaluation time is 10 minutes. For the purpose of power quality surveys and studies, other time intervals may be used, and have to be defined in the index. For example a 1 minute interval should be written as $P_{\text{st},1\text{min}}$.

3.8

P_{lt}

long-term flicker severity

$$P_{\text{lt}} = \sqrt[3]{\frac{\sum_{i=1}^N P_{\text{st},i}^3}{N}}$$

where $P_{\text{st},i}$ ($i = 1, 2, 3, \dots$) are consecutive readings of the short-term severity P_{st}

Note 1 to entry: Unless otherwise specified, P_{lt} is calculated over discrete T_{long} periods. Each time a T_{long} period has expired, a new P_{lt} calculation is started.

3.9

flickermeter

instrument designed to measure any quantity representative of flicker

Note 1 to entry: Measurements are normally P_{st} and P_{lt} and may also include the directly measured parameters specified in 3.2 to 3.5.

[SOURCE: IEC 60050-161:1990, 161-08-14]

3.10

flicker impression time

t_f

value with a time dimension which describes the flicker impression of a voltage change characteristic

3.11

shape factor

F

value derived from the type of voltage fluctuation, such as a step, double step, or ramp pattern

Note 1 to entry: The shape factor is mainly needed when the analytical method is used to calculate P_{st} .

3.12

interface point

interface between a public supply network and a user's installation

3.13

conditional connection

connection of equipment requiring the user's supply at the interface point to have an impedance lower than the reference impedance Z_{ref} in order that the equipment emissions comply with the limits in this part

Note 1 to entry: Meeting the voltage change limits may not be the only condition for connection; emission limits for other phenomena such as harmonics, may also have to be satisfied.

4 Assessment of voltage changes, voltage fluctuations and flicker

4.1 Assessment of a relative voltage change, $d(t)$

The basis for flicker evaluation is the voltage change characteristic at the terminals of the equipment under test, that is the difference $\Delta U_{\text{hp}}(t)$ of any two successive values of the phase-to-neutral voltages $U_{\text{hp}}(t_1)$ and $U_{\text{hp}}(t_2)$:

$$\Delta U_{\text{hp}}(t) = U_{\text{hp}}(t_1) - U_{\text{hp}}(t_2) \quad (1)$$

NOTE 1 See Annex C for relevant definitions that are taken from IEC 61000-4-15:2010.

The r.m.s. values $U_{\text{hp}}(t_1)$, $U_{\text{hp}}(t_2)$ of the voltage shall be measured or calculated. When deducing r.m.s. values from oscillographic waveforms, account should be taken of any waveform distortion that may be present.

The voltage change at the EUT terminals, ΔU , is due to the change of the voltage drop across the complex reference impedance \underline{Z} , caused by the complex fundamental input current change, $\Delta \underline{I}$, of the equipment under test. ΔI_p and ΔI_q are the active and reactive parts respectively of the current change, $\Delta \underline{I}$.

$$\Delta \underline{I} = \Delta I_p - j\Delta I_q = \underline{I}(t_1) - \underline{I}(t_2) \quad (2)$$

NOTE 2 I_q is positive for lagging currents and negative for leading currents.

NOTE 3 If the harmonic distortion of the currents $I(t_1)$ and $I(t_2)$ is less than 10 %, the total r.m.s. value can be applied instead of the r.m.s. values of their fundamental currents, taking account of the phase angles of the fundamental currents.

NOTE 4 For single-phase and symmetrical three-phase equipment the voltage change can be, provided X is positive (inductive), approximated to:

$$\Delta U_{\text{hp}} = |\Delta I_p R + \Delta I_q X| \quad (3)$$

where ΔI_p and ΔI_q are the active and reactive parts respectively of the current change $\Delta \underline{I}$ and R and X are the elements of the complex reference impedance Z (see Figure 1).

The relative voltage change is given by:

$$d = \Delta U_{\text{hp}} / U_n \quad (4)$$

The $d_{\text{max},i}$ evaluation ends as soon as a new steady state condition is established, or at the end of the observation period. The polarity of change(s) may be indicated as follows: if the maximum voltage deviation is observed during a reduction in voltage with respect to the previous $d_{\text{end},i}$ the resulting $d_{\text{max},i}$ value is positive; if the maximum voltage deviation is observed during a voltage increase with respect to the previous $d_{\text{end},i}$ the resulting $d_{\text{max},i}$ value is negative.

4.2 Assessment of the short-term flicker value, P_{st}

4.2.1 General

Table 1 shows alternative methods for evaluating P_{st} , due to voltage fluctuations of different types; in all cases direct measurement (with a flickermeter) is acceptable:

Table 1 – Assessment method

Types of voltage fluctuations	Method for evaluating P_{st}
All voltage fluctuations (on-line evaluation)	Flickermeter
All voltage fluctuations where $U(t)$ is known	Simulation
Voltage change characteristics according to Figures 3 to 5 with an occurrence rate less than 1 per second	Analytical
Rectangular voltage change at equal intervals	Use of the $P_{st} = 1$ curve of Figure 2

4.2.2 Flickermeter

All types of voltage fluctuations may be assessed by direct measurement using a flickermeter which complies with the specification given in IEC 61000-4-15:2010, and is connected as described in this standard. This is the reference method for application of the limits.

4.2.3 Simulation method

In the case where the relative voltage change characteristic $d(t)$ is known, P_{st} can be evaluated using a computer simulation.

4.2.4 Analytical method

4.2.4.1 General

For voltage change characteristics of the types shown in Figures 3, 4 and 5, the P_{st} value can be evaluated by an analytical method using Equations (5) and (6).

NOTE 1 The value of P_{st} obtained using this method is expected to be within $\pm 10\%$ of the result which would be obtained by direct measurement (reference method).

NOTE 2 This method is not used if the time duration between the end of one voltage change and the start of the next is less than 1 s.

4.2.4.2 Description of the analytical method

Each relative voltage change characteristic shall be expressed by a flicker impression time, t_f , in seconds:

$$t_f = 2,3 (Fd_{\max})^{3,2} \quad (5)$$

- the maximum relative voltage change d_{\max} is expressed as a percentage of the nominal voltage U_n ;
- the shape factor, F , is associated with the shape of the voltage change characteristic (see 4.2.4.3).

The sum of the flicker impression times, Σt_f , of all evaluation periods within a total interval of the length T_p , in seconds, is the basis for the P_{st} evaluation. If the total time interval T_p is chosen according to 6.5, it is an "observation period", and: