

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Power quality measurement in power supply systems –
Part 1: Power quality instruments (PQI)**

**Mesure de la qualité de l'alimentation dans les réseaux d'alimentation –
Partie 1: Instruments de mesure de la qualité de l'alimentation**

<https://standards.iteh.ai/catalog/standards/sist/146a1e9c-cc5e-498b-9e57-5b38e666f0fe/iec-62586-1-2013>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc/iec

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Power quality measurement in power supply systems –
Part 1: Power quality instruments (PQI)**

**Mesure de la qualité de l'alimentation dans les réseaux d'alimentation –
Partie 1: Instruments de mesure de la qualité de l'alimentation**

<https://standards.iteh.ai/catalog/standards/sist/149a1e9c-cc5e-498b-9e57-5b38e666f0fe/iec-62586-1-2013>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 17.220.20

ISBN 978-2-8322-1290-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions, abbreviations, notations and symbols	9
3.1 General definitions	9
3.2 Terms and definitions related to environments.....	10
3.3 Definitions related to uncertainty	10
3.4 Notations.....	11
3.4.1 Functions	11
3.4.2 Symbols and abbreviations.....	11
3.4.3 Indices	12
4 Environmental conditions.....	12
4.1 General.....	12
4.2 Environments FI1, FI2, FI1-H, FI2-H, FO and FO-H.....	13
4.3 Environments PI, PI-H, PO and PO-H.....	14
4.4 Relationship between ambient air temperature and relative humidity	15
5 Ratings.....	15
5.1 Rated input energising voltages	15
5.2 Rated frequencies	15
6 Design and construction	15
6.1 General.....	15
6.2 General architecture.....	15
6.3 Functions embedded in PQI-A and PQI-S.....	16
6.3.1 PQI-A minimum functions definition	16
6.3.2 PQI-S minimum functions definition	17
6.3.3 Summary of IEC 61000-4-30 requirements for functions	17
6.4 Additional requirements complementary to IEC 61000-4-30.....	18
6.4.1 Data to be provided for testing reasons	18
6.4.2 Resolution of the presented data	20
6.4.3 Clarification about “data flagging”	20
6.4.4 Temperature drift requirement within the rated range of operation for ambient air temperature.....	20
6.5 Safety requirements	21
6.6 EMC requirements.....	22
6.6.1 Emissions.....	22
6.6.2 Immunity	22
6.7 Climatic requirements of PQI.....	22
6.8 Mechanical requirements.....	22
6.8.1 Product mechanical robustness	22
6.8.2 Enclosure robustness	22
6.9 Degree of protection by enclosures	23
6.10 Start-up requirements.....	23
7 Marking and operating instructions	23
7.1 General.....	23
7.2 Marking.....	23

7.3	Operating instructions	23
8	Functional, environmental and safety type tests	24
8.1	General	24
8.2	Reference conditions for type tests	24
8.3	Safety tests	25
8.4	EMC tests	25
8.4.1	Emissions	25
8.4.2	Immunity	25
8.5	Climatic tests	26
8.6	Mechanical tests	27
8.6.1	Product mechanical robustness	27
8.6.2	Degree of protection provide by enclosures for electrical equipment against external mechanical impacts (IK code)	28
8.6.3	Degree of protection by enclosure (IP code)	28
8.7	Functional and uncertainty tests	28
9	Routine tests	28
9.1	General	28
9.2	Protective bonding test	28
9.3	Dielectric strength test	28
9.4	Intrinsic uncertainty test	28
10	Certificates and declarations	28
11	Re-calibration and re-verification	28
Annex A (informative)	Information about environment H and G described in IEC/TS 61000-6-5	29
Bibliography https://standards.itec.int/catalog/standards/sist/62586-1/iec-62586-1-2013	30
Figure 1	– Instrument generic measurement chain	16
Figure 2	– Uncertainty requirement as a function of temperature	21
Figure A.1	– Example of power station and substation: selection of the specification for apparatus and the related connections	29
Table 1	– Products coding table	12
Table 2	– Definition of class A products	12
Table 3	– Definition of class S products	13
Table 4	– Description of FI1, FI2, FI1-H, FI2-H, FO, FO-H environments	13
Table 5	– Description of PI, PI-H, PO and PO-H environments	14
Table 6	– PQI-A functions	16
Table 7	– PQI-S minimum functions	17
Table 8	– Summary of measurements requested for testing	19
Table 9	– Uncertainty multipliers for different temperature ranges	21
Table 10	– Enclosure mechanical requirements	22
Table 11	– Minimum IP requirements	23
Table 12	– Characteristics specification template	24
Table 13	– Reference conditions for testing	25
Table 14	– Climatic requirements	26
Table 15	– Product mechanical requirements	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER QUALITY MEASUREMENT IN POWER SUPPLY SYSTEMS –

Part 1: Power quality instruments (PQI)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62586-1 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

The text of this standard is based on the following documents:

FDIS	Report on voting
85/460/FDIS	85/466/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62586 series, published under the general title *Power quality measurement in power supply systems*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62586-1:2013](https://standards.iteh.ai/catalog/standards/sist/146a1e9c-cc5e-498b-9e57-5f38e666f0fe/iec-62586-1-2013)

<https://standards.iteh.ai/catalog/standards/sist/146a1e9c-cc5e-498b-9e57-5f38e666f0fe/iec-62586-1-2013>

INTRODUCTION

Electricity as delivered to the network users has several characteristics which are variable and which affect its usefulness to the network user.

Power quality instruments on the market have different characteristics. This standard provides a common system of references in order to facilitate their selection, comparison and evaluation. This standard specifies a classification based on product performances, environment and safety.

It is acknowledged that IEC 61000-4-30 is a basic EMC publication. Detailed guidance on instrument performance, performance verification methods, additional influence quantities and other similar information should, in general, be found in a product standard.

IEC 62586-1 is a product standard that refers to IEC 61000-4-30, IEC 61000-4-7 and IEC 61000-4-15 for measuring methods. IEC 62586-2 specifies functional tests and uncertainty requirements for instruments in the scope of IEC 62586-1.

IEC 62586-1 is therefore complementing basic EMC standards with environmental, safety and performance requirements.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62586-1:2013](https://standards.iteh.ai/catalog/standards/sist/146a1e9c-cc5e-498b-9e57-5b38e666f0fe/iec-62586-1-2013)

<https://standards.iteh.ai/catalog/standards/sist/146a1e9c-cc5e-498b-9e57-5b38e666f0fe/iec-62586-1-2013>

Withhold

POWER QUALITY MEASUREMENT IN POWER SUPPLY SYSTEMS –

Part 1: Power quality instruments (PQI)

1 Scope

This part of IEC 62586 specifies product and performance requirements for instruments whose functions include measuring, recording and possibly monitoring power quality parameters in power supply systems, and whose measuring methods (class A or class S) are defined in IEC 61000-4-30.

These requirements are applicable in single, dual- (split phase) and 3-phase a.c. power supply systems at 50 Hz or 60 Hz.

These instruments can be used:

- in the generation, transmission and distribution of electricity, for example inside a power station, substation or a distributed generator connection.
- at the interface point between the installation and the network, e.g. in order to check the compliance of the connection agreement between a network operator and the customer.

NOTE 1 These instruments can also be used for other applications, e.g. inside commercial / industrial installations especially where comparable measurements are needed (i.e. data centers or petrochemical plants).

These instruments are fixed-installed or portable. They are intended to be used indoors and/or outdoors.

Devices such as digital fault recorders, energy/power meters, protection relays or circuit breakers may include power quality functions defined in 61000-4-30 class A or class S. If such devices are specified according to this standard, then this standard fully applies and applies in addition to the relevant product standard. This standard does not replace the relevant product standard.

NOTE 2 It is not the intent of this standard to address user interface or topics unrelated to device measurement performance.

NOTE 3 The standard does not cover post-processing and interpretation of the data, for example with a dedicated software.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Tests A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Tests B: Dry heat*

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

- IEC 60068-2-14, *Environmental testing – Part 2-14 Tests – Test N: Change of temperature*
- IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*
- IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*
- IEC 60068-2-52, *Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution)*
- IEC 60068-2-57, *Environmental testing – Part 2-57: Tests – Test Ff: Vibration – Time-history and sine-beat method*
- IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*
- IEC 60529, *Degrees of protection provided by enclosures (IP Code)*
- IEC 60654-1, *Industrial-process measurement and control equipment – Operating conditions – Part 1: Climatic conditions*
- IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*
- IEC 60721-3-1, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 1: Storage*
- IEC 60721-3-2, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 2: Transportation*
- IEC 60721-3-3, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Section 3: Stationary use at weatherprotected locations*
- IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*
Amendment 1:2008
- IEC 61000-4-15:2010, *Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications*
- IEC 61000-4-30:2008, *Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods*
- IEC /TS 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for power station and substation environments*
- IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*
- IEC 61010-2-030, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for testing and measuring circuits*
- IEC 62262, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62586-2, *Power quality measurement in power supply systems – Part 2: Functional tests and uncertainty requirements*

CISPR 22, *Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement*

3 Terms, definitions, abbreviations, notations and symbols

For the purposes of this document, the terms and definitions given in IEC 61000-4-30 as well as the following terms and definitions apply.

3.1 General definitions

3.1.1

power quality instrument

PQI

instrument whose main function is to measure, record and possibly monitor power quality parameters in power supply systems, and whose measuring methods (class A or class S) are defined in IEC 61000-4-30

3.1.2

power quality instrument class A

PQI-A

PQI whose measuring methods comply with class A of IEC 61000-4-30

3.1.3

power quality instrument class S

PQI-S

PQI whose measuring methods comply with class S of IEC 61000-4-30

3.1.4

portable instrument

portable measuring instrument

measuring instrument designed to be easily carried by hand and to be connected and disconnected by the user

[SOURCE: IEC 60050-300:2001, 312-02-18]

3.1.5

fixed installed instrument

fixed installed measuring instrument

measuring instrument designed to be permanently mounted and which is intended to be connected by means of permanently installed connectors

[SOURCE: IEC 60050-300:2001, 312-02-17, modified – “conductors” has been replaced by “connectors”.]

3.1.6

panel mounted instrument

fixed installed instrument intended to be mounted in a cut out of a panel or a chassis

3.1.7

modular instrument fixed on DIN rail

fixed installed instrument intended to be used in switchgear or control gear, fixed on a DIN rail

3.1.8

housing instrument fixed on DIN rail

fixed installed instrument, intended to be fixed on a DIN rail within a control panel

3.2 Terms and definitions related to environments

3.2.1

EMC environment H

harsh EMC environment

EXAMPLES High voltage stations, arc furnaces, welding, aluminium plants.

Note 1 to entry: This environment is described in IEC 61000-6-5 as H environment. A summary description of such environments is given in Annex A.

3.2.2

EMC environment G

general EMC environment

EXAMPLES Power stations, MV and LV substations, extended industrial applications.

Note 1 to entry: This environment is described in IEC 61000-6-5 as G environment. A summary description of such environments is given in Annex A.

3.2.3

uncontrolled environment

environment where climatic conditions such as temperature and humidity depend on external climatic conditions and on housing of products

Note 1 to entry: Shelter or housing can be used to minimize the impact of environment.

3.2.4

controlled environment

environment where climatic conditions such as temperature and humidity are under control

Note 1 to entry: This kind of environment is usually controlled by HVAC systems.

3.2.5

limit range of operation

extreme conditions that an measuring instrument can withstand without damage and without degradation of its metrological characteristics when it is subsequently operated within its rated operating conditions

Note 1 to entry: Measuring instrument should be able to function within the limit range of operation

3.2.6

rated range of operation

range of values of a single influence quantity that forms a part of the rated operating conditions

Note 1 to entry: Uncertainty requirements should be met within the rated range of operation

3.3 Definitions related to uncertainty

3.3.1

intrinsic uncertainty

uncertainty of a measuring instrument when used under reference conditions

Note 1 to entry: In this standard, it is the uncertainty of a measured value defined in its rated range and with all influence quantities under reference conditions, unless otherwise stated.

[SOURCE: IEC 60359:2001, 3.2.10, modified – Note 1 to entry has been added.]

3.3.2

influence quantity

quantity which is not the subject of the measurement and whose change affects the relationship between the indication and the result of the measurement

Note 1 to entry: Influence quantities can originate from the measured system, the measuring equipment or the environment.

Note 2 to entry: As the calibration diagram depends on the influence quantities, in order to assign the result of a measurement it is necessary to know whether the relevant influence quantities lie within the specified range.

[SOURCE: IEC 60359:2001, 3.1.14, modified – Note 3 has been deleted.]

3.3.3

variation

variation due to a single influence quantity

difference between the value measured under reference conditions and any value measured within the rated operating range (for this specific influence quantity)

Note 1 to entry: The other performance characteristics and the other influence quantities should stay within the ranges specified for the reference conditions.

3.3.4

rated operating conditions

set of conditions that must be fulfilled during the measurement in order that a calibration diagram may be valid

Note 1 to entry: Beside the specified measuring range and rated operating ranges for the influence quantities, the conditions may include specified ranges for other performance characteristics and other indications that cannot be expressed as ranges of quantities.

[SOURCE: IEC 60359:2001, 3.3.13]

3.3.5

operating uncertainty

uncertainty under the rated operating conditions

Note 1 to entry: The operating instrumental uncertainty, like the intrinsic one, is not evaluated by the user of the instrument, but is stated by its manufacturer or calibrator. The statement may be expressed by means of an algebraic relation involving the intrinsic instrumental uncertainty and the values of one or several influence quantities, but such a relation is just a convenient means of expressing a set of operating instrumental uncertainties under different operating conditions, not a functional relation to be used for evaluating the propagation of uncertainty inside the instrument.

[SOURCE: IEC 60359:2001, 3.2.11, modified – the word "instrumental" has been removed from both the term and the definition.]

3.3.6

overall system uncertainty

uncertainty including the uncertainty of all components related to the measurement system (sensors, wires, measuring instrument, etc.) under the rated operating conditions

3.4 Notations

3.4.1 Functions

See functions defined in IEC 61000-4-30.

3.4.2 Symbols and abbreviations

N.R. Not requested

N.A. Not applicable

3.4.3 Indices

min minimum value

max maximum value

4 Environmental conditions

4.1 General

This standard classifies power quality instruments according to the following criterion:

- instruments that are complying either with class A measurement methods of IEC 61000-4-30 (PQI-A) or with class S measurement methods of IEC 61000-4-30 (PQI-S);
- instruments that are either fixed installed (F), or portable (P);
- instruments that are intended to be used either Indoor (I) or Outdoor (O);
- instruments that are intended to be used in generic EMC environment G or in specific harsh EMC environment H. See Annex A.

Instruments shall be named according to coding of Table 1. The list of all allowed instruments is given in Table 2 and Table 3.

Table 1 – Products coding table

Power quality instrument (PQI)	Functions class according to IEC 61000-4-30 (A or S)	Fixed installed (F) or Portable (P) instrument	Indoor (I) or Outdoor (O) application	EMC environment G (blank) or H (-H)
PQI-A or PQI-S		-FI1, -FI2, -FO, -PI or -PO ^a		Blank or -H ^a
^a See Table 4 and Table 5.				

Table 2 – Definition of class A products

	Fixed installed		Portable	
	Indoor application	Outdoor application	Indoor application	Outdoor application
EMC environment G	PQI-A-FI1 PQI-A-FI2	PQI-A-FO	PQI-A-PI	PQI-A-PO
EMC environment H	PQI-A-FI1-H PQI-A-FI2-H	PQI-A-FO-H	PQI-A-PI-H	PQI-A-PO-H
NOTE F11 is an indoor environment with uncontrolled temperature variations, while F12 is an indoor environment with controlled temperature variations				

Table 3 – Definition of class S products

	Fixed installed		Portable	
	Indoor application	Outdoor application	Indoor application	Outdoor application
EMC environment G	PQI-S-FI1 PQI-S-FI2	PQI-S-FO	PQI-S-PI	PQI-S-PO
EMC environment H	PQI-S-FI1-H PQI-S-FI2-H	PQI-S-FO-H	PQI-S-PI-H	PQI-S-PO-H

NOTE FI1 is an indoor environment with uncontrolled temperature variations, while FI2 is an indoor environment with controlled temperature variations

4.2 Environments FI1, FI2, FI1-H, FI2-H, FO and FO-H

Those environments are dedicated to fixed-installed instruments, used:

- in EMC environment G or in EMC environment H;
- for indoor operation or outdoor operation.

Table 4 – Description of FI1, FI2, FI1-H, FI2-H, FO, FO-H environments

Environmental parameters	Storage and transport	Indoor operation	Outdoor operation
Ambient temperature: limit range of operation ^a	IEC 60721-3-1 / 1K5 -40 °C to + 70 °C IEC 60721-3-2 / 2K4 -40 °C to + 70 °C	FI1: IEC 60721-3-3 / 3K6 -25 °C to + 55 °C FI2: IEC 60721-3-3 / 3K5 mod.: 0 °C to +45 °C	Depends on the geographic regions or the application ⁹ At least the requirements for indoor operation are mandatory
Ambient temperature: rated range of operation ^b	---	FI1: IEC 60721-3-3 / 3K5 mod. -10 °C to + 45° FI2: IEC 60721-3-3 / 3K5 mod. 0 °C to + 45 °C	IEC 60721-3-3 / 3K6 -25 °C to + 55 °C
Relative humidity: 24 h average	from 5 % to 95 % ^d	from 5 % to 95 % ^d	from 5 % to 95 % ^d
Solar radiations	Negligible	700 W/m ²	1120 W/m ²
Wind-driven precipitation (rain, snow, hail, etc.)	Negligible	Negligible	Significant precipitation.
Air pollution by dust, salt, smoke, corrosive/flammable gas, vapours	No significant air pollution ^c	No significant air pollution ^c	Significant air pollution by dust and salt.
Vibration, earth tremors	IEC 60721-3-1 / 1M1 IEC 60721-3-2 / 2M1	IEC 60721-3-3 / 3M1	IEC 60721-3-3 / 3M1
Electromagnetic disturbances immunity	Environments FI1, FI2, FO	---	IEC 61000-6-5 environment G
	Environments FI1-H, FI2-H, FO-H	---	IEC 61000-6-5 environment H
Altitude	---	≤ 2 000 m	≤ 2 000 m
Pollution degree	---	2 according to IEC 61010	2 or 3 according to IEC 61010