



IEC 61427-2

Edition 1.1 2024-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



Secondary cells and batteries for renewable energy storage – General requirements and methods of test – Part 2: On-grid applications

Document Preview

[IEC 61427-2:2015](#)

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International
Standards
Document Preview

[IEC 61427-2:2015](https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015)

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>



IEC 61427-2

Edition 1.1 2024-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



Secondary cells and batteries for renewable energy storage – General requirements and methods of test –
Part 2: On-grid applications

Document Preview

<https://standards.iteh.ai/>
IEC 61427-2:2015

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.220.20

ISBN 978-2-8322-8676-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 General considerations.....	14
5 General test conditions.....	15
5.1 Accuracy of measuring equipment	15
5.1.1 Voltage measurements	15
5.1.2 Current measurements	15
5.1.3 Temperature measurements	15
5.1.4 Time measurements	15
5.2 Test object considerations	15
5.3 Test object battery selection and size considerations.....	16
5.4 Test plan.....	17
6 Battery endurance	21
6.1 General.....	21
6.2 Test for endurance in frequency-regulation service	21
6.3 Test for endurance in load-following service	26
6.4 Test for endurance in peak-power shaving service.....	30
6.5 Test for endurance in photovoltaic energy storage, time-shift service.....	32
7 Battery properties and electrical performance.....	35
7.1 Declaration of the system properties.....	35
7.2 Determination of energy content at +25 °C ambient temperature.....	38
7.3 Determination of the energy efficiency during endurance tests at +25 °C ambient temperature	38
7.4 Determination of the energy efficiency during endurance tests at the minimum and maximum ambient temperature	40
7.5 Determination of waste heat generated during endurance tests at the maximum ambient temperature	44
7.6 Determination of energy requirements during periods of idle state at +25 °C ambient temperature.....	46
Annex A (informative) Battery-related hazards	49
A.1 General.....	49
A.2 Examples.....	49
Annex B (informative) Supplemental test profile for frequency regulation duty service	51
B.1 General.....	51
B.2 The Annex B profile for evaluating battery endurance in frequency-regulation duty	51
B.3 Test procedure.....	53
B.4 Examples of data acquired with the 6.2 and the 24 h Annex B sequence	55
Bibliography.....	57
Figure 1 – Boundary of the full-sized battery (FSB).....	16
Figure 2 – Two-step selection process of the test object battery (TOB).....	17
Figure 3 – Workflow for the determination of endurance properties and electrical performance of the TOB as governed by the sequence of test data generation within 6.2 to 6.5	18

Figure 4 – Sequence of performance tests carried out with TOB 1 within an endurance test 6.x	18
Figure 5 – Workflow and decision tree for endurance tests 6.2 through 6.5	20
Figure 6 – Frequency regulation service test routine profile (6.2) – Profile a	23
Figure 7 – Frequency regulation service test routine profile (6.2) – Profile b	24
Figure 8 – Frequency regulation service test routine profile (6.2) – Profile c	24
Figure 9 – Schematic view of the evolution of battery voltage over time during cycling with constant power discharge and charge pulses	25
Figure 10 – Load-following service test routine profile (6.3) – Profile a	28
Figure 11 – Load-following service test routine profile (6.3) – Profile b	28
Figure 12 – Load-following service test routine profile (6.3) – Profile c	29
Figure 13 – Daily peak-power shaving service test routine profile (6.4)	31
Figure 14 – Daily photovoltaic energy storage time-shift service test routine (6.5) – 3 kW	33
Figure 15 – Daily photovoltaic energy storage time-shift service test routine (6.5) – 30 kW	34
Figure 16 – Schematic view of the location of the two sets of energy values (energy to auxiliaries and energy to and from TOB) to be used for the determination of the energy storage efficiency factor η	39
Figure 17 – Schematic view of the location of the two sets of energy values (energy to auxiliaries and energy to and from battery) to be used for the determination of the amount of waste heat generated	45
Figure 18 – Schematic view of the location of the two sets of energy values (energy to auxiliaries and energy to battery) to be used for the determination of the energy requirements during periods of idle state of the battery	47
Figure B.1 – 24 h sequence of the Annex B profile for a supplemental evaluation of the service-induced performance decay of a battery in frequency-regulation service	52
Figure B.2 – Development of excessive on-charge voltage levels after about 40 days of simulated frequency-regulation with the 6.2 c profile	55
Figure B.3 – Decay of charge acceptance resulting, after about 20 days, in the need for an increased number of SoC _{OT} recovery actions when tested with the Annex B sequence profile	56
Table 1 – Summary of endurance test related electrical property data of the full-sized (FSB) and the test object (TOB) battery	36
Table 2 – Summary of physical dimension data of the full-sized battery (FSB)	37
Table 3 – Summary description of the full-sized battery (FSB)	37
Table 4 – Summary description of the test-object battery (TOB)	37
Table 5 – Summary of the constant power discharge performance of the TOB at an ambient temperature of +25 °C ± 3 K	38
Table 6 – Summary of energy efficiencies determined in endurance tests at an ambient temperature of +25 °C ± 3 K	40
Table 7 – Summary of energy efficiencies determined in endurance cycle tests at the minimum and maximum ambient temperature	42
Table 8 – Parameters to achieve and maintain the target operational state of charge, SoC _{OT} , during tests at the minimum ambient temperature	43
Table 9 – Parameters to achieve and maintain the target operational state of charge, SoC _{OT} , during tests at the maximum ambient temperature	44

Table 10 – Summary of energy released as heat during endurance tests at the maximum ambient temperature	46
Table 11 – Summary of energy required during idle state periods at +25 °C ± 3 K ambient temperature	48
Table A.1 – Non-exhaustive listing of potential battery-related hazards to be taken in consideration in risk assessment activities	49
Table A.2 – Non-exhaustive listing of potential installation-related hazards to be taken in consideration in risk assessment activities	50

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61427-2:2015](https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015)

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SECONDARY CELLS AND BATTERIES FOR RENEWABLE ENERGY STORAGE – GENERAL REQUIREMENTS AND METHODS OF TEST –

Part 2: On-grid applications

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61427-2 edition 1.1 contains the first edition (2015-08) [documents 21/862/FDIS and 21/863/RVD] and its amendment 1 (2024-03) [documents 21/1179/FDIS and 21/1194/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61427-2 has been prepared by IEC technical committee 21: Secondary cells and batteries.

A list of all parts in the IEC 61427 series, published under the general title *Secondary cells and batteries for renewable energy storage – General requirements and methods of test*, can be found on the IEC website.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

ITeH Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61427-2:2015](#)

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

SECONDARY CELLS AND BATTERIES FOR RENEWABLE ENERGY STORAGE – GENERAL REQUIREMENTS AND METHODS OF TEST

Part 2: On-grid applications

1 Scope

This part of IEC 61427 relates to secondary batteries used in on-grid Electrical Energy Storage (EES) applications and provides the associated methods of test for the verification of their endurance, properties and electrical performance in such applications. The test methods are essentially battery chemistry neutral, i.e. applicable to all secondary battery types.

On-grid applications are characterized by the fact that batteries are connected, via power conversion devices, to a regional or nation- or continent-wide electricity grid and act as instantaneous energy sources and sinks to stabilize the grid's performance when randomly major amounts of electrical energy from renewable energy sources are fed into it.

Related power conversion and interface equipment is not covered by this part of IEC 61427.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

None.

[IEC 61427-2:2015](https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015)

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

accuracy

<of a measuring instrument>

quality which characterizes the ability of a measuring instrument to provide an indicated value close to a true value of the quantity to be measured

Note 1 to entry: This term is used in the “true” value approach.

Note 2 to entry: Accuracy is better when the indicated value is closer to the corresponding true value.

[SOURCE: IEC 60050-311:2001, 311-06-08]

3.2

accuracy class

category of measuring instruments, all of which are intended to comply with a set of specifications regarding uncertainty

[SOURCE: IEC 60050-311:2001, 311-06-09]

3.3

ambient temperature

average temperature of the air or another medium in the vicinity of the equipment

Note 1 to entry - During the measurement of the ambient temperature the measuring instrument/probe should be shielded from draughts and radiant heating.

[SOURCE: IEC 60050-826:2004, 826-10-03]

3.4

maximum ambient temperature

<for battery operation> highest ambient temperature at which the battery is operable and should perform according to specified requirements

[SOURCE: IEC 60050-426:2008, 426-20-17, modified — In the definition, “trace heating” has been replaced with “battery”.]

3.5

minimum ambient temperature

<for battery operation> lowest ambient temperature at which the battery is operable and should perform according to specified requirements

[SOURCE: IEC 60050-426:2008, 426-20-20, modified — In the definition, “trace heating” has been replaced with “battery”.]

3.6

ampere hour

quantity of electrical charge obtained by integrating the current in amperes with respect to time in hours

Note 1 to entry: The SI unit for electric charge is the coulomb (1 C = 1 As) but in practice it is usually expressed in ampere hours (Ah).

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

<https://standards.iteh.ai/catalog/standards/iec/2908fd3e-63fe-484f-8a4b-f68b28535818/iec-61427-2-2015>

battery

two or more cells fitted with devices necessary for use, for example case, terminals, marking and protective devices

[SOURCE: IEC 60050-482:2004, 482-01-04, modified — In the definition, “one” has been replaced with “two”.]

3.8

battery management system

BMS

battery management unit

BMU

electronic system associated with a battery which monitors and/or manages its state, calculates secondary data, reports that data and/or controls its environment to influence the battery's performance and/or service life

Note 1 to entry: The function of the battery management system can be fully or partially assigned to the battery pack and/or to equipment that uses this battery.

Note 2 to entry: A battery management system is also called a "battery management unit" (BMU).

Note 3 to entry: This note applies to the French language only.

Note 4 to entry: This note applies to the French language only.

3.9

idle state

<of a battery system> state of a battery which is fully functional but not actively delivering or absorbing energy

Note 1 to entry: Such a system can deliver and absorb energy on demand with a reaction time as required by the application.

Note 2 to entry: The reaction time can vary from a few milliseconds to a few seconds.

3.10

battery support system

BSS

group of interconnected and interactive parts that perform an essential task as a component of a battery system

Note 1 to entry: Such systems are for example electrolyte storage tanks and circulation pumps, cooling and heating devices, exhaust gas abatement systems, fire extinguishers, spill catchment systems, safety barriers, racks and similar facilities.

Note 2 to entry: This note applies to the French language only.

3.11

capacity

<of cells and batteries> quantity of electric charge which a cell or battery can deliver under specified discharge conditions

Note 1 to entry: The SI unit for electric charge, or quantity of electricity, is the coulomb (1 C = 1 As) but in practice, capacity is usually expressed in ampere hours (Ah).

[SOURCE: IEC 60050-482:2004, 482-03-14, modified — In the definition, “quantity of” has been added.]

3.12

charging

<of a battery> operation during which a secondary battery is supplied with electric energy from an external circuit which results in chemical changes within the cell and thus the storage of energy as chemical energy

Note 1 to entry: A charge operation is defined by its maximum voltage, current, duration and other conditions as specified by the manufacturer.

[SOURCE: IEC 60050-482:2004, 482-05-27, modified — Note 1 to entry has been added.]

3.13

constant power charge

<of a battery> operation in which the charge power input, i.e. the product of charge current and charge voltage, is held constant and where the current and voltage freely adjust according to polarization effects of the battery

3.14

discharge

operation by which a battery delivers, to an external electric circuit and under specified conditions, electric energy produced in the cells

[SOURCE: IEC 60050-482:2004, 482-03-23]

3.15

constant power discharge

<of a battery> operation in which the discharge power output, i.e. the product of discharge current and discharge voltage, is held constant and where the current and voltage freely adjust according to polarization effects of the battery

3.16**electrolyte**

substance containing mobile ions that render it ionically conductive

Note 1 to entry: The electrolyte may be a liquid, solid or a gel.

[SOURCE: IEC 60050-482:2004, 482-02-29]

3.17**endurance**

<of a battery> numerically defined performance during a given test simulating specified conditions of service

[SOURCE: IEC 60050-482:2004, 482-03-44]

3.18**endurance test**

<of a battery> test carried out over a time interval to investigate how the properties are affected by the application of stated stresses and by their time duration or repeated application

[SOURCE: IEC 60050-151:2001, 151-16-22, modified — “<of a battery>” has been added before the definition and “of an item” has been deleted from the definition.]

3.19**energy**

<of a battery> energy which a battery delivers under specified conditions

Note 1 to entry: The SI unit for energy is the joule (1 J = 1 Ws) but in practice, energy of a battery is usually expressed in watt hours (Wh) (1 Wh = 3 600 J).

Note 2 to entry: Such energy content is generally determined with a constant power (W) discharge.

Note 3 to entry: k or M are unit prefixes in the metric system denoting multiplication of the unit by one thousand (k) or one million (M).

[SOURCE: IEC 60050-482:2004, 482-03-21, modified — Notes 2 and 3 to entry have been added.]

3.20**actual energy**

<of a battery> energy content value, determined experimentally at a defined instant of time with a constant power discharge at a specified rate to a specified final voltage and at a specified temperature

Note 1 to entry: This value is expressed in watt hours (Wh) and varies over the operational cycle or life of the battery.

3.21**final voltage**

end-of-discharge voltage

cut-off voltage

end-point-voltage

U_{final}

<of a battery> specified voltage of a battery at which the battery discharge is terminated

[SOURCE: IEC 60050-482:2004, 482-03-30]

3.22

flow cell

secondary cell characterized by the spatial separation of the electrode from the fluid volumes which contain active materials

Note 1 to entry: The fluids, consisting of liquids, solutions, suspensions or gases, flow separately through the electrode spaces.

Note 2 to entry: A flow cell in which one of the active materials is, depending on the state of charge, a solid deposited on one of the electrodes, is called a hybrid flow cell.

3.23

flow battery

two or more flow cells electrically connected in series and including all components for their use as an electrochemical energy storage system

Note 1 to entry: The components can be tanks, pumps, thermal and battery management systems, piping and similar.

3.24

frequency regulation service

<with batteries> regulation mode of the electrical power grid with energy drawn from or supplied to batteries to maintain the system frequency within defined limits

Note 1 to entry: This balancing of the temporal variations of grid frequency occurs typically over time periods of the order of seconds to minutes.

3.25

full charge

<of a battery> state of charge wherein the battery has been completely charged in accordance with the manufacturer's recommended charging conditions.

3.26

full-sized battery

FSB

complete battery that meets the absolute requirements of power capability and energy content, as defined in the respective endurance test clauses

Note 1 to entry: This battery is an assembly of n cells, modules or stacks and is equipped with the relative BMS and BSS as needed.

Note 2 to entry: This note applies to the French language only.

3.27

laboratory test

<of a battery> test made under prescribed and controlled conditions that may or may not simulate field conditions

[SOURCE: IEC 60050-192:2015, 192-09-05]

3.28

load following service

<with batteries> regulation mode of the electrical power grid with energy drawn from or supplied to batteries to compensate for temporary variations in load demand

Note 1 to entry: This balancing of the temporary variations of grid load demand occurs typically over time periods of the order of a few minutes to one hour.

3.29

module

standardized and interchangeable assembly of cells connected in series and/or parallel and associated hardware designed for easy assembly into a commercial battery

3.30**operating voltage range
operating voltage limits**

<of a battery> voltage range, as declared by the manufacturer, in which the battery is to be operated and performs according to specifications

3.31**maximum operating voltage
upper voltage limit** U_{\max}

<of a battery> upper limit of the voltage range in which the battery is operable and performs according to specifications

3.32**minimum operating voltage
lower voltage limit** U_{\min}

<of a battery> lower limit of the voltage range in which the battery is operable and performs according to specification

3.33**peak-power shaving service
load levelling service**

<with batteries> process of energy demand management consisting of supplementing the energy in a localized power grid, during periods of excessive demand or instantaneous high electricity costs, with energy drawn from a battery

Note 1 to entry: The energy utilized to “shave off” the demand peak is recharged into the battery in periods of low energy demand or cheap energy supply.

Note 2 to entry: This demand peak-shaving activity lasts typically over time periods of one to several hours.

3.34**PV energy storage time-shift service**

<with batteries> process of energy demand management consisting of storing photovoltaic energy in a battery for a time deferred release into a localized power grid

Note 1 to entry: This energy demand management occurs typically with a 24 h day/night rhythm.

3.35**performance**

<of a battery> characteristics defining the ability of the battery to achieve the intended function

[SOURCE: IEC 60050-311:2001, 311-06-11, modified — In the definition, “measuring instrument” has been replaced with “battery”.]

3.36**performance test**

test carried out to determine the electrical characteristics of a battery

3.37**secondary cell**

<electrochemical> basic manufactured unit of an electrochemical system capable of storing electric energy in chemical form and delivering that electrical energy back by reconversion of its stored chemical energy.

[SOURCE: IEC 60050-811:1991, 811-20-01, modified]