



# SLOVENSKI STANDARD

## SIST EN 10002-2:1996

01-junij-1996

---

**Kovinski materiali - Natezni preskus - 2. del: Preverjanje sistema za merjenje sile na nateznih preskuševalnih strojih**

Metallic materials - Tensile testing - Part 2: Verification of the force measuring system of the tensile testing machines

Metallische Werkstoffe - Zugversuch - Teil 2: Prüfung der Kraftmeßeinrichtungen von Zugprüfmaschinen

Matériaux métalliques - Essai de traction - Partie 2: Vérification du système de mesure de la charge de la machine d'essai de traction

<https://standards.iteh.ai/catalog/standards/sist/9f1bb96d-0cec-4c51-b682-7c416514c935/sist-en-10002-2-1996>

**Ta slovenski standard je istoveten z: EN 10002-2:1991**

---

**ICS:**

77.040.10 Mehansko preskušanje kovin Mechanical testing of metals

**SIST EN 10002-2:1996**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 10002-2:1996

<https://standards.iteh.ai/catalog/standards/sist/9fd96d-0cec-4c51-b682-7c416514c935/sist-en-10002-2-1996>

EUROPEAN STANDARD

EN 10002-2:1991

NORME EUROPEENNE

EUROPAISCHE NORM

September 1991

UDC 669:620.172

Descriptors: Metal products, mechanical tests, tension tests,  
tensile testing machines, measurements, loads,  
verification

English version

**Metallic materials - Tensile testing - Part 2:  
Verification of the force measuring system of the  
tensile testing machines**

Matériaux métalliques - Essai de  
traction - Partie 2: Vérification du  
système de mesure de la charge de la  
machine d'essai de traction

Metallische Werkstoffe - Zugversuch -  
Teil 2: Prüfung der  
Kraftmessenrichtungen von  
Zugprüfmaschinen

This European Standard was approved by CEN on 1991-09-25.  
CEN members are bound to comply with the CEN/CENELEC Internal Regulations  
which stipulate the conditions for giving this European Standard the  
status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national  
standards may be obtained on application to the Central Secretariat or to  
any CEN member.

This European Standard exists in three official versions (English, French,  
German). A version in any other language made by translation under the  
responsibility of a CEN member into its own language and notified to the  
Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Denmark,  
Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg,  
Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CEN

European Committee for Standardization  
Comité Européen de Normalisation  
Europäisches Komitee für Normung

Central Secretariat: rue de Stassart 36, B-1050 Brussels

(c) CEN 1991 Copyright reserved to all CEN members

Ref. No. EN 10002-2:1991 E

## Contents

	Page
Foreword	3
1. SCOPE	4
2. NORMATIVE REFERENCES	4
3. SYMBOLS AND DEFINITIONS	4
4. GENERAL INSPECTION OF THE TESTING MACHINE	4
5. VERIFICATION OF THE FORCE-MEASURING SYSTEM OF THE TESTING MACHINE	4
5.1 General	4
5.2 Determination of the resolution	7
5.3 Prior verification of the relative resolution of the force indicator	8
5.4 Test procedure	9
5.5 Assessment of the force indicator	13
6. CLASS OF THE TESTING MACHINE	14
7. VERIFICATION REPORT	14
8. INTERVALS BETWEEN VERIFICATIONS	14
	<a href="https://standards.iteh.ai/catalog/standards/sist/9fd1bb96d-0cec-4c51-b682-7c416514c935/sist-en-10002-2-1996">https://standards.iteh.ai/catalog/standards/sist/9fd1bb96d-0cec-4c51-b682-7c416514c935/sist-en-10002-2-1996</a>
ANNEX A GENERAL INSPECTION OF THE TESTING MACHINE	16

## Foreword

The proposal for this European Standard was prepared by the Technical Committee ECISS/TC1A 'Mechanical and physical tests' the Secretariat of which has been allocated to the Association Francaise de Normalisation (AFNOR).

It forms Part 2 of the general standard EN 10 002.

This Standard is based on the International Standard:

ISO 7500/1 - 1986 Metallic materials - Verification of static uniaxial testing machines -

Part 1 : Tensile testing machines.

According to the Common CEN/CENELEC Rules, being part of the Internal Regulations of CEN, the following countries are bound to implement this European Standard:

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

SIST EN 10002-2:1996

The Standard EN 10 002 will comprise the following parts:  
<https://standards.iteh.ai/catalog/standards/sist/961b96d1-0cec-4c51-b682-7c416514c935/sist-en-10002-2-1996>

Part 1 : Metallic materials; Tensile test; Method of test (at ambient temperature)

Part 2 : Verification of the force measuring system of the testing machine

Part 3 : Metallic materials; Tensile test; Calibration of proving devices used for the verification of uniaxial testing machines

Part 4 : Metallic materials; Tensile test; Verification of extensometers used in uniaxial testing

Part 5 : Metallic materials; Tensile test; Method of test at elevated temperatures.

## 1 Scope

This European Standard specifies the verification of the force measuring system of tensile testing machines.

This verification shall be preceded by a general inspection of the testing machine (see clause 4).

The dynamic verification of the forces applied by tensile testing machines is excluded from this Standard.

This Standard is not concerned with the verification of extensometers (see EN 10 002-4).

## 2 Normative References

EN 10002-3 1) Part 3 : Metallic materials - Tensile test : Calibration of force proving instruments used for the verification of uniaxial testing machines.

EN 10002-4 1) Part 4 : Metallic materials - Tensile test - Verification of extensometers used in uniaxial testing.

SIST EN 10002-2:1996

<https://standards.iteh.ai/catalog/standards/sist/9f1bb96d-0ccc-4c51-b682-7c416514c935/sist-en-10002-2-1996>

## 3 Symbols and definitions

For the purpose of this European Standard the symbols and definitions of table 1 shall apply.

## 4 General inspection of the testing machine

The verification of the testing machine shall only be carried out if the machine is in good working order. For this purpose, a general inspection of the machine shall be carried out before verification of the force measuring system of the machine (see annex A).

## 5 Verification of the force-measuring system of the testing machine

### 5.1 General

This verification shall be carried out for each of the force ranges used and with the most frequently employed force indicator. Accessory devices (slave pointer, recorder) which may affect the force-measuring system shall, where used, be verified in accordance with 5.4.6.

If the testing machine has several force-measuring systems, each system shall be regarded as a separate testing machine. The same procedure shall be followed for double-piston hydraulic machines.

- 1) In preparation.

This verification shall be carried out using tension force-proving instruments. For small forces ( $\leq 500$  N) this verification should be carried out with known masses. In the latter case, the value of local acceleration due to gravity shall be recorded in the verification report.

The verification shall, in general, be carried out with a constant indicated force  $F_i$ . When this method is not applicable, the verification may be carried out with a constant true force  $F$  (see Note).

#### Note

When the machine allows, all the verifications shall be carried out with a slowly increasing force. The word 'constant' signifies that the same value of  $F_i$  (or  $F$ ) is used for the three series of measurements made (see 5.4.5).

The instruments used for the verification shall have a certified traceability using the International System of Units (SI).

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 10002-2:1996

<https://standards.iteh.ai/catalog/standards/sist/9f1bb96d-0ccc-4c51-b682-7c416514c935/sist-en-10002-2-1996>

Table 1 Symbols and definitions

Symbol	Unit	Definition
$F_N$	N	Maximum capacity of the measuring range of the force indicator of the testing machine
$F_i$	N	Force reading on the force indicator of the testing machine to be verified, with increasing test force
$F'_i$	N	Force reading on the force indicator of the testing machine to be verified, with decreasing test force
$F$	N	True force indicated by the force-proving instrument or exerted by the masses, with increasing test force
$F'$	N	True force indicated by the force-proving instrument or exerted by the masses, with decreasing test force
$F_C$	N	True force indicated by the force-proving instrument or exerted by the masses, with increasing test force, for the complementary series of measurements for the smallest range which is used
$F_{ic}$	N	Force reading on the force indicator of the testing machine to be verified, with increasing test force, for the complementary series of measurements for the smallest range which is used.
$\bar{F}_i, \bar{F}$	N	Arithmetic mean of several measurements of $F_i$ and $F$ for the same discrete force
$F_{i \max}, F_{i \min}$	N	Highest or lowest value of $F_i$ or $F$ for the same discrete force
$F_{\max}, F_{\min}$ $F_{i0}$	N	Residual indication on the force indicator of the testing machine to be verified after removal of force
$a$	%	Relative resolution of the force indicator of the testing machine
$b$	%	Relative repeatability error of the force measuring system of the testing machine
$f_0$	%	Relative zero error of the force-measuring system of the testing machine
$q$	%	Relative accuracy error of the force-measuring system of the testing machine
$u$	%	Relative error in reversibility of the force-measuring system of the testing machine



The force-proving instruments shall comply with the requirements specified in EN 10 002-3. The class of the instrument shall be equal or better to the class in which the tensile testing machine has been verified. In the case of dead weights, the relative error of the force generated by these weights shall be less than or equal to  $\pm 0.1\%$ . 2).

The verification shall be carried out at ambient temperature between 10 °C and 35 °C.

2) The exact equation giving the force  $F$ , in newtons created by the dead weights of mass  $M$ , in kilograms, is

$$F = Mg_1 \left( 1 - \frac{d}{D} \right)$$

where

$g_1$  is the local acceleration due to gravity, in metres per second squared;

$d$  is the density of air, in kilograms per cubic metre;

$D$  is the density of the dead weights, in kilograms per cubic metre.

This force shall be calculated using the following approximate formula

$$F = Mg_1$$

The relative error of the force is calculated in this instance using the formula

$$\frac{\Delta F}{F} = \frac{\Delta M}{M} + \frac{\Delta g_1}{g_1}$$

## 5.2 Determination of the resolution

### 5.2.1 Analogue scale

The width of the graduation marks on the scale shall be uniform and the width of the pointer (or the width of the trace if a recorder is used) shall be approximately equal to the width of a graduation mark.

The resolution  $r$  of the indicator shall be obtained from the ratio between the width of the pointer or the trace and the centre-to-centre distance between two adjacent scale graduation marks (scale interval). The recommended ratios are 1/2, 1/5 or 1/10, a spacing of 2.5 mm or greater being required for the estimation of one-tenth of a scale division.