

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Application integration at electric utilities – System interfaces for distribution management –
Part 6: Interfaces for maintenance and construction**

**Intégration d'applications pour les services électriques – Interfaces système
pour la gestion de distribution –
Partie 6: Interfaces de maintenance et de construction**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Application integration at electric utilities – System interfaces for distribution management –
Part 6: Interfaces for maintenance and construction**

**Intégration d'applications pour les services électriques – Interfaces système pour la gestion de distribution –
Partie 6: Interfaces de maintenance et de construction**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.200

ISBN 978-2-8322-3257-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms, definitions and abbreviations	9
3.1 Terms and definitions	9
3.2 Abbreviations	9
4 Reference and information models	9
4.1 General.....	9
4.2 Reference model.....	10
4.2.1 General	10
4.2.2 Geographical Inventory (GINV).....	12
4.2.3 Maintenance and Inspection (MAI).....	12
4.2.4 Construction	12
4.2.5 Design	12
4.2.6 Work Scheduling and Dispatching (SCHD).....	12
4.2.7 Field Recording (FRD)	12
4.2.8 Network Operation Simulation (SIM).....	12
4.2.9 Customer Service (CS).....	12
4.2.10 Trouble call management (TCM).....	12
4.2.11 Financial (FIN).....	13
4.2.12 Human resources.....	13
4.2.13 Asset Management (AM) System.....	13
4.2.14 Network Operations (NO)	13
4.3 Interface reference model.....	13
4.4 Maintenance and construction functions and components	14
4.5 Static information model.....	14
4.5.1 Information model classes	14
4.5.2 Classes for maintenance and construction.....	14
4.6 Maintenance and construction use cases	15
5 Maintenance and construction message types.....	16
5.1 General.....	16
5.2 Work.....	17
5.3 Work request message.....	17
5.3.1 General	17
5.3.2 Applications – Carry out planned maintenance with temporary equipment.....	17
5.3.3 Message format	19
5.4 Service order message.....	20
5.4.1 General	20
5.4.2 Applications – Meter installation and removal	20
5.4.3 Message format	21
5.5 Maintenance order message.....	23
5.5.1 General	23
5.5.2 Applications	23
5.5.3 Message format	24

6	Document conventions.....	26
6.1	UML diagrams.....	26
6.2	Message definitions	26
6.2.1	General	26
6.2.2	Mandatory versus optional	26
Annex A	(normative) Description of message type verbs.....	27
Annex B	(normative) XML Schemas for Message Payloads.....	29
B.1	General.....	29
B.2	WorkRequest	29
B.3	ServiceOrder.....	50
B.4	MaintenanceOrder.....	91
	Bibliography	143
	Figure 1 – Asset life cycle.....	10
	Figure 2 – IEC 61968-6 reference model for maintenance.....	11
	Figure 3 – End-to-end business cases and related messages	16
	Figure 4 – Carry out planned maintenance with temporary equipment	18
	Figure 5 – Work request message format	19
	Figure 6 – Meter installation and removal.....	20
	Figure 7 – Service order message format.....	22
	Figure 8 – Maintenance of high voltage device (transformer etc) requested by FRD	24
	Figure 9 – MaintenanceOrder message format	25
	Table 1 – Document overview for IEC 61968-6.....	7
	Table 2 – Business functions and abstract components	14
	Table 3 – Maintenance and construction classes	15
	Table A.1 – Commonly used verbs	27

<https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d-1e220533406c/iec-61968-6-2015>
 IEC 61968-6:2015

INTERNATIONAL ELECTROTECHNICAL COMMISSION

—————

**APPLICATION INTEGRATION AT ELECTRIC UTILITIES –
SYSTEM INTERFACES FOR DISTRIBUTION MANAGEMENT –**
Part 6: Interfaces for maintenance and construction
FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This part of International Standard IEC 61968 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This bilingual version (2016-08) corresponds to the monolingual English version, published in 2015-07.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/1566/FDIS	57/1586/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61968 series, published under the general title *Application integration at electric utilities – System interfaces for distribution management*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW

(standards.iteh.ai)

[IEC 61968-6:2015](https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d-9b32205e59dc/iec-61968-6-2015)

<https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d-9b32205e59dc/iec-61968-6-2015>

INTRODUCTION

The IEC 61968 standard, taken as a whole, defines interfaces for the major elements of an interface architecture for Distribution Management Systems (DMS). IEC 61968-1, *Interface architecture and general recommendations*, identifies and establishes requirements for standard interfaces based on an Interface Reference Model (IRM). IEC 61968-3 to 9 of this standard define interfaces relevant to each of the major business functions described by the Interface Reference Model.

As used in IEC 61968, a DMS consists of various distributed application components for the utility to manage electrical distribution networks. These capabilities include monitoring and control of equipment for power delivery, management processes to ensure system reliability, voltage management, demand-side management, outage management, work management, automated mapping and facilities management.

This set of standards is limited to the definition of interfaces and is implementation independent. They provide for interoperability among different computer systems, platforms, and languages. Methods and technologies used to implement functionality conforming to these interfaces are considered outside of the scope of these standards; only the interface itself is specified in these standards.

The purpose of this part of IEC 61968 is to define a standard for the integration of Maintenance and Construction Systems (MC), which would include Work Management Systems, with other systems and business functions within the scope of IEC 61968. The scope of this standard is the exchange of information between Maintenance and Construction Systems and other systems within the utility enterprise. The specific details of communication protocols those systems employ are outside the scope of this standard. Instead, this standard will recognize and model the general capabilities that can be potentially provided by maintenance and construction systems including planned, unplanned and conditional maintenance. In this way, this standard will not be impacted by the specification, development and/or deployment of next generation maintenance systems, either through the use of standards or proprietary means.

The IEC 61968 series of standards is intended to facilitate *inter-application integration* as opposed to *intra-application integration*. Intra-application integration is aimed at programs in the same application system, usually communicating with each other using middleware that is embedded in their underlying runtime environment, and tends to be optimised for close, real-time, synchronous connections and interactive request/reply or conversation communication models. IEC 61968, by contrast, is intended to support the inter-application integration of a utility enterprise that needs to connect disparate applications that are already built or new (legacy or purchased applications), each supported by dissimilar runtime environments. Therefore, these interface standards are relevant to loosely coupled applications with more heterogeneity in languages, operating systems, protocols and management tools. This series of standards is intended to support applications that need to exchange data every few seconds, minutes, or hours rather than waiting for a nightly batch run. This series of standards, which are intended to be implemented with middleware services that exchange messages among applications, will complement, not replace, utility data warehouses, database gateways, and operational stores.

As used in IEC 61968, a Distribution Management System (DMS) consists of various distributed application components for the utility to manage electrical distribution networks. These capabilities include monitoring and control of equipment for power delivery, management processes to ensure system reliability, voltage management, demand-side management, outage management, work management, automated mapping and facilities management. Standard interfaces are defined for each class of applications identified in the Interface Reference Model (IRM), which is described in IEC 61968-1, *Interface architecture and general recommendations*.

This part of IEC 61968 contains the clauses listed in Table 1.

Table 1 – Document overview for IEC 61968-6

Clause	Title	Purpose
1	Scope	The scope and purpose of the document are described.
2	Normative references	Documents that contain provisions which, through reference in this text, constitute provisions of this International Standard.
3	Reference and information models	Description of general approach to work management system, reference model, use cases, interface reference model, maintenance and construction functions and components, message type terms and static information model.
4	Maintenance and construction message types	Message types related to the exchange of information for documents related to maintenance and construction.
Annex A	Message type verbs	Description of the verbs that are used for the message types.
Annex B	XML schemas for message payloads	To provide xsd information for use by developers to create IEC 61968-9 messages.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61968-6:2015](https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d-9b32205e59dc/iec-61968-6-2015)

<https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d-9b32205e59dc/iec-61968-6-2015>

APPLICATION INTEGRATION AT ELECTRIC UTILITIES – SYSTEM INTERFACES FOR DISTRIBUTION MANAGEMENT –

Part 6: Interfaces for maintenance and construction

1 Scope

This part of IEC 61968 specifies the information content of a set of message types that can be used to support business functions related to Maintenance and Construction. Typical uses of the message types defined in this part of IEC 61968 include planned maintenance, unplanned maintenance, conditional maintenance, work management, new service requests, etc. Message types defined in other parts of IEC 61968 may also be relevant to these use cases.

The mapping of these messages to specific technologies such as XML will be described at a later date.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050, *International Electrotechnical Vocabulary*

<https://standards.iteh.ai/catalog/standards/sist/2603812e-b953-42ed-974d->

IEC 61968-1, *Application integration at electric utilities – System interfaces for distribution management – Part 1: Interface architecture and general recommendations*

IEC TS 61968-2, *Application integration at electric utilities – System interfaces for distribution management – Part 2: Glossary*

IEC 61968-4, *Application integration at electric utilities – System interfaces for distribution management – Part 4: Interfaces for records and asset management*

IEC 61968-9:2013, *Application integration at electric utilities – System interfaces for distribution management – Part 9: Interfaces for meter reading and control*

IEC 61968-11, *Application integration at electric utilities – System interfaces for distribution management – Part 11: Common information model (CIM) extensions for distribution*

IEC 61970-301, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*

IEC TR 62051, *Electricity metering – Glossary of terms*

IEC 62055-31, *Electricity metering – Payment systems – Part 31: Particular requirements – Static payment meters for active energy (classes 1 and 2)*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this standard, the terms and definitions given in IEC 60050-300, IEC TS 61968-2, IEC TR 62051, IEC 62055-31 and the following terms apply.

Where there is a difference between the definitions in this standard and those contained in other referenced IEC standards, then those defined in IEC 61968-2 shall take precedence over the others listed, and those defined in IEC 61968-6 shall take precedence over those defined in IEC 61968-2.

3.2 Abbreviations


AM	Asset Management
CIM	Common Information Model
NO	Network Operations
OMS	Outage Management System
WM	Work Management
GINV	Geographical Inventory
MAI	Maintenance & Inspection
CON	Construction
DGN	Design
SCHD	Work Scheduling and Dispatching
FRD	Field Recording
NE	Network Extension Planning
TCM	Trouble Call Management
MR&C	Meter Read and Control
CS	Customer Services
HR	Human Resources
FIN	Financials

4 Reference and information models

4.1 General

The message types defined in this document are based on a logical partitioning of the DMS business functions and components called the IEC 61968 Interface Reference Model.

Figure 1 provides an overview diagram which puts Maintenance and Construction as well as Work Management in context of Enterprise Asset Management. The diagram demonstrates the relationship between asset and power system resource. It also relates Work to the construction process (when new asset is built) and to the maintenance process (when inspection or repair is performed on the existing asset).



IEC 61968-6:2015
<https://standards.iteh.ai/catalog/standards/sis/2009/120-b953-42ed-974d-9b32205e59dc/iec-61968-6-2015>
Figure 1 – Asset life cycle

IEC

The contents of the message types are based on a static information model to ensure consistency of field names and data types. Each message type is defined as a set of fields copied from the information model classes in IEC 61968-11. The message types defined in this standard are intended to satisfy a majority of typical applications. In some particular project implementations, it may be desirable to modify the set of fields using a methodology such as that described in IEC 61968-1.

4.2 Reference model

4.2.1 General

The diagram shown in Figure 2 serves as reference model and provides example of the logical components and data flows related to this International Standard. Subclause 4.5.2 provides references to terms that are defined by the CIM.

The diagram in Figure 2 describes the flows between the components in the reference model. The numbers in brackets provide linkages to the flow definitions. As per the title of Figure 2, this reference model includes only a subset of all maintenance and construction functions. The rest of the functions, especially functions related to Construction, will be included in future editions of this standard.




Figure 2 – IEC 61968-6 reference model for maintenance

The reference architecture reflects several main logical components (potentially realized as systems or subsystems) related to maintenance:

- a) Geographical Inventory (GINV)
- b) Maintenance and Inspection (MAI)
- c) Construction (CON)
- d) Design (DGN)
- e) Work Scheduling and Dispatching (SCHD)
- f) Field Recording (FRD)
- g) Asset Management System (AM)
- h) Network Operations Simulation (SIM)
- i) Network Operations (NO)
- j) Network Extension Planning (NE)
- k) Trouble Call Management (TCM)
- l) Meter Read and Control (MR&C)
- m) Customer Service (CS)
- n) Human Resources (HR)
- o) Materials Management System
- p) Financial System (FIN)

4.2.2 Geographical Inventory (GINV)

Management of geospatial data, typically by utilizing computer graphics technology to enter, store, and update graphic and non-graphic information. Geographic depictions and related non-graphic data elements for each entity are typically stored some form of a database. The graphic representations are referenced using a coordinate system that relates to locations on the surface of the earth. Information in the database can be queried and displayed based upon either the graphic or non-graphic attributes of the entities.

4.2.3 Maintenance and Inspection (MAI)

Work involving inspection, cleaning, adjustment, or other service of equipment to enable it to perform better or to extend its service life. Examples of maintenance work are routine oil changes and painting. Examples of inspection work are pole inspections, vault inspections, and substation inspections.

4.2.4 Construction

Examples of construction work include service installations, line extensions, and system betterment projects.

4.2.5 Design

A design is created by an engineer or work planner using the Design and Estimation System (DGN). Designs can be made up of individual line items or by a set of “Compatible Units” or CUs. Line items and Compatible Units are associated with a Design Location which is associated with the Location object in the CIM.

4.2.6 Work Scheduling and Dispatching (SCHD)

Work scheduling and dispatching makes it possible, for a defined scope of work, to assign the required resources and keep track of work progress.

4.2.7 Field Recording (FRD)

Field recording is often accomplished through hand held devices which allow field personnel to view and enter information relevant to the work they are performing in the field. For example, line crews and servicemen can access their respective district maps, do searches by pole number, substation, transformer number, switch numbers, and feeder names.

4.2.8 Network Operation Simulation (SIM)

This set of functions allows facilities to define, prepare and optimise the sequence of operations required for carrying out maintenance work on the system (release/clearance orders) and operational planning.

4.2.9 Customer Service (CS)

This function set covers the different aspects related to customer interfaces required for operation and commercial purposes.

4.2.10 Trouble call management (TCM)

Customer troubles related to blackouts are then transmitted and compared with network data in order to provide accurate information on the incident.

4.2.11 Financial (FIN)

Financial performance across the whole organization, which includes the evaluation of investments in capital projects, maintenance, or operations. These processes include risk and benefit costs and impact on levels of service.

4.2.12 Human resources

Human resource information contains personnel information for each employee. It includes such data as job code, employee status, department or place in the organisation, and job-related skills. This information is often needed and updated by work and project management-oriented business sub-functions.

4.2.13 Asset Management (AM) System

Utilities will employ some form of asset management software in an effort to maintain detailed records regarding their physical assets. Asset management is treated categorically in IEC 61968-4.

4.2.14 Network Operations (NO)

This function provides utilities for supervising main substation topology (breaker and switch state) and control equipment status. It also provides the utilities for handling network connectivity and loading conditions. It also makes it possible to locate customer telephone complaints and supervise the location of field crews.

4.3 Interface reference model

It is not the intention of this standard to define the applications and systems that vendors should produce. It is expected that a concrete (physical) application will provide the functionality of one or more abstract (logical) components as listed in this standard. These abstract components are grouped by the business functions of the Interface Reference Model.

In this standard, the term abstract component is used to refer to that portion of a software system that supports one or more of the interfaces defined in IEC 61968-3 to -9 and IEC 61968-13. It does not necessarily mean that compliant software is delivered either as separate modules or as a single system.

IEC 61968-1 describes infrastructure services common to all abstract components while IEC 61968-3 to -9 and -13 define the details of the information exchanged for specific types of abstract component.

IEC 61968 defines that:

- a) An inter-application infrastructure is compliant if it supplies services defined in IEC 61869-1 to support at least two applications with interfaces compliant to sections of IEC 61968-3 to -9 and -13.
- b) An application interface is compliant if it supports the interface standards defined in IEC 61968-3 to -9 and -13 for the relevant abstract components defined in the Interface Reference Model.
- c) An application is only required to support interface standards of the applicable components listed under abstract components. An application is not required to support interfaces required by other abstract components of the same business sub-function or within the same business function. While this standard primarily defines information exchanged among components in different business functions, it will occasionally also define information exchanged among components within a single business function when a strong market need for this capability has been realised.