



Designation: D 6807 – 02

Standard Test Method for Operating Performance of Continuous Electrodeionization Systems on Reverse Osmosis Permeates from 2 to 100 $\mu\text{S}/\text{cm}^1$

This standard is issued under the fixed designation D 6807; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the determination of the operating characteristics of continuous electrodeionization (CEDI) devices, indicative of deionization performance when a device is applied to production of highly deionized water from the product water of a reverse osmosis system. This test method is a procedure applicable to feed waters containing carbonic acid and/or dissolved silica and other solutes, with a conductivity range of approximately 2 to 100 microsiemens- cm^{-1} .

1.2 This test method covers the determination of operating characteristics under standard test conditions of CEDI devices where the electrically active transfer media therein is predominantly regenerated.

1.3 The method is not necessarily indicative of:

1.3.1 Long term performance on feed waters containing foulants and/or sparingly soluble solutes;

1.3.2 Performance on feeds of brackish water, sea water, or other high salinity feeds;

1.3.3 Performance on synthetic industrial feed solutions, pharmaceuticals, or process solutions of foods and beverages; or,

1.3.4 Performance on feed waters less than 2 $\mu\text{S}/\text{cm}$, particularly performance relating to organic solutes, colloidal or particulate matter, or biological or microbial matter.

1.4 The test method, subject to the limitations described, can be applied as either an aid to predict expected deionization performance for a given feed water quality, or as a method to determine whether performance of a given device has changed over some period of time. It is ultimately, however, the user's responsibility to ensure the validity of the test method for their specific applications.

1.5 *This standard may involve hazardous materials, operations, and equipment. This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

D 513 Test Methods for Total and Dissolved Carbon Dioxide in Water (Method A or B)

D 859 Test Method for Silica in Water

D 1125 Test Methods for Electrical Conductivity and Resistivity of Water (Method B)

D 1129 Terminology Relating to Water

D 1293 Test Methods for pH of Water (Method B)

D 2777 Practice for Determination of Precision and Bias of Applicable Methods of Committee D19 on Water

D 4194 Test Methods for Operating Characteristics of Reverse Osmosis Devices (Method B)

3. Terminology

3.1 *Definitions*—For definitions of general terms used in these test methods, refer to Terminology D 1129.

3.2 For descriptions of terms relating to reverse osmosis, refer to Test Methods D 4194.

3.3 *Definitions of Terms Specific to This Standard:*

3.3.1 *cell*—an independently fed chamber formed by two adjacent ion exchange membranes, or by a membrane and an adjacent electrode.

3.3.2 *continuous electrodeionization (CEDI) device*—a device that removes ionized and ionizable species from liquids using electrically active media and using an electrical potential to influence ion transport, where the ionic transport properties of the active media are a primary sizing parameter. CEDI devices typically comprise semi-permeable ion exchange membranes and permanently charged ion exchange media. Examples include continuous deionization, electrodiagnosis, and packed-bed or filled-cell electrodialysis.

3.3.3 *current efficiency*—the ratio, expressed in percent, of the net transfer of ionized and ionizable solutes per unit cell within a CEDI device, expressed in chemical equivalents transferred per unit time, to the number of coulombs transferred from an external DC power source to each electrode

¹ This test method is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.08 on Membranes and Ion Exchange Materials.

Current edition approved June 10, 2002. Published August 2002.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

pair, expressed in faradays per unit time. Calculation of current efficiency is described in 9.2.

4. Summary of Test Method

4.1 This test method is used to determine performance capabilities of CEDI devices with regard to extent of ion removal, pressure/flow relationships and electrical power consumption at standard or nominal operating conditions, electrical current characteristics, and the relative ability of the device to remove ionized and ionizable species when fed reverse osmosis permeate water. On this type of feed, there is considerable water splitting and ion-exchange resin regeneration, causing certain species to become ionized within the device, either by the electromotive force or a localized pH shift. The method is applicable to both new and used devices.

4.2 Pressure loss data is obtained. This information provides information relating to possible particulate plugging, fouling, or internal damage of the device. Deionization performance, extent of silica and dissolved carbon dioxide removal, concentrating stream pH, and applied voltage are determined at a predetermined level of electrical current transfer. The ohmic (electrical) resistance is determined. This information in combination with concentrating stream pH provides basic design and performance information.

5. Significance and Use

5.1 CEDI devices can be used to produce deionized water from feeds of pretreated water. This test method permits the measurement of key performance capabilities of CEDI devices using a standard set of conditions. The data obtained can be analyzed to provide information on whether changes may have occurred in operating characteristics of the device independently of any variability in feed water characteristics or operating conditions. Under specific circumstances, the method may also provide sufficient information for plant design.

6. Apparatus

6.1 Description:

6.1.1 The test apparatus is schematically represented in Fig. 1. Feed water to the apparatus may be passed through a heat exchanger and/or other accessories to modify and/or control feed water temperature as desired. Alternately, data obtained from the operation of the apparatus may be normalized for temperature if normalization factors are known.

6.1.2 Feed water to the apparatus enters a holding tank (open or vented) of volume sufficient to maintain good control of water level and solute concentrations. The tank is unpressurized, ported to be capable of occasional cleanings or sanitizations, and incorporates needed safety features such as high temperature and overflow protection. The tank also incorporates a drain valve. During operation of the apparatus, the drain valve may be used in combination with a valve controlling the rate of feed water to the apparatus to aid in control of solute concentrations, water level, and temperature within the tank. The tank supplies water to a recirculation pump designed to feed water to the CEDI device at a flow rate and pressure consistent with the ratings of the CEDI device. A

recirculation line with shut off valve from the pump discharge to the tank may be incorporated as required for proper pump operation.

6.1.3 Adjustment of feed water solute concentration is not required. Adjust feed water pH as required by the manufacturer of the CEDI device. Feed water to the CEDI device must be monitored for solute concentrations, pH (Test Method D 1293), and temperature. Solute concentration may be monitored via electrical conductivity or resistivity (Test Method D 1125) in combination with silica (Test Method D 513) and carbon dioxide (Test Method D 859) concentration measurement, or alternately may be monitored for individual ionic species and dissolved carbon dioxide and silica, depending on the feed water supplied to the tank and the solutes of interest.

6.1.4 Feed water provided to the CEDI device should be plumbed as specified by the supplier, with appropriate flow and pressure controls, internal recirculations, drains, interlocks, safety controls, and other features as required. Pressure at the inlet and outlet and flow rates of each the streams of interest must be monitored (for example, deionized water stream, concentrate stream, and electrode feed stream).

6.1.5 The CEDI device should be powered as specified by the supplier, with equipment and wiring to provide appropriate supply DC voltage and amperage, controls, interlocks, grounding, and safety features. Supply voltage and supply amperage to the CEDI device should be monitored at positions within the device or device assembly as specified by the supplier.

6.1.6 Streams leaving the CEDI device may be returned to the tank via return lines. Alternately, one or more of the streams may be sent either completely or partially to drain via appropriate valving if such operation provides easier control of desired feed water conditions. The outlet deionization stream is monitored for the same solutes as for the feed water. The outlet concentrating stream is also monitored for the same solutes as for the feed water. Control of temperature is not required. For CEDI devices with internal recirculation and “feed and bleed” features, solute concentrations must be measured at locations that are indicative of conditions within the CEDI module prior to mixing of recirculation flows.

6.1.7 Feed water to the tank of the test apparatus shall be prepared using reverse osmosis apparatus. The pretreatment requirements for the RO are optional depending on the application, but should, at minimum, conform to the manufacturer’s specifications for the particular system.

6.2 Installation:

6.2.1 Materials of construction shall be as specified by the supplier of the CEDI device and in conformance to standard engineering practice.

6.2.2 Controls and monitors should be calibrated and maintained according with suppliers requirements and standard engineering practice.

7. Reagents

7.1 Specific chemical reagents are not required for this test method. However, chemical modification such as pH adjustment, addition of trace solutes, and the addition of dissolved carbon dioxide may be applicable under certain circumstances. Unless otherwise indicated, it is intended that all reagents shall conform to the specifications of the Committee on Analytical