

# **IEC TS 62782**

Edition 1.0 2016-03

# TECHNICAL SPECIFICATION



<u>IEC TS 62782:2016</u> https://standards.iteh.ai/catalog/standards/sist/66d42e83-4fd7-487c-b266-303219e54fa5/iec-ts-62782-2016





### THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office	Tel.: +41 22 919 02 11
3, rue de Varembé	Fax: +41 22 919 03 00
CH-1211 Geneva 20	info@iec.ch
Switzerland	www.iec.ch

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

#### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

### IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

### IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number) text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - webstore.iec.ch/justpublished Stay up to date on all new IEC publications. Just Published

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

### IEC Customer Service Centre - webstore.iec.ch/csc

details all new publications released. Available on the and <u>62/1f-youl</u> wish to give us your feedback on this publication or also once a month by emailtips://standards.iteh.ai/catalog/standardheed further assistance, please contact the Customer Service 303219e54fa5/iec-Centresese@jec.ch.



# **IEC TS 62782**

Edition 1.0 2016-03

# TECHNICAL SPECIFICATION

# Photovoltaic (PV) modules T cyclic (dynamic) mechanica Moad testing (standards.iteh.ai)

<u>IEC TS 62782:2016</u> https://standards.iteh.ai/catalog/standards/sist/66d42e83-4fd7-487c-b266-303219e54fa5/iec-ts-62782-2016

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 27.160

ISBN 978-2-8322-3223-1

Warning! Make sure that you obtained this publication from an authorized distributor.

## CONTENTS

- 2 -

FOF	FOREWORD	
1	Scope	.5
2	Normative references	.5
3	Terms and definitions	.6
4	Apparatus	.6
5	Initial measurements	.6
6	Procedure	.7
7	Final measurements	.7
8	Test report	.8
Ann	ex A (informative) Subsequent testing	.9

# iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>IEC TS 62782:2016</u> https://standards.iteh.ai/catalog/standards/sist/66d42e83-4fd7-487c-b266-303219e54fa5/iec-ts-62782-2016

### INTERNATIONAL ELECTROTECHNICAL COMMISSION

## PHOTOVOLTAIC (PV) MODULES – CYCLIC (DYNAMIC) MECHANICAL LOAD TESTING

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies. sist/66042e83-4fd7-487c-b266-
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62782, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/971/DTS	82/1014A/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

# iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>IEC TS 62782:2016</u> https://standards.iteh.ai/catalog/standards/sist/66d42e83-4fd7-487c-b266-303219e54fa5/iec-ts-62782-2016

## PHOTOVOLTAIC (PV) MODULES – CYCLIC (DYNAMIC) MECHANICAL LOAD TESTING

### 1 Scope

This technical specification provides a test method for performing a cyclic (dynamic) mechanical load test in which the module is supported at the design support points and a uniform load normal to the module surface is cycled in alternating negative and positive directions. This test may be utilized to evaluate if components within the module including solar cells, interconnect ribbons and/or electrical bonds within the module are susceptible to breakage or if edge seals are likely to fail due to the mechanical stresses encountered during installation and operation. This test can be performed at any module temperature within the normal operating temperature range. Since the results have been determined to depend on the module temperature during the application of the load it is critical to maintain the module at a constant temperature during the performance of this test.

This technical specification has historically been applied to rigid modules. It cannot be applied to flexible modules unless they are designed to be mounted in a rigid manner. In which case, the cyclic (dynamic) mechanical load test can be applied to the flexible module in its rigid mounting system.

This test has been written as a standalone technical specification, but it is likely to be used in conjunction with other test standards. Typically, this test itself will not result in power loss, but when followed by additional stress tests like thermal cycling and humidity freeze, the damage done by the mechanical cycling results in power loss that would not have occurred due only to the thermal cycling and humidity freeze tests. For example, the transportation testing procedure (IEC 62759) includes the requirements for such a cyclic (dynamic) mechanical load test followed by 50 thermal cycles and 10 humidity freeze cycles.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 60904-12, Photovoltaic devices – Part 12: Infrared thermography of photovoltaic modules<sup>1</sup>

IEC TS 60904-13, Photovoltaic devices – Part 13: Electroluminescence of photovoltaic  $modules^{1}$ 

IEC 61215-1:2016, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1: Test requirements

IEC 61215-2:2016, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures

IEC TS 61836, Solar photovoltaic energy systems – Terms, definitions and symbols

<sup>&</sup>lt;sup>1</sup> To be published.

ISO/IEC 17025, General requirements for the competence of testing and calibration laboratories

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC TS 61836 apply.

### 4 Apparatus

The apparatus for this technical specification include:

- a) Equipment for performing the cyclic (dynamic) loading: this equipment shall be capable of applying a uniform load of 1 000 Pa  $\pm$  100 Pa onto the module surface in both directions to simulate pressure and tensile loads at a rate between 3 and 7 cycles per minute. The prescribed load is of uniform pressure, *P*, and is most appropriately applied with a pressure of air or vacuum. If a piston system (or other non-uniform application) is used to load the module, the force each piston (or applicators) exert is F = PA/n, where *A* is the area of the module and *n* is the number of pistons. To ensure a similar effect to the module, the maximum, perpendicular, center-to-center distance between evenly loaded points shall be 20 cm or less. If one piston consists of multiple loading points this maximum distance refers to both the loading points within and between pistons. The maximum perpendicular distance between the module frame and an evenly loaded point shall also be 20 cm or less.
- b) Means for monitoring, throughout the test, the continuity of the internal circuit of each module. (standards.iteh.ai)
- c) Means for monitoring the temperature of the module to an accuracy of ±2,0 °C and repeatability of ±0,5 °C. The temperature sensors shall be attached to the front or back surface of the module near the middle without interfering with the cyclic loading.
- d) Infrared (IR) camera and a constant current power supply capable of providing between one and two times the Standard Test Condition (STC) maximum power current of the module in the forward direction. (See future IEC TS 60904-12.)
- e) Electroluminescence (EL) equipment and a constant current power supply capable of providing between 0,1 and 1 times the STC short circuit current of the module in the forward direction. (See future IEC TS 60904-13.)

The IR and EL systems do not have to be capable of observing the module while it is under test. These tests can be performed independent of the cyclic (dynamic) load test equipment.

### 5 Initial measurements

The following measurements shall be performed on the test module before beginning the stress testing.

- a) Perform a visual inspection of the module in accordance with IEC 61215-2 MQT 01.
- b) Perform the initial module stabilization procedure in accordance with IEC 61215-2 MQT 19.1.
- c) Measure the maximum power performance of the module in accordance with IEC 61215-2 MQT 02.
- d) Perform an insulation test in accordance with IEC 61215-2 MQT 03.
- e) Perform a wet leakage current test in accordance with IEC 61215-2 MQT 15.
- f) Perform an EL scan of the module using a forward bias current between 0,1 and one times the STC short circuit current to identify cracked cells and other breaks in the cell junction. Note the observed broken cells, interconnects and/or electrical bonds or any additional anomalies observed in the test report (Clause 8k) as identified in future IEC TS 60904-13.

- 6 -

g) Perform an IR scan of the module using a forward bias current between the STC maximum power current and twice the STC maximum power current to identify areas of localized heating. Note the observed areas of localized heating in the test report (Clause 8k) as identified in future IEC TS 60904-12.

If there is reason to use a current of more than *lsc* in either the IR or EL test, check with the module manufacturer to determine that such a high current will not damage the module.

### 6 Procedure

- a) Equip the module so that the electrical continuity of the internal circuit can be monitored continuously during the test.
- b) Mount the module on the cyclic (dynamic) loading equipment using the method prescribed by the manufacturer including the mounting means (clips/clamps and any kind of fastener) and underlying support rails. If there are different possibilities each mounting method needs to be evaluated separately. For all mounting methods, mount the module in a manner where the distance between the fixing points is worst case, which is typically at the maximum distance.
- c) Set the module temperature at the desired level. Monitor the module temperature throughout the application of the cyclic loading. Maintain module temperature within  $\pm 2$  °C of the selected temperature during the application of the cyclic loading.
- d) Apply the cyclic (dynamic) mechanical load and cycle it 1 000 times using a maximum pressure of ±1 000 Pa (with a tolerance of ±100 Pa) and a rate between 3 and 7 cycles per minute. (Cycles being defined as one positive and one negative load application.)
- e) Monitor continuity throughout the test.

Measuring continuity requires only a small current flow (1% of Isc would be more than adequate). However, there may be cases where it would be useful or interesting for the test to be performed with a higher current flow up to the STC peak power current. If that is the case this fact should be noted in the test report (Clause 8 j). Such 7a<sup>4</sup> test could end up causing arcing in broken cells or broken interconnects icc-ts-62782-2016

Cyclic (dynamic) mechanical load tests are normally performed in the laboratory at room temperature. However, there may be cases where it is of interest to perform the test at either lower temperatures to simulate stress during winter or at higher temperatures to simulate stress during summertime operation. Temperature ranges shall be limited by the minimum/maximum operating temperature of module and mounting materials under test (e.g. clip rubber, washers, etc.). The module temperature during the cyclic loading should be noted in the test report (Clause 8 j).

### 7 Final measurements

- a) Perform a visual inspection of the module in accordance with IEC 61215-2 MQT 01.
- b) Perform the final module stabilization procedure in accordance with IEC 61215-2 MQT 19.2.
- c) Measure the maximum power performance of the module in accordance with IEC 61215-2 MQT 02.
- d) Perform an insulation test in accordance with IEC 61215-2 MQT 03.
- e) Perform a wet leakage current test in accordance with IEC 61215-2 MQT 15.
- f) Perform an EL scan of the module using a forward bias current between 0,1 and one times the STC short circuit current to identify changes in the module using the guidance from future IEC TS 60904-13.
- g) Perform an IR scan of the module using a forward bias current between the STC peak power current and twice the STC peak power current to identify changes in the module using guidance from future IEC TS 60904-12.