

IEC 61378-1
(Second edition – 2011)

Converter transformers –
Part 1: Transformers for industrial applications

CORRIGENDUM 1

Replace the existing Formula (H.1) by the following new formula:

$$\rho = K_b / \sqrt{1 + (K_b / K_c)^2} - K_b / K_c \quad (\text{H.1})$$

Replace the existing Formula (H.2) by the following new formula:

$$\text{tg } \alpha = \sqrt{3} \times (1 - K_b / K_c) / (1 + K_b / K_c) \quad (\text{H.2})$$

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61378-1:2011/COR1:2012](https://standards.iteh.ai/catalog/standards/iec/f087cd8-b945-4087-bd7c-5ade020bff96/iec-61378-1-2011-cor1-2012)

<https://standards.iteh.ai/catalog/standards/iec/f087cd8-b945-4087-bd7c-5ade020bff96/iec-61378-1-2011-cor1-2012>