

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electromagnetic compatibility (EMC) –
Part 4-30: Testing and measurement techniques - Power quality measurement
methods**

**Compatibilité électromagnétique (CEM) –
Partie 4-30: Techniques d'essai et de mesure – Méthodes de mesure de la qualité
de l'alimentation**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



IEC 61000-4-30

Edition 3.1 2021-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electromagnetic compatibility (EMC) –
Part 4-30: Testing and measurement techniques - Power quality measurement
methods**

**Compatibilité électromagnétique (CEM) –
Partie 4-30: Techniques d'essai et de mesure – Méthodes de mesure de la qualité
de l'alimentation**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.100.99

ISBN 978-2-8322-9538-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**Electromagnetic compatibility (EMC) –
Part 4-30: Testing and measurement techniques - Power quality measurement
methods**

**Compatibilité électromagnétique (CEM) –
Partie 4-30: Techniques d'essai et de mesure - Méthodes de mesure de la qualité
de l'alimentation**

CONTENTS

FOREWORD	7
INTRODUCTION	9
1 Scope	10
2 Normative references	10
3 Terms and definitions	11
4 General	16
4.1 Classes of measurement	16
4.2 Organization of the measurements	17
4.3 Electrical values to be measured	17
4.4 Measurement aggregation over time intervals	17
4.5 Measurement aggregation algorithm	18
4.5.1 Requirements	18
4.5.2 150/180-cycle aggregation	18
4.5.3 10-min aggregation	18
4.5.4 2-hour aggregation	20
4.6 Time-clock uncertainty	21
4.7 Flagging concept	21
5 Power quality parameters	21
5.1 Power frequency	21
5.1.1 Measurement method	21
5.1.2 Measurement uncertainty and measuring range	22
5.1.3 Measurement evaluation	22
5.1.4 Aggregation	22
5.2 Magnitude of the supply voltage	22
5.2.1 Measurement method	22
5.2.2 Measurement uncertainty and measuring range	22
5.2.3 Measurement evaluation	23
5.2.4 Aggregation	23
5.3 Flicker	23
5.3.1 Measurement method	23
5.3.2 Measurement uncertainty and measuring range	23
5.3.3 Measurement evaluation	23
5.3.4 Aggregation	23
5.4 Supply voltage dips and swells	24
5.4.1 Measurement method	24
5.4.2 Detection and evaluation of a voltage dip	24
5.4.3 Detection and evaluation of a voltage swell	25
5.4.4 Calculation of a sliding reference voltage	26
5.4.5 Measurement uncertainty and measuring range	26
5.5 Voltage interruptions	26
5.5.1 Measurement method	26
5.5.2 Evaluation of a voltage interruption	26
5.5.3 Measurement uncertainty and measuring range	27
5.5.4 Aggregation	27
5.6 Transient voltages	27

5.7	Supply voltage unbalance	27
5.7.1	Measurement method	27
5.7.2	Measurement uncertainty and measuring range	28
5.7.3	Measurement evaluation	29
5.7.4	Aggregation	29
5.8	Voltage harmonics	29
5.8.1	Measurement method	29
5.8.2	Measurement uncertainty and measuring range	29
5.8.3	Measurement evaluation	30
5.8.4	Aggregation	30
5.9	Voltage interharmonics	30
5.9.1	Measurement method	30
5.9.2	Measurement uncertainty and measuring range	30
5.9.3	Evaluation	30
5.9.4	Aggregation	30
5.10	Mains signalling voltage on the supply voltage	31
5.10.1	General	31
5.10.2	Measurement method	31
5.10.3	Measurement uncertainty and measuring range	31
5.10.4	Aggregation	31
5.11	Rapid voltage change (RVC)	31
5.11.1	General	31
5.11.2	RVC event detection	32
5.11.3	RVC event evaluation	33
5.11.4	Measurement uncertainty	35
5.12	Underdeviation and overdeviation	35
5.13	Current	35
5.13.1	General	35
5.13.2	Magnitude of current	36
5.13.3	Current recording	36
5.13.4	Harmonic currents	37
5.13.5	Interharmonic currents	37
5.13.6	Current unbalance	37
6	Performance verification	37
Annex A	(informative) Power quality measurements – Issues and guidelines	40
A.1	General	40
A.2	Installation precautions	40
A.2.1	General	40
A.2.2	Test leads	40
A.2.3	Guarding of live parts	41
A.2.4	Monitor placement	41
A.2.5	Earthing	42
A.2.6	Interference	42
A.3	Transducers	42
A.3.1	General	42
A.3.2	Signal levels	43
A.3.3	Frequency response of transducers	44
A.3.4	Transducers for measuring transients	44

A.4	Transient voltages and currents	45
A.4.1	General.....	45
A.4.2	Terms and definitions	45
A.4.3	Frequency and amplitude characteristics of a.c. mains transients	45
A.4.4	Transient voltage detection	46
A.4.5	Transient voltage evaluation	47
A.4.6	Effect of surge protective devices on transient measurements	47
A.5	Voltage dip characteristics	47
A.5.1	General.....	47
A.5.2	Rapidly updated r.m.s values	48
A.5.3	Phase angle/point-on-wave.....	48
A.5.4	Voltage dip unbalance	48
A.5.5	Phase shift during voltage dip	49
A.5.6	Missing voltage	49
A.5.7	Distortion during voltage dip	49
A.5.8	Other characteristics and references.....	49
Annex B (informative)	Power quality measurement – Guidance for applications	50
B.1	Contractual applications of power quality measurements	50
B.1.1	General.....	50
B.1.2	General considerations	50
B.1.3	Specific considerations	51
B.2	Statistical survey applications	54
B.2.1	General.....	54
B.2.2	Considerations.....	54
B.2.3	Power quality indices	55
B.2.4	Monitoring objectives	55
B.2.5	Economic aspects of power quality surveys	55
B.3	Locations and types of surveys	56
B.3.1	Monitoring locations	56
B.3.2	Pre-monitoring site surveys.....	57
B.3.3	Customer side site survey.....	57
B.3.4	Network side survey.....	57
B.4	Connections and quantities to measure.....	57
B.4.1	Equipment connection options	57
B.4.2	Priorities: Quantities to measure	58
B.4.3	Current monitoring	59
B.5	Selecting the monitoring thresholds and monitoring period.....	59
B.5.1	Monitoring thresholds	59
B.5.2	Monitoring period	59
B.6	Statistical analysis of the measured data	60
B.6.1	General.....	60
B.6.2	Indices	60
B.7	Trouble-shooting applications	60
B.7.1	General.....	60
B.7.2	Power quality signatures	60
Annex C (informative)	Conducted emissions in the 2 kHz to 150 kHz range	62
C.1	General.....	62
C.2	Measurement method – 2 kHz to 9 kHz	62

C.3	Measurement method – 9kHz to 150 kHz	63
C.4	Measurement range and measurement uncertainty	64
C.5	Aggregation	64
Annex D (informative)	Underdeviation and overdeviation	65
D.1	General.....	65
D.2	Measurement method	65
D.3	Measurement uncertainty and measuring range	65
D.4	Aggregation	65
Annex E (informative)	Class B Measurement Methods	67
E.1	Background for Class B	67
E.2	Class B – Measurement aggregation over time intervals	67
E.3	Class B – Measurement aggregation algorithm	67
E.4	Class B – Real time clock (RTC) uncertainty.....	67
E.4.1	General.....	67
E.4.2	Class B – Frequency – Measurement method	67
E.4.3	Class B – Frequency – Measurement uncertainty.....	67
E.4.4	Class B – Frequency – Measurement evaluation.....	68
E.4.5	Class B – Magnitude of the supply – Measurement method.....	68
E.4.6	Class B – Magnitude of the supply – Measurement uncertainty and measuring range.....	68
E.5	Class B – Flicker.....	68
E.5.1	General.....	68
E.5.2	Class B – Supply voltage dips and swells – Measurement method	68
E.6	Class B – Voltage interruptions	68
E.6.1	General.....	68
E.6.2	Class B – Supply voltage unbalance – Measurement method	68
E.6.3	Class B – Supply voltage unbalance –Uncertainty.....	68
E.6.4	Class B – Voltage harmonics – Measurement method.....	68
E.6.5	Class B –Voltage harmonics – Measurement uncertainty and range.....	68
E.6.6	Class B – Voltage interharmonics – Measurement method	69
E.6.7	Class B –Voltage interharmonics – Measurement uncertainty and range.....	69
E.6.8	Class B – Mains signalling voltage – Measurement method	69
E.6.9	Class B –Mains signalling voltage – Measurement uncertainty and range.....	69
E.6.10	Class B – Current – Measurement method	69
E.6.11	Class B – Current – Measurement uncertainty and range.....	69
Bibliography.....		70
Figure 1 – Measurement chain.....		17
Figure 2 – Synchronization of aggregation intervals for Class A		19
Figure 3 – Synchronization of aggregation intervals for Class S: parameters for which gaps are not permitted		20
Figure 4 – Synchronization of aggregation intervals for Class S: parameters for which gaps are permitted (see 4.5.2)		20
Figure 5 – Example of supply voltage unbalance uncertainty		28
Figure 6 – RVC event: example of a change in r.m.s voltage that results in an RVC event		34

Figure 7 – Not an RVC event: example of a change in r.m.s voltage that does not result in an RVC event because the dip threshold is exceeded 35

Figure A.1 – Frequency spectrum of typical representative transient test waveforms 46

Table 1 – Summary of requirements (see subclauses for actual requirements) 38

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61000-4-30:2015](https://standards.iteh.ai/catalog/standards/sist/a4cb1e5e-edc1-4b6b-ab91-e45c6fab264e/iec-61000-4-30-2015)

<https://standards.iteh.ai/catalog/standards/sist/a4cb1e5e-edc1-4b6b-ab91-e45c6fab264e/iec-61000-4-30-2015>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-30: Testing and measurement techniques – Power quality measurement methods

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61000 4-30 edition 3.1 contains the third edition (2015-02) [documents 77A/873/FDIS and 77A/878/RVD] and its corrigendum (2016-12), and its amendment 1 (2021-03) [documents 77A/1080/CDV and 77A/1092/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61000-4-30 has been prepared by subcommittee 77A: EMC – Low-frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility.

This standard forms part 4-30 of IEC 61000. It has the status of a basic EMC publication in accordance with IEC Guide 107.

This third edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the measurement method for current, previously informative, is now normative with some changes;
- b) the measurement method for RVC (rapid voltage change) has been added;
- c) the measurement method for conducted emissions in the 2 kHz to 150 kHz range has been added in informative Annex C;
- d) underdeviation and overdeviation parameters are moved to informative Annex D;
- e) Class A and Class S measurement methods are defined and clarified, while Class B is moved to informative Annex E and considered for future removal;
- f) measurement methods continue in this standard, but responsibility for influence quantities, performance, and test procedures are transferred to IEC 62586-2.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

IEC 61000-4-30:2015

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)
Definitions, terminology

Part 2: Environment

Description of the environment
Classification of the environment
Compatibility levels

Part 3: Limits

Emission limits
Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques
Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines
Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards or as Technical Specifications or Technical Reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and completed by a second number identifying the subdivision (example: 61000-6-1).

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-30: Testing and measurement techniques – Power quality measurement methods

1 Scope

This part of IEC 61000-4 defines the methods for measurement and interpretation of results for power quality parameters in a.c. power supply systems with a declared fundamental frequency of 50 Hz or 60 Hz.

Measurement methods are described for each relevant parameter in terms that give reliable and repeatable results, regardless of the method's implementation. This standard addresses measurement methods for in-situ measurements.

Measurement of parameters covered by this standard is limited to conducted phenomena in power systems. The power quality parameters considered in this standard are power frequency, magnitude of the supply voltage, flicker, supply voltage dips and swells, voltage interruptions, transient voltages, supply voltage unbalance, voltage harmonics and interharmonics, mains signalling on the supply voltage, rapid voltage changes, and current measurements. Emissions in the 2 kHz to 150 kHz range are considered in Annex C (informative), and over- and underdeviations are considered in Annex D (informative). Depending on the purpose of the measurement, all or a subset of the phenomena on this list may be measured.

NOTE 1 Test methods for verifying compliance with this standard can be found in IEC 62586-2.

NOTE 2 The effects of transducers inserted between the power system and the instrument are acknowledged but not addressed in detail in this standard. Guidance about effects of transducers can be found IEC TR 61869-103.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050 (all parts), *International Electrotechnical Vocabulary (IEV)* (available at www.electropedia.org)

IEC 61000-2-4, *Electromagnetic compatibility (EMC) – Part 2-4: Environment – Compatibility levels in industrial plants for low-frequency conducted disturbances*

IEC 61000-3-8, *Electromagnetic compatibility (EMC) – Part 3: Limits – Section 8: Signalling on low-voltage electrical installations – Emission levels, frequency bands and electromagnetic disturbance levels*

IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*
IEC 61000-4-7:2002/AMD1:2008

IEC 61000-4-15:2010, *Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-161, as well as the following apply.

3.1

channel

individual measurement path through an instrument

Note 1 to entry: “Channel” and “phase” are not the same. A voltage channel is by definition the difference in potential between 2 conductors. Phase refers to a single conductor. On polyphase systems, a channel may be between 2 phases, or between a phase and neutral, or between a phase and earth, or between neutral and earth.

3.2

declared input voltage

U_{din}

value obtained from the declared supply voltage by a transducer ratio

3.3

declared supply voltage

U_{c}

normally the nominal voltage U_{n} of the system.

Note 1 to entry: If by agreement between the supplier and the customer a voltage different from the nominal voltage is applied to the terminals, then this voltage is the declared supply voltage U_{c} .

3.4

dip threshold

voltage magnitude specified for the purpose of detecting the start and the end of a voltage dip

3.5

flagged data

for any measurement time interval in which interruptions, dips or swells occur, the marked measurement results of all other parameters made during this time interval

Note 1 to entry: For some applications, this ‘marked’ or ‘flagged’ data may be excluded from further analysis, for example. See 4.7 for further explanation.

3.6

flicker

impression of unsteadiness of visual sensation induced by a light stimulus whose luminance or spectral distribution fluctuates with time

[SOURCE: IEC 60050-161:1990, 161-08-13]

3.6.1

P_{st}

short-term flicker evaluation based on an observation period of 10 min

[SOURCE: IEC 61000-4-15]