

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electrical accessories – Circuit-breakers for overcurrent protection
for household and similar installations –
Part 1: Circuit-breakers for a.c. operation**

**Petit appareillage électrique – Disjoncteurs pour la protection
contre les surintensités pour installations domestiques et analogues –
Partie 1: Disjoncteurs pour le fonctionnement en courant alternatif**

<https://standards.iteh.ai/catalog/standards/iec/3e342d5e-f37e-4088-98c8-8066907010b7/iec-60898-1-2015>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



IEC 60898-1

Edition 2.1 2019-12
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electrical accessories – Circuit-breakers for overcurrent protection
for household and similar installations –
Part 1: Circuit-breakers for a.c. operation**

**Petit appareillage électrique – Disjoncteurs pour la protection
contre les surintensités pour installations domestiques et analogues –
Partie 1: Disjoncteurs pour le fonctionnement en courant alternatif**

<https://standards.iteh.ai/catalog/standards/iec/3e342d5e-f37e-4088-98c8-8066907010b7/iec-60898-1-2015>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-8322-7736-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**Electrical accessories – Circuit-breakers for overcurrent protection
for household and similar installations –
Part 1: Circuit-breakers for a.c. operation**

**Petit appareillage électrique – Disjoncteurs pour la protection
contre les surintensités pour installations domestiques et analogues –
Partie 1: Disjoncteurs pour le fonctionnement en courant alternatif**

<https://standards.iteh.ai/catalog/standards/iec/3e342d5e-f37e-4088-98c8-8066907010b7/iec-60898-1-2015>

CONTENTS

FOREWORD	8
1 Scope	10
2 Normative references	11
3 Terms and definitions	12
3.1 Devices	12
3.2 General terms	13
3.3 Constructional elements	15
3.4 Conditions of operation	18
3.5 Characteristic quantities	18
3.6 Definitions related to insulation co-ordination	23
4 Classification	25
4.1 General	25
4.2 According to the number of poles:	25
4.3 According to the protection against external influences:	25
4.4 According to the method of mounting:	25
4.5 According to the methods of connection	25
4.5.1 According to the fixation system:	25
4.5.2 According to the type of terminals:	26
4.6 According to the instantaneous tripping current (see 3.5.17)	26
4.7 According to the I^2t characteristic	26
5 Characteristics of circuit-breakers	26
5.1 List of characteristics	26
5.2 Rated quantities	27
5.2.1 Rated voltages	27
5.2.2 Rated current (I_n)	27
5.2.3 Rated frequency	27
5.2.4 Rated short-circuit capacity (I_{cn})	27
5.3 Standard and preferred values	28
5.3.1 Preferred values of rated voltage	28
5.3.2 Preferred values of rated current	28
5.3.3 Standard values of rated frequency	28
5.3.4 Values of rated short-circuit capacity	29
5.3.5 Standard ranges of instantaneous tripping	29
5.3.6 Standard values of rated impulse withstand voltage (U_{imp})	29
6 Marking and other product information	30
7 Standard conditions for operation in service	32
7.1 General	32
7.2 Ambient air temperature range	32
7.3 Altitude	32
7.4 Atmospheric conditions	32
7.5 Conditions of installation	32
7.6 Pollution degree	32
8 Requirements for construction and operation	32
8.1 Mechanical design	32
8.1.1 General	32

8.1.2	Mechanism	33
8.1.3	Clearances and creepage distances and solid insulation (see Annex B)	34
8.1.4	Screws, current-carrying parts and connections	40
8.1.5	Terminals for external conductors	40
8.1.6	Non-interchangeability	43
8.1.7	Mechanical mounting of plug-in type circuit-breakers	43
8.2	Protection against electric shock	43
8.3	Dielectric properties and isolating capability	44
8.3.1	General	44
8.3.2	Dielectric strength at power frequency	44
8.3.3	Isolating capability	44
8.3.4	Dielectric strength at rated impulse withstand voltage (U_{imp})	44
8.4	Temperature-rise	44
8.4.1	Temperature-rise limits	44
8.4.2	Ambient air temperature	45
8.5	Uninterrupted duty	45
8.6	Automatic operation	45
8.6.1	Standard time-current zone	45
8.6.2	Conventional quantities	46
8.6.3	Tripping characteristic	46
8.7	Mechanical and electrical endurance	47
8.8	Performance at short-circuit currents	47
8.9	Resistance to mechanical shock and impact	47
8.10	Resistance to heat	48
8.11	Resistance to abnormal heat and to fire	48
8.12	Resistance to rusting	48
8.13	Power loss	48
8.14	Electromagnetic immunity	48
8.15	Electromagnetic emission	48
9	Tests	49
9.1	Type tests and test sequences	49
9.2	Test conditions	49
9.3	Test of indelibility of marking	50
9.4	Test of reliability of screws, current-carrying parts and connections	51
9.5	Tests of reliability of screw-type terminals for external copper conductors	52
9.6	Test of protection against electric shock	54
9.7	Test of dielectric properties	54
9.7.1	Resistance to humidity	60
9.7.2	Insulation resistance of the main circuit	61
9.7.3	Dielectric strength of the main circuit	61
9.7.4	Insulation resistance and dielectric strength of auxiliary circuits	62
9.7.5	Verification of impulse withstand voltages (across clearances and across solid insulation) and of leakage current across open contacts	63
9.8	Test of temperature-rise and measurement of power loss	66
9.8.1	Ambient air temperature	66
9.8.2	Test procedure	66
9.8.3	Measurement of the temperature of parts	66
9.8.4	Temperature-rise of a part	66
9.8.5	Measurement of power loss	66

9.9	28-day test.....	67
9.10	Test of tripping characteristic.....	67
9.10.1	General.....	67
9.10.2	Test of time-current characteristic.....	67
9.10.3	Test of instantaneous tripping, of correct opening of the contacts and of the trip-free function.....	68
9.10.4	Test of effect of single-pole loading on the tripping characteristic of multipole circuit-breakers.....	69
9.10.5	Test of effect of ambient temperature on the tripping characteristic.....	69
9.11	Verification of mechanical and electrical endurance.....	69
9.11.1	General test conditions.....	69
9.11.2	Test procedure.....	70
9.11.3	Condition of the circuit-breaker after test.....	70
9.12	Short-circuit tests.....	70
9.12.1	General.....	70
9.12.2	Values of test quantities.....	71
9.12.3	Tolerances on test quantities.....	72
9.12.4	Test circuit for short-circuit performance.....	72
9.12.5	Power factor of the test circuit.....	73
9.12.6	Measurement and verification of I^2t and of the peak current (I_p).....	73
9.12.7	Calibration of the test circuit.....	73
9.12.8	Interpretation of records.....	74
9.12.9	Condition of the circuit-breaker for test.....	74
9.12.10	Behaviour of the circuit-breaker during short-circuit tests.....	75
9.12.11	Test procedure.....	76
9.12.12	Verification of the circuit breaker after short circuit tests.....	81
9.13	Mechanical stresses.....	81
9.13.1	Mechanical shock.....	81
9.13.2	Resistance to mechanical stresses and impact.....	82
9.14	Test of resistance to heat.....	85
9.15	Resistance to abnormal heat and to fire.....	86
9.16	Test of resistance to rusting.....	87
Annex A (informative)	Determination of short-circuit power factor.....	102
Annex B (normative)	Determination of clearances and creepage distances.....	103
Annex C (normative)	Test sequences and number of samples.....	108
Annex D (informative)	Co-ordination under short-circuit conditions between a circuit-breaker and another short-circuit protective device (SCPD) associated in the same circuit.....	114
Annex E (normative)	Special requirements for auxiliary circuits for safety extra-low voltage.....	121
Annex F (informative)	Examples of terminals.....	122
Annex G (informative)	Correspondence between ISO and AWG copper conductors.....	125
Annex H (normative)	Arrangement for short-circuit test.....	126
Annex I (normative)	Routine tests.....	129
Annex J (normative)	Particular requirements for circuit-breakers with screwless-type terminals for external copper conductors.....	130
Annex K (normative)	Particular requirements for circuit-breakers with flat quick-connect terminations.....	147

Annex L (normative) Specific requirements for circuit-breakers with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors 154

Bibliography 164

Figure 1 – Thread forming tapping screw (3.3.22) 88

Figure 2 – Thread cutting tapping screw (3.3.23) 88

Figure 3 – Typical diagram for all short circuit tests except for 9.12.11.2.2) 88

Figure 4 – Typical diagram for short circuit tests according to 9.12.11.2.2) 89

Figure 5 – Detail of impedance Z and Z_1 89

Figure 6 – Example of short-circuit making or breaking test record in the case of a single-pole device on single phase ~~a-c~~ AC 92

Figure 7 – Mechanical shock test apparatus (9.13.1) 93

Figure 8 – Standard test finger (9.6) 94

Figure 9 – Mechanical impact test apparatus (9.13.2) 95

Figure 10 – Striking element for pendulum for mechanical impact test apparatus (9.13.2) 96

Figure 11 – Mounting support for mechanical impact test (9.13.2) 97

Figure 12 – Example of mounting ~~for a rear fixed~~ of a flush-type circuit-breaker for mechanical impact test (9.13.2) 98

Figure 13 – Example of mounting of a panel board type circuit-breaker for mechanical impact test (9.13.2) 99

Figure 14 – Application of force for mechanical test on a rail-mounted circuit-breaker (9.13.2.4) 100

Figure 15 – Ball-pressure test apparatus 100

Figure 16 – Example of application of force for mechanical test on two-pole plug-in circuit-breaker, the holding in position of which depends solely on the plug-in connections (9.13.2.5) 101

Figure 17 – Diagrammatic representation (9.15) 101

Figure B.1 – Examples of methods of measuring creepage distances and clearances 107

Figure D.1 – Overcurrent co-ordination between a circuit-breaker and a fuse or back-up protection by a fuse – Operating characteristics 119

Figure D.2 – Total selectivity between two circuit-breakers 119

Figure D.3 – Back-up protection by a circuit-breaker – Operating characteristics 120

Figure F.1 – Examples of pillar terminals 122

Figure F.2 – Examples of screw terminals and stud terminals 123

Figure F.3 – Examples of saddle terminals 124

Figure F.4 – Examples of lug terminals 124

Figure H.1 – ~~Example of~~ test arrangement 127

Figure H.2 – Grid circuit 127

Figure H.3 – Grid circuit 128

Figure J.1 – ~~Connecting samples~~ Example of test set-up 144

Figure J.2 – Examples of screwless-type terminals 145

Figure K.1 – Example of position of the thermocouple for measurement of the temperature-rise 150

Figure K.2 – Dimensions of male tabs 151

Figure K.3 – Dimensions of round dimple detents (see Figure K.2)	152
Figure K.4 – Dimensions of rectangular dimple detents (see Figure K.2).....	152
Figure K.5 – Dimensions of hole detents	153
Figure K.6 – Dimensions of female connectors	153
Figure L.1 – General arrangement for the test.....	162
Figure L.2	162
Figure L.3	163
Figure L.4	163
Figure L.5	163
Figure L.6	163
Table 1 – Preferred values of rated voltage.....	28
Table 2 – Ranges of instantaneous tripping	29
Table 3 – Rated impulse withstand voltage as a function of the nominal voltage of the installation	30
Table 4 – Minimum clearances and creepage distances.....	38
Table 5 – Connectable cross-sections of copper conductors for screw-type terminals	41
Table 6 – Temperature-rise values.....	45
Table 7 – Time-current operating characteristics.....	46
Table 8 – Maximum power loss per pole	48
Table 9 – List of type tests.....	49
Table 10 – Cross-sectional areas (S) of test copper conductors corresponding to the rated currents	50
Table 11 – Screw thread diameters and applied torques	52
Table 12 – Pulling forces	53
Table 13 – Test voltage of auxiliary circuits	63
Table 14 – Test voltage for verification of impulse withstand voltage	65
Table 15 – Test voltage for verifying the suitability for isolation, referred to the rated impulse withstand voltage of the circuit breakers and the altitude where the test is carried out	65
Table 16 – Applicability of short-circuit tests	71
Table 17 – Power factor ranges of the test circuit	73
Table 18 – Ratio k between service short-circuit capacity (I_{CS}) and rated short-circuit capacity (I_{CN}).....	78
Table 19 – Test procedure for I_{CS} in the case of single- and two-pole circuit-breakers	78
Table 20 – Test procedure for I_{CS} in the case of three- and four-pole circuit-breakers.....	79
Table 21 – Test procedure for I_{CS} in the case of three-phase tests for single-pole circuit-breakers of rated voltage 230/400 V.....	79
Table 22 – The test procedure for I_{CN}	80
Table 23 – Test procedure for I_{CN} in the case of three-phase tests for single-pole circuit-breakers of rated voltage 230/400 V	80
Table C.1 – Test sequences	109
Table C.2 – Number of samples for full test procedure.....	110
Table C.3 – Reduction of samples for series of circuit-breakers having different numbers of poles	112

Table C.4 – Test sequences for a series of circuit-breakers being of different instantaneous tripping classifications	113
Table J.1 – Connectable Conductors and their theoretical diameters	141
Table J.2 – Cross-sections of copper conductors connectable to screwless-type terminals.....	141
Table J.3 – Pull forces	143
Table K.1 – Informative table on colour code of female connectors in relationship with the cross section of the conductor.....	148
Table K.2 – Overload test forces	149
Table K.3 – Dimensions of tabs	150
Table K.4 – Dimensions of female connectors.....	153
Table L.1 – Marking for terminals.....	155
Table L.2 – Connectable cross-sections of aluminium conductors for screw-type terminals.....	156
Table L.3 – List of tests according to the material of conductors and terminals	157
Table L.4 – Connectable conductors and their theoretical diameters.....	157
Table L.5 – Cross sections (<i>S</i>) of aluminium test conductors corresponding to the rated currents	158
Table L.6 – Test conductor length.....	159
Table L.7 – Equalizer and busbar dimensions.....	159
Table L.8 – Test current as a function of rated current.....	161
Table L.9 – Example of calculation for determining the average temperature deviation <i>D</i>	161

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL ACCESSORIES –
CIRCUIT-BREAKERS FOR OVERCURRENT PROTECTION
FOR HOUSEHOLD AND SIMILAR INSTALLATIONS –****Part 1: Circuit-breakers for a.c. operation**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60898-1 edition 2.1 contains the second edition (2015-03) [documents 23E/881/FDIS and 23E/894/RVD] and its corrigendum (2015-11), its amendment 1 (2019-12) [documents 23E/1156/FDIS and 23E/1157/RVD] and its corrigendum (2020-03). The contents of the corrigendum of the amendment only applies to the French version.

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60898-1 has been prepared by sub-committee 23E: Circuit-breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories.

This second edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of 9.5 Terminals
- b) Revision of the test of glow wire
- c) Simplification of the figures for short circuit tests.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The following differing practices of a less permanent nature exist in the countries indicated below.

- Annex J, Clause J.1: Upper limit of current for use of screwless terminals is 16 A (CZ, DK, NL and CH; upper limit of current for use of screwless terminals is 30 A (Japan).
- J.3.3: Only universal screwless-type terminals are accepted (AT, BE, CN, DK, DE, ES, FR, IT, PT, SE and CH).

In this standard, the following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Explanatory matter: in smaller roman type.

A list of all parts in the IEC 60898 series, published under the general title *Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

ELECTRICAL ACCESSORIES – CIRCUIT-BREAKERS FOR OVERCURRENT PROTECTION FOR HOUSEHOLD AND SIMILAR INSTALLATIONS –

Part 1: Circuit-breakers for a.c. operation

1 Scope

This part of IEC 60898 applies to a.c. air-break circuit-breakers for operation at 50 Hz, 60 Hz or 50/60 Hz, having a rated voltage not exceeding 440 V (between phases), a rated current not exceeding 125 A and a rated short-circuit capacity not exceeding 25 000 A.

As far as possible, it is in line with the requirements contained in IEC 60947-2.

NOTE 1 Additional requirements are necessary for circuit-breakers used in locations having more severe overvoltage conditions.

These circuit-breakers are intended for the protection against overcurrents of wiring installations of buildings and similar applications; they are designed for use by uninstructed people and ~~for not being maintained~~ do not require maintenance.

They are intended for use in an environment with pollution degree 2 and overvoltage category III.

For an environment with a higher pollution degree, enclosures giving the appropriate degree of protection are used.

They are suitable for isolation.

[IEC 60898-1:2015](https://standards.iteh.ai/catalog/standards/iec/3e342d5e-f37e-4088-98c8-8066907010b7/iec-60898-1-2015)

Circuit-breakers of this standard, with exception of those rated 120 V or 120/240 V (see Table 1), are suitable for use in IT systems.

This standard also applies to circuit-breakers having more than one rated current, provided that the means for changing from one discrete rating to another is not accessible in normal service and that the rating cannot be changed without the use of a tool.

This standard does not apply to

- circuit-breakers intended to protect motors;
- circuit-breakers, the current setting of which is adjustable by means accessible to the user.

For circuit-breakers having a degree of protection higher than IP20 according to IEC 60529, for use in locations where arduous environmental conditions prevail (e.g. excessive humidity, heat or cold or deposition of dust) and in hazardous locations (e.g. where explosions are liable to occur), special constructions may be required.

This standard does not apply to circuit-breakers for a.c. and d.c. operation, which is covered by IEC 60898-2.