

TECHNICAL REPORT

RAPPORT TECHNIQUE

A method of temperature-rise verification of low-voltage switchgear and controlgear assemblies by calculation

Méthode de vérification par calcul des échauffements pour les ensembles d'appareillage à basse tension

IEC TR 60890:2014
<https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

TECHNICAL REPORT

RAPPORT TECHNIQUE

A method of temperature-rise verification of low-voltage switchgear and controlgear assemblies by calculation

Méthode de vérification par calcul des échauffements pour les ensembles d'appareillage à basse tension

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 29.130.20

ISBN 978-2-8322-1566-1

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Conditions for application	7
5 Calculation	8
5.1 Necessary information	8
5.2 Calculation procedure	8
5.2.1 General	8
5.2.2 Determination of the effective cooling surface A_e of the enclosure	8
5.2.3 Determination of the internal temperature rise $\Delta t_{0,5}$ of the air at mid-height of the enclosure	8
5.2.4 Determination of the internal temperature rise $\Delta t_{1,0}$ of air at the top of the enclosure	9
5.2.5 Characteristic curve for temperature rise of air inside enclosure	9
6 Evaluation of the design	11
Annex A (informative) Examples for the calculation of the temperature-rise of air inside the enclosures	20
A.1 Example 1	20
A.2 Example 2	23
Annex B (informative) Operating current and power losses of conductors	27
Bibliography.....	32
Figure 1 – Temperature-rise characteristic curve for enclosures with A_e exceeding 1,25 m ²	10
Figure 2 – Temperature-rise characteristic curve for enclosures with A_e not exceeding 1,25 m ²	10
Figure 3 – Enclosure constant k for enclosures without ventilation openings, with an effective cooling surface $A_e > 1,25$ m ²	13
Figure 4 – Temperature distribution factor c for enclosures without ventilation openings and with an effective cooling surface $A_e > 1,25$ m ²	14
Figure 5 – Enclosure constant k for enclosures with ventilation openings and an effective cooling surface $A_e > 1,25$ m ²	15
Figure 6 – Temperature distribution factor c for enclosures with ventilation openings and an effective cooling surface $A_e > 1,25$ m ²	16
Figure 7 – Enclosure constant k for enclosures without ventilation openings and with an effective cooling surface $A_e \leq 1,25$ m ²	17
Figure 8 – Temperature distribution factor c for enclosures without ventilation openings and with an effective cooling surface $A_e \leq 1,25$ m ²	18
Figure 9 – Calculation of temperature rise of air inside enclosures.....	19
Figure A.1 – Example 1, calculation for an enclosure with exposed side faces without ventilation openings and without internal horizontal partitions	20
Figure A.2 – Example 1, calculation for a single enclosure.....	22
Figure A.3 – Example 2, calculation for an enclosure for wall-mounting with ventilation openings.....	23

Figure A.4 – Example 2, calculation for one enclosure half	24
Figure A.5 – Example 2, calculation for an enclosure for wall-mounting with ventilation openings	26
Table 1 – Method of calculation, application, formulae and characteristics	11
Table 2 – Symbols, units and designations	12
Table 3 – Surface factor b according to the type of installation	12
Table 4 – Factor d for enclosures without ventilation openings and with an effective cooling surface $A_e > 1,25 \text{ m}^2$	12
Table 5 – Factor d for enclosures with ventilation openings and an effective cooling surface $A_e > 1,25 \text{ m}^2$	12
Table B.1 – Operating current and power loss of single-core copper cables with a permissible conductor temperature of 70 °C (ambient temperature inside the enclosure: 55 °C)	28
Table B.2 – Reduction factor k_1 for cables with a permissible conductor temperature of 70 °C (extract from IEC 60364-5-52:2009, Table B.52-14)	29
Table B.3 – Operating current and power loss of bare copper bars with rectangular cross-section, run horizontally and arranged with their largest face vertical (ambient temperature inside the enclosure: 55 °C, temperature of the conductor 70 °C)	30
Table B.4 – Factor k_4 for different temperatures of the air inside the enclosure and/or for the conductors	31

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC TR 60890:2014

<https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

A METHOD OF TEMPERATURE-RISE VERIFICATION OF LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES BY CALCULATION

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 60890, which is a technical report, has been prepared by subcommittee 17D: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition published in 1987 and its Amendment 1:1995. It constitutes a technical revision.

This edition includes the following significant technical changes with respect to the last edition:

- alignment with IEC 61439-1:2011;
- revision of Annex B;
- general editorial review.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
17D/490/DTR	17D/499/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC TR 60890:2014](https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014)

<https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014>

INTRODUCTION

In IEC 61439-1, in the series of design verifications, a temperature-rise verification of low-voltage power switchgear and controlgear assemblies (hereafter called ASSEMBLIES) is specified. This may be by test, however, alternatives are acceptable in defined circumstances. Selection of the method used for temperature rise verification is the responsibility of the original manufacturer. Where applicable this technical report may also be used for temperature rise verification of similar products in accordance with other standards. The factors and coefficients, set out in this report have been derived from measurements on numerous ASSEMBLIES and the method has been verified by comparison with test results.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC TR 60890:2014](https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014)

<https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6fc6093ecc/iec-tr-60890-2014>

A METHOD OF TEMPERATURE-RISE VERIFICATION OF LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES BY CALCULATION

1 Scope

This Technical Report specifies a method of temperature-rise verification of low-voltage switchgear and controlgear ASSEMBLIES by calculation.

The method is applicable to enclosed ASSEMBLIES or partitioned sections of ASSEMBLIES without forced ventilation. It is not applicable where temperature rise verification to the relevant product standard of the IEC 61439 series has been established

NOTE 1 The influence of the materials and wall thicknesses usually used for enclosures can have some effect on the steady state temperatures. However, the generalised approach used in this technical report ensures it is applicable to enclosures made of sheet steel, sheet aluminium, cast iron, insulating material and the like.

The proposed method is intended to determine the temperature rise of the air inside the enclosure.

NOTE 2 The air temperature within the enclosure is equal to the ambient air temperature outside the enclosure plus the temperature rise of the air inside the enclosure caused by the power losses of the installed equipment.

Unless otherwise specified, the ambient air temperature outside the ASSEMBLY is the air temperature indicated for the installation (average value over 24 h) of 35 °C. If the ambient air temperature outside the ASSEMBLY at the place of use exceeds 35 °C, this higher temperature is deemed to be the ambient air temperature.

2 Normative references

[IEC TR 60890:2014](https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6f6093eac/iec-tr-60890-2014)

[https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-](https://standards.iteh.ai/catalog/standards/sist/0b6f9b6a-46ac-4733-97a7-9e6f6093eac/iec-tr-60890-2014)

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61439-1:2011, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61439-1 apply.

4 Conditions for application

This method of calculation is only applicable if the following conditions are fulfilled:

- the power loss data for all built in components is available;
- there is an approximately even distribution of power losses inside the enclosure;
- the installed equipment is so arranged that air circulation is not significantly impeded;
- the equipment installed is designed for direct current or alternating current up to and including 60 Hz with the total of supply currents not exceeding 3 150 A;
- conductors carrying currents in excess of 200 A, and the adjacent structural parts are so arranged that eddy-current and hysteresis losses are minimised;
- for enclosures with natural ventilation, the cross-section of the air outlet openings is at least 1,1 times the cross-section of the air inlet openings;

- there are no more than three horizontal partitions in the ASSEMBLY or in a section of it;
- where enclosures with external ventilation openings have compartments, the surface of the ventilation openings in each horizontal partition shall be at least 50 % of the horizontal cross-section of the compartment.

5 Calculation

5.1 Necessary information

The following data is needed to calculate the temperature rise of the air inside an enclosure:

- dimensions of the enclosure: height/width/depth;
- the type of installation of the enclosure according to Figure 4;
- design of enclosure, i.e. with or without ventilation openings;
- number of internal horizontal partitions;
- effective power loss of equipment installed in the enclosure;
- effective power losses (P_V) of conductors according to Annex B.

NOTE The effective power losses of the equipment installed in the circuits of the ASSEMBLY used for this calculation are the power losses at the rated currents of the various circuits.

5.2 Calculation procedure

5.2.1 General

For the enclosures specified in columns 4 and 5 of Table 1, the calculation of the temperature rise of the air inside the enclosures is carried out using the formulae laid down in columns 1 to 3 of Table 1.

The pertinent factors and exponents (characteristics) are obtained from columns 6 to 10 of Table 1.

The symbols, units and designations are to be taken from Table 2.

For enclosures having more than one section with vertical partitions the temperature rise of the air inside the enclosure shall be determined separately for each section.

Where enclosures without vertical partitions or individual sections have an effective cooling surface greater than 11,5 m² or a width greater than about 1,5 m, they should be divided for the calculation into fictitious sections, whose dimensions approximate to the foregoing values.

NOTE The form (see Figure 9) can be used as a calculation aid.

5.2.2 Determination of the effective cooling surface A_e of the enclosure

The calculation is carried out according to Formula (1) in column 1 of Table 1.

The effective cooling surface A_e of an enclosure is the sum of the individual surfaces A_o multiplied by the surface factor b . This factor takes into account the heat dissipation of the individual surfaces according to the type of installation of the enclosure.

5.2.3 Determination of the internal temperature rise $\Delta t_{0,5}$ of the air at mid-height of the enclosure

The calculation is carried out according to Formula (2) in column 2 of Table 1.

In Formula (2) the enclosure constant k allows for the size of the effective cooling surface for enclosures without ventilation openings and, in addition, for the cross-section of the air inlet openings for enclosures with ventilation openings.

The dependence of the temperature rises occurring in the enclosure on the effective power loss P is expressed by the exponent x .

The factor d allows for the dependence of the temperature rise on the number of internal horizontal partitions.

5.2.4 Determination of the internal temperature rise $\Delta t_{1,0}$ of air at the top of the enclosure

The calculation is made according to Formula (3) in column 3 of Table 1.

Factor c allows for the temperature distribution inside an enclosure. Its determination varies with the design and installation of the ASSEMBLY as follows:

- a) For enclosures without ventilation openings and with an effective cooling surface: The factor c from Figure 4, depends on the type of installation and the height/base factor f , where:

$$A_e > 1,25 \text{ m}^2 \quad f = \frac{h^{1,35}}{A_b}$$

- b) For enclosures with ventilation openings and with an effective cooling surface: The factor c from Figure 6, depends on the cross-section of air inlet openings and the height/base factor f , where:

$$A_e > 1,25 \text{ m}^2 \quad f = \frac{h^{1,35}}{A_b}$$

- c) For enclosures without ventilation openings and with an effective cooling surface: The factor c from Figure 8, depends on the height/width factor g , where:

$$A_e \leq 1,25 \text{ m}^2 \quad g = \frac{h}{w}$$

where

h is the enclosure height, in m;

A_b is the surface area of the enclosure base, in m²;

w is the enclosure width, in m.

5.2.5 Characteristic curve for temperature rise of air inside enclosure


5.2.5.1 General

To evaluate the design according to Clause 6, it is necessary to apply the calculated results of 5.2.3 and 5.2.4 with the proper characteristic curve for temperature rise of air inside the enclosure as a function of the enclosure height. The air temperatures within horizontal levels are practically constant.

5.2.5.2 Temperature-rise characteristic curve for enclosures with an effective cooling surface A_e exceeding 1,25 m²

As a general rule, the characteristic curve of temperature rise is adequately well defined by a straight line which runs through the points $\Delta t_{1,0}$ and $\Delta t_{0,5}$ (see Figure 1).

The internal air temperature rise at the bottom of the enclosure is close to zero, i.e. the characteristic curve flattens out towards zero. In practice, the dotted part of the characteristic curve is of secondary importance.



IEC 1428/14


Figure 1 – Temperature-rise characteristic curve for enclosures with A_e exceeding 1,25 m²

5.2.5.3 Temperature rise characteristic curve for enclosures with an effective cooling surface A_e not exceeding 1,25 m²

For this type of enclosure, the maximum temperature rise in the upper quarter is constant and the values for $\Delta t_{1,0}$ and $\Delta t_{0,75}$ are identical (see Figure 2).

The characteristic curve is obtained by connecting the temperature-rise values at an enclosure level of 0,75 and 0,5 (see Figure 2).

The internal air temperature rise at the bottom of the enclosure is close to zero, i.e. the characteristic curve flattens out towards zero. In practice, the dotted part of the characteristic curve is of secondary importance.



IEC 1429/14

Figure 2 – Temperature-rise characteristic curve for enclosures with A_e not exceeding 1,25 m²

6 Evaluation of the design

It shall be determined whether the equipment within the ASSEMBLY can operate satisfactorily at the relevant calculated temperature rise.

If it is not so, the parameters will have to be changed and the calculation repeated.

iteh
STANDARD PREVIEW
(standards.iteh.ai)

Table 1 – Method of calculation, application, formulae and characteristics

1	2	3	4	5	6	7	8	9	10	11	
Calculation formulae					Enclosure					Characteristic curve	
Effective cooling surface A_e	Temperature rise of air		Effective cooling surface A_e	Enclosure without ventilation openings	Factors	Exponent	Plotting of temperature-rise characteristics				
	At mid-height of the enclosure	At (internal) top of enclosure									
$A_e = \Sigma (A_o \times b)$ (1)	$\Delta t_{0,5} = k \times d \times P^x$ (2)	$\Delta t_{1,0} = c \times \Delta t_{0,5}$ (3)	>1,25 m ²	Enclosure without ventilation openings	Figure 3	Table 4	Figure 4	0,804	See 5.2.5.2		
				Enclosure with ventilation openings	Figure 5	Table 5	Figure 6				
			<1,25 m ²			Enclosure without ventilation openings	Figure 7	–	Figure 8	0,804	See 5.2.5.3

For symbols, units and designations, see Table 2.

Table 2 – Symbols, units and designations

Symbol	Unit	Designation
A_o	m ²	Surfaces of external sides of enclosure
A_b	m ²	Enclosure base surface
A_e	m ²	Effective cooling surface of enclosure
b	–	Surface factor
c	–	Temperature distribution factor
d	–	Temperature-rise factor for internal horizontal partitions inside enclosure
f	–	Height/base factor
g	–	Height/width factor
h	m	Enclosure height
k	–	Enclosure constant
n	–	Number of internal horizontal partitions (up to three partitions)
P	W	Effective power loss of equipment installed inside enclosure
P_v	W	Effective power losses of conductors
w	m	Enclosure width
x	–	Exponent
A_t	K	Temperature rise of air inside enclosure in general
$\Delta t_{0,5}$	K	Temperature rise of air at (internal) mid-height of enclosure
$\Delta t_{0,75}$	K	Temperature rise of air at (internal) 3/4 height of enclosure
$\Delta t_{1,0}$	K	Temperature rise of air at (internal) top of enclosure

IEC TR 60890:2014

Table 3 – Surface factor b according to the type of installation

Type of installation	Surface factor b
Exposed top surface	1,4
Covered top surface, e.g. of built-in enclosures	0,7
Exposed side faces, e.g. front, rear and side walls	0,9
Covered side faces, e.g. rear side of wall-mounted enclosures	0,5
Side faces of central enclosures	0,5
Floor surface	not taken into account
Fictitious side faces of sections (see 5.2) which have been introduced only for calculation purposes are not taken into account	

Table 4 – Factor d for enclosures without ventilation openings and with an effective cooling surface $A_e > 1,25 \text{ m}^2$

Number of horizontal partitions n	0	1	2	3
Factor d	1,00	1,05	1,15	1,30

Table 5 – Factor d for enclosures with ventilation openings and an effective cooling surface $A_e > 1,25 \text{ m}^2$

Number of horizontal partitions n	0	1	2	3
Factor d	1,00	1,05	1,10	1,15




Figure 3 – Enclosure constant k for enclosures without ventilation openings, with an effective cooling surface $A_e > 1,25 \text{ m}^2$