

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Live working – Voltage detectors –
Part 3: Two-pole low-voltage type

STANDARD PREVIEW
(standards.iteh.ai)

Travaux sous tension – Détecteurs de tension –
Partie 3: Type bipolaire basse tension

IEC 61243-3:2014
<https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af4dc2a0f50/iec-61243-3-2014>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 61243-3

Edition 3.0 2014-10

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Live working – Voltage detectors –
Part 3: Two-pole low-voltage type

STANDARD PREVIEW
(standards.iteh.ai)

Travaux sous tension – Détecteurs de tension –
Partie 3: Type bipolaire basse tension

IEC 61243-3:2014
http://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aeed-1af4dc2a0f50/iec-61243-3-2014

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 13.260, 29.240.20, 29.260.99

ISBN 978-2-8322-1882-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	11
4 Requirements	14
4.1 General requirements.....	14
4.1.1 Safety.....	14
4.1.2 Indication.....	15
4.1.3 Electromagnetic compatibility (EMC)	15
4.2 Functional requirements.....	15
4.2.1 Clear indication.....	15
4.2.2 Clear perceptibility	16
4.2.3 Temperature and humidity dependence of the indication	17
4.2.4 Frequency dependency for a.c. voltage detector	17
4.2.5 Ripple dependency for d.c. voltage detector	17
4.2.6 Response time.....	17
4.2.7 Power source dependability.....	17
4.2.8 Testing element	18
4.2.9 Time rating	18
4.3 Electrical requirements.....	18
4.3.1 Insulating material.....	18
4.3.2 Protection against electric shocks.....	18
4.3.3 Current limiting elements.....	19
4.3.4 Minimum clearance and creepage distances	19
4.3.5 Protection against electrical stresses.....	21
4.3.6 Lead(s).....	21
4.3.7 Probes.....	22
4.3.8 Connector(s) (if any)	22
4.3.9 Accessible switches in the detecting circuit for temporary loading (if any).....	22
4.4 Mechanical requirements.....	22
4.4.1 Design.....	22
4.4.2 Dimensions, construction	24
4.4.3 Degree of protection provided by enclosures	24
4.4.4 Resistance to vibration.....	24
4.4.5 Drop resistance.....	24
4.4.6 Shock resistance.....	24
4.4.7 Possible disassembling	24
4.4.8 Surface temperature	25
4.4.9 Resistance to heat	25
4.4.10 Probes.....	25
4.4.11 Lead(s).....	25
4.5 Marking.....	25
4.5.1 General	25
4.5.2 Marking on the indicator	25

4.5.3	Marking on the probe and/or the lead	26
4.6	Instructions for use.....	26
4.7	Requirements in case of reasonably foreseeable misuse during live working	27
4.7.1	AC/DC voltage misuse	27
4.7.2	Maximum current to earth in case of misuse	27
4.7.3	Misuse in case of mistaking of the voltage of the low voltage network	28
5	Tests.....	28
5.1	General.....	28
5.2	Tests for general requirements	29
5.2.1	Indication.....	29
5.2.2	Electromagnetic compatibility (EMC)	29
5.3	Tests for functional requirements.....	30
5.3.1	Clear indication.....	30
5.3.2	Clear perceptibility of visual indication	33
5.3.3	Clear perceptibility of audible indication (when available).....	35
5.3.4	Temperature and humidity dependence of the indication	37
5.3.5	Frequency dependency for a.c. voltage detector	38
5.3.6	Ripple dependency for d.c. voltage detector	39
5.3.7	Response time	39
5.3.8	Power source dependability.....	40
5.3.9	Testing element	40
5.3.10	Time rating	40
5.4	Tests for electrical requirements.....	41
5.4.1	Tests on the insulation	41
5.4.2	Protection against electric shocks.....	42
5.4.3	Current limiting elements.....	43
5.4.4	Minimum clearance and creepage distances	43
5.4.5	Protection against electrical stresses.....	43
5.4.6	Lead(s)	44
5.4.7	Probe(s)	44
5.4.8	Connector(s).....	44
5.4.9	Switches for temporary loading (if any).....	44
5.5	Tests for mechanical requirements	45
5.5.1	Design	45
5.5.2	Dimensions, construction	45
5.5.3	Degree of protection provided by enclosures	45
5.5.4	Vibration resistance	45
5.5.5	Drop resistance.....	46
5.5.6	Shock resistance.....	47
5.5.7	Possible disassembling	47
5.5.8	Surface temperature	47
5.5.9	Heat resistance.....	48
5.5.10	Probes.....	48
5.5.11	Lead(s).....	50
5.6	Marking.....	51
5.6.1	Visual inspection and measurement	51
5.6.2	Durability of marking	51
5.7	Instructions for use.....	52
5.7.1	Type test	52

5.7.2	Alternative test in case of voltage detectors having completed the production phase	52
5.8	Tests for reasonably foreseeable misuse during live working	52
5.8.1	AC/DC voltage misuse	52
5.8.2	Maximum current to earth in case of misuse	52
5.8.3	Misuse in case of mistaking of the voltage of the low voltage network	53
6	Conformity testing	53
7	Modifications	53
Annex A (informative)	Differences with IEC 61010 series	54
A.1	Existing requirements and tests but with different sanctions or pass test criteria	54
A.2	List of requirements of IEC 61010 series not included in this standard, with rationale	56
A.3	Additional requirements of this standard, related to safety and functional safety of voltage detectors, with rationale	57
Annex B (normative)	Supplementary functions: Phase indication – Rotating field indication – Continuity check	59
B.1	Terms and definitions	59
B.2	General requirements for the supplementary functions	59
B.2.1	Safety and performance of the voltage detector	59
B.2.2	Indication	59
B.2.3	Indication only in contact with bare part	59
B.2.4	Temperature rise	59
B.2.5	Instructions for use	59
B.3	General tests for the supplementary functions	60
B.3.1	Safety and performance of the voltage detector	60
B.3.2	Indication	60
B.3.3	Indication only in contact with bare part	60
B.3.4	Temperature rise test	60
B.3.5	Instructions for use	60
B.4	Phase indication with or without the use of accessible electrode	61
B.4.1	General	61
B.4.2	Additional requirements	61
B.4.3	Additional tests	61
B.5	Rotating field indication	62
B.5.1	Additional requirements	62
B.5.2	Additional tests	62
B.6	Continuity check	63
B.6.1	Additional requirements	63
B.6.2	Additional tests	63
B.7	Classification of defects and associated requirements and tests	64
Annex C (normative)	Instructions for use	65
C.1	General	65
C.2	Safety advices	66
Annex D (normative)	General type test procedure	67
Annex E (normative)	Classification of defects and associated requirements and tests	69
Annex F (informative)	In-service care and use	71
F.1	Use and storage	71
F.2	Inspection before use	71

F.3	Maintenance	71
F.3.1	Regular maintenance	71
F.3.2	Periodic maintenance.....	72
F.3.3	Periodic testing	72
Annex G (informative)	Voltage detectors and the presence of interference voltages	73
G.1	General.....	73
G.2	Voltage detectors with the capability of suppressing or reducing significantly the level of interference voltages – relatively low internal impedance (< 100 kΩ).....	73
G.3	Voltage detectors with the capability of discriminating an operating voltage from an interference voltage	73
G.4	Voltage detectors with no capability of suppressing or reducing significantly the level of interference voltages – relatively high internal impedance (> 100 kΩ)	74
Bibliography	75
Figure 1	– Illustration of the electrical insulation features applicable to components of a voltage detector.....	20
Figure 2	– Voltage detector.....	23
Figure 3	– Maximum rms a.c. current to earth in case of misuse	27
Figure 4	– Maximum d.c. current to earth in case of misuse	28
Figure 5	– Test set-up for the performance of a voltage detector claiming to be able to distinguish an operating voltage from an interference voltage.....	32
Figure 6	– Test set-up for measurement of clear perceptibility of visual indication	34
Figure 7	– Test set-up for measurement of clear perceptibility of audible indication	36
Figure 8	– Test set-up for close adhesion of insulation of the insulated part of the contact electrode	49
Table 1	– Climatic categories of voltage detectors	17
Table 2	– Minimum clearance distances for basic insulation and for supplementary insulation.....	20
Table 3	– Minimum clearance distances for reinforced insulation	21
Table 4	– Parameters to be observed to check the climatic dependence	37
Table 5	– AC voltage values for test on the complete equipment.....	42
Table 6	– Maximum permissible surface temperatures	48
Table B.1	– Classification of defects and associated requirements and tests.....	64
Table D.1	– Sequential order for performing type tests	67
Table D.2	– Type tests out of sequence.....	68
Table E.1	– Classification of defects and associated requirements and tests.....	69
Table F.1	– Periodic testing	72

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LIVE WORKING –
VOLTAGE DETECTORS –****Part 3: Two-pole low-voltage type**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61243-3 has been prepared by IEC technical committee 78: Live working.

This third edition cancels and replaces the second edition published in 2009. It is a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- requirement and test to manage *interference voltages* at power frequencies;
- informative annex on *voltage detectors* and the presence of *interference voltages*.

The text of this standard is based on the following documents:

FDIS	Report on voting
78/1054/FDIS	78/1090/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Terms defined in Clause 3 are given in italic print throughout this standard.

A list of all parts of the IEC 61243 series can be found, under the general title *Live working – Voltage detectors*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW

(standards.iteh.ai)

The contents of the corrigenda 1 (January 2015) and 2 (May 2015) have been included in this copy.

[IEC 61243-3:2014](https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af4dc2a0f50/iec-61243-3-2014)

<https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af4dc2a0f50/iec-61243-3-2014>

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

The devices covered by this standard are designed to be used in a live working environment to determine the status (presence or absence of operating voltage) of low-voltage installations.

The live working environment comes with its specific hazards and working conditions, which are generally more severe than the ones encountered by workers in other fields than live working.

This International Standard is a product standard giving essential requirements and tests to verify that the devices perform well and will contribute to the safety of the users, provided they are used by skilled persons, and according to safe working procedures and to local or national regulations.

Voltage detectors are not considered as measuring or testing devices, separately covered by IEC 61010 series. However, in case of misuse by general electrical workers, the requirements and tests included in this document are intended to achieve an equivalent level of safety.

To take into consideration the specific needs of a live working environment, the following differences exist with IEC 61010 series:

- some requirements and tests exist in both standards but with different sanctions or pass test criteria (see A.1);
- some requirements of IEC 61010 are not included in this standard (see A.2, with rationale);
- some additional requirements of this standard are not specified in IEC 61010 with the rationale (see A.3).

This International Standard has been prepared according to the requirements of IEC 61477, where applicable.

The product covered by this standard may have an impact on the environment during some or all stages of its life cycle. These impacts can range from slight to significant, be of short-term or long-term effect, and occur at the global, regional or local level.

This standard does not include requirements and test provisions for the manufacturers of the product, or recommendations to the users of the product for environmental improvement. However, all parties intervening in its design, manufacture, packaging, distribution, use, maintenance, repair, reuse, recovery and disposal are invited to take account of environmental considerations.

LIVE WORKING – VOLTAGE DETECTORS –

Part 3: Two-pole low-voltage type

1 Scope

This part of IEC 61243 is applicable to hand-held *two-pole voltage detectors* with their accessories (crocodile clips and detachable *leads*) to be used in contact with parts of electrical systems:

- for a.c. voltages not exceeding 1 000 V at nominal frequencies between 16 2/3 Hz and up to 500 Hz,

and/or

- for d.c. voltages not exceeding 1 500 V.

NOTE The a.c. voltages defined in this standard refer either to phase-to-phase voltages or phase to neutral voltages.

Contact electrode extensions are not covered by this standard.

Voltage detectors covered by this standard are intended to be used under dry and humid conditions, both indoor and outdoor. They are not intended to be used under rain conditions.

Voltage detectors covered by this standard are not intended to be used for continuous operation.

Voltage detectors covered by this standard are intended to be used up to 2 000 m above sea level.

This standard also includes provisions for the following supplementary functions when available (see Annex B):

- phase indication,
- rotating field indication, and
- continuity check.

Other supplementary functions are not covered by this standard.

Voltage detectors covered by this standard are not considered as measuring devices. Relevant safety requirements for measuring devices are included in IEC 61010 series.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60068-2-75:1997, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60304, *Standard colours for insulation for low-frequency cables and wires*

IEC 60417, *Graphical symbols for use on equipment*. Available from: <http://www.graphical-symbols.info/equipment>

IEC TS 60479-1:2005, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013¹

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60695-10-2:2003, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

[IEC 61243-3:2014](https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af8dc2e0f50/iec-61243-3-2014)

[https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-](https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af8dc2e0f50/iec-61243-3-2014)

[1af8dc2e0f50/iec-61243-3-2014](https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af8dc2e0f50/iec-61243-3-2014)

IEC 60942, *Electroacoustics – Sound calibrators*

IEC 61010-031:2002, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test*

IEC 61010-031:2002/AMD1:2008²

IEC 61010-1:2001³, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61140:2001, *Protection against electric shock – Common aspects for installation and equipment*

Amendment 1:2004

IEC 61180-1, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61180-2, *High-voltage test techniques for low-voltage equipment – Part 2: Test equipment*

IEC 61260, *Electroacoustics – Octave-band and fractional-octave-band filters*

¹ There exists a consolidated edition 2.2 (2013) that includes IEC 60529:1989 and its Amendments 1 and 2.

² There exists a consolidated edition 1.1 (2008) that includes IEC 61010-031:2002 and its Amendment 1.

³ Second edition, replaced by a third edition in 2010.

IEC 61318, *Live working – Conformity assessment applicable to tools, devices and equipment*

IEC 61326-1:2005, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61477, *Live working – Minimum requirements for the utilization of tools, devices and equipment*

IEC 61557-7:2007, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 7: Phase sequence*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*

ISO 286-1, *Geometrical product specifications (GPS) – ISO code system for tolerances on linear sizes – Part 1: Bases of tolerances, deviations and fits*

ISO 286-2, *Geometrical product specifications (GPS) – ISO code system for tolerances on linear sizes – Part 2: Tables of standard tolerance classes and limit deviations for holes and shafts*

ISO 354, *Acoustics – Measurement of sound absorption in a reverberation room*

ISO 3744:1994⁴, *Acoustics – Determination of sound power levels of noise sources using sound pressure – Engineering method in an essentially free field over a reflecting plane*

ISO 3745, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Precision methods for anechoic rooms and hemi-anechoic rooms*

<https://standards.iteh.ai/catalog/standards/sist/d1d1ea9b-0189-4c6c-aecd-1af4dc2a0f50/iec-61243-3-2014>

ISO 7000, *Graphical symbols for use on equipment – Registered symbols. Available at: <http://www.graphical-symbols.info/equipment>*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61318 and the following apply.

3.1 basic insulation

insulation applied to live parts of a *voltage detector* to provide basic protection against electric shock

Note 1 to entry: *Basic insulation* does not necessarily include insulation used exclusively for functional purposes (see 3.10.1 of IEC 61140:2001).

[SOURCE: IEC 60664-1:2007, 3.17.2 modified – The definition has been modified to fit the specific context of a *voltage detector*.]

3.2 clear indication

unambiguous detection and indication of the voltage state between the *contact electrodes*

⁴ Second edition, replaced by a third edition in 2010.

3.3**clear perceptibility**

case where the indication is unmistakably discernible by the user under specific environmental conditions when the *voltage detector* is in its operating position

3.4**contact electrode**

conductive part of the *probe* which establishes the electric connection to the part to be checked

Note 1 to entry: In certain designs, a part of the *contact electrode* is covered with insulating material.

3.5**extra low voltage****ELV**

voltage below 50 V a.c. or 120 V d.c.

3.6**hand-guard**

distinctive physical barrier (fixed to or part of the *probe*) to prevent the fingers or hands of the operator from inadvertently touching the *contact electrode* or any energized part

3.7**hazardous live**

capable of rendering an electrical shock or electrical burn in *normal condition* or *single fault condition*

3.8**indicating voltage** **U_i**

approximate value of the operating voltage identified by the *voltage detector*

Note 1 to entry: The *indicating voltage* of the *voltage detector* is the parameter associated with its *clear indication*. Certain types of *voltage detectors* may have several *indicating voltages* and/or several *indicating voltage* ranges. Limit values of a voltage range are named U_i min. and U_i max.

3.9**indicator**

part of the *voltage detector* which indicates the presence of the operating voltage between the *contact electrodes*

Note 1 to entry: The *indicator* may provide as well information related to supplementary functions.

3.10**inspection**

conformity evaluation by observation and judgement, accompanied as appropriate by measurement, testing, gauging or calculation

SOURCE: ISO 9000:2005, 3.8.2 modified – The definition has been modified to include calculation.]

3.11**interference voltage**

voltage at power frequency picked up inductively or capacitively by the part to be tested

3.12**internal energy source**

integrated functional power supply

3.13**lead**

flexible cable connecting different components of the *voltage detector* together

3.14**normal condition**

condition in which all means of protection are intact

[SOURCE: IEC Guide 104:2010, 3.7]

3.15**probe**

insulated part of a *voltage detector* intended to be handled by the user to bring its *contact electrode* in contact with the component to be checked

Note 1 to entry: The *probe* may contain the *indicator*.

Note 2 to entry: The *probe* does not include a *lead*. The *probe* and the *lead* may be detachable or not.

3.16**protective impedance**

component, assembly of components or the combination of *basic insulation* and a current or voltage-limiting device, whose impedance, construction and reliability are such that, when connected between accessible conductive parts which are hazardous when live, it provides protection to the extent required by this standard in *normal condition* and *single fault condition*

3.17**reasonably foreseeable misuse**

use of a product, process or service in a way not intended by the supplier, but which can result from readily predictable human behaviour

[SOURCE: ISO/IEC Guide 51:2014, 3.14, modified – The two notes to entry in the original have been deleted.]

3.18**recovery time**

r_t

minimum no-load time between two uses as specified by the manufacturer

3.19**response time**

time delay between a sudden change of the voltage state between the *contact electrodes* and the associated *clear indication*

3.20**single fault condition**

condition in which one means of protection against hazards is defective, or one fault is present which could cause a hazard

Note 1 to entry: If a *single fault condition* results unavoidably in one or more other fault conditions, all are considered as one *single fault condition*.

[SOURCE: IEC Guide 104:2010, 3.8, modified – The wording has been changed to refer specifically to the potential hazards involved.]

3.21**temporary overvoltage**

power frequency overvoltage of relatively long duration