

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Field Device Integration (FDI) –
Part 101-1: Profiles – Foundation Fieldbus H1
(standards.iteh.ai)

Intégration des appareils de terrain (FDI) –
Partie 101-1: Profils – Foundation Fieldbus H1
<https://standards.iteh.ai/catalog/standards/sist/05ceef453-9318-4251-a1f5-1f4de564fb39/iec-62769-101-1-2015>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 62769-101-1

Edition 1.0 2015-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Field Device Integration (FDI) –
Part 101-1: Profiles – Foundation Fieldbus H1**
(standards.iteh.ai)

**Intégration des appareils de terrain (FDI) –
Partie 101-1: Profils – Foundation Fieldbus H1**
IEC 62769-101-1:2015
https://standards.iteh.ai/catalog/standards/sist/6ce453-9318-4251-a1f5-1f4de564fb39/iec-62769-101-1-2015

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100

ISBN 978-2-8322-2634-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions, abbreviated terms and acronyms	8
3.1 Terms and definitions.....	8
3.2 Abbreviated terms and acronyms	8
4 Conventions	8
4.1 EDDL syntax.....	8
4.2 XML syntax.....	8
4.3 Capitalizations	8
5 Profile for CP 1/1 (FOUNDATION™ H1)	9
5.1 General.....	9
5.2 Catalog profile	9
5.2.1 Protocol support file.....	9
5.2.2 CommunicationProfile definition.....	9
5.2.3 Profile device.....	9
5.2.4 Protocol version information	9
5.3 Associating a Package with a CP 1/1 device.....	10
5.3.1 Device type identification mapping.....	10
5.3.2 Device type revision mapping.....	10
5.4 Information Model mapping.....	10
5.4.1 ProtocolType definition.....	10
5.4.2 DeviceType mapping	11
5.4.3 FunctionalGroup Identification definition	11
5.4.4 BlockType property mapping	11
5.4.5 Mapping to Block ParameterSet.....	12
5.5 Topology elements.....	12
5.5.1 ConnectionPoint definition	12
5.5.2 Communication Device definition	14
5.5.3 Communication service provider definition	15
5.5.4 Network definition	16
5.6 Methods.....	17
5.6.1 Methods for FDI Communication Servers	17
5.6.2 Methods for Gateways	24
Annex A (normative) Topology scan schema.....	25
A.1 General.....	25
A.2 FoundationH1AddressT	25
A.3 FoundationH1ConnectionPointT.....	25
A.4 FoundationH1NetworkT	26
A.5 Network	26
A.6 FoundationBlockIdentificationT	27
A.7 FoundationIdentificationT	27
Annex B (normative) Transfer service parameters.....	29
B.1 General.....	29

B.2	receiveData	29
B.3	sendData	29
B.4	OperationT	30
B.5	ResponseCodeT	30
B.6	TransferResultDataT	30
B.7	TransferSendDataT	31
Annex C (informative) Communication service arguments for Transfer Method		32
Bibliography		33
Table 1	– Capability File part	9
Table 2	– CommunicationProfile definition	9
Table 3	– Device type catalog mapping	10
Table 4	– ProtocolType Foundation_H1 definition	10
Table 5	– Inherited DeviceType Property mapping	11
Table 6	– Identification Parameters	11
Table 7	– Inherited BlockType property mapping	12
Table 8	– ConnectionPointType ConnectionPoint_Foundation_H1 definition	12
Table 9	– Communication device ParameterSet definition	15
Table 10	– Method Connect arguments	18
Table 11	– Method Disconnect arguments	19
Table 12	– Method Transfer arguments	20
Table 13	– Method GetPublishedData arguments	22
Table 14	– Method SetAddress arguments	23
Table A.15	– Attributes of FoundationH1ConnectionPointT	26
Table A.16	– Elements of FoundationH1ConnectionPointT	26
Table A.17	– Elements of FoundationH1NetworkT	26
Table A.18	– Attributes of FoundationBlockIdentificationT	27
Table A.19	– Attributes of FoundationIdentificationT	28
Table B.1	– Elements of receiveData	29
Table B.2	– Enumerations of OperationT	30
Table B.3	– Attributes of ResponseCodeT	30
Table B.4	– Attributes of TransferResultDataT	31
Table B.5	– Attributes of TransferSendDataT	31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE INTEGRATION (FDI) –

Part 101-1: Profiles – Foundation Fieldbus H1

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard IEC 62769-101-1 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this standard is based on the following documents:

CDV	Report on voting
65E/352/CDV	65E/415/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62769 series, published under the general title *Field Device Integration (FDI)*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 62769-101-1:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/03cef453-9318-4251-a1f5-1f4de564fb39/iec-62769-101-1-2015>

INTRODUCTION

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning

- a) Method for the Supplying and Installation of Device-Specific Functionalities, see Patent Family DE10357276;
- b) Method and device for accessing a functional module of automation system, see Patent Family EP2182418;
- c) Methods and apparatus to reduce memory requirements for process control system software applications, see Patent Family US2013232186;
- d) Extensible Device Object Model, see Patent Family US12/893,680.

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holders of these patent rights have assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

- a) ABB Research Ltd
Claes Ryttoft
Affolterstrasse 4
Zurich, 8050
Switzerland
- b) Phoenix Contact GmbH & Co. KG
Intellectual Property, Licenses & Standards
Flachsmarktstrasse 8, 32825 Blomberg
Germany
- c) Fisher Controls International LLC
John Dilger, Emerson Process Management LLLP
301 S. 1st Avenue, Marshalltown, Iowa 50158
USA
- d) Rockwell Automation Technologies, Inc.
1 Allen-Bradley Drive
Mayfield Heights, Ohio 44124
USA

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

FIELD DEVICE INTEGRATION (FDI) –

Part 101-1: Profiles – Foundation Fieldbus H1

1 Scope

This part of IEC 62769 specifies an FDI profile of IEC 62769 for IEC 61784-1_CP 1/1 (FOUNDATION™ Fieldbus H1)¹.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158-5-9:2014, *Industrial communication networks - Fieldbus specifications - Part 5-9: Application layer service definition - Type 9 elements*

IEC 61784-1, *Industrial communication networks - Profiles - Part 1: Fieldbus profiles*

IEC 61784-2, *Industrial communication networks - Profiles - Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3*

IEC 61784-3:2010, *Industrial communication networks - Profiles - Part 3: Functional safety fieldbuses - General rules and profile definitions*

IEC 61804 (all parts), *Function blocks (FB) for process control*

IEC 62541-100:2015, *OPC Unified Architecture – Part 100: OPC UA for Devices*

NOTE IEC 62769-1 is technically identical to FDI-2021.

IEC 62769-2, *Field Device Integration (FDI) – Part 2: FDI Client*

NOTE IEC 62769-2 is technically identical to FDI-2022.

IEC 62769-4:2015, *Field Device Integration (FDI) – Part 4: FDI Packages*

NOTE IEC 62769-4 is technically identical to FDI-2024.

IEC 62769-5:2015, *Field Device Integration (FDI) – Part 5: FDI Information Model*

NOTE IEC 62769-5 is technically identical to FDI-2025.

IEC 62769-6, *Field Device Integration (FDI) – Part 6: FDI Technology Mapping*

NOTE IEC 62769-6 is technically identical to FDI-2026.

¹ FOUNDATION™ Fieldbus is the trade name of the non-profit consortium Fieldbus Foundation. This information is given for the convenience of users of this standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance does not require use of the trade name. Use of the trade name requires permission of the trade name holder.

IEC 62769-7:2015–, *Field Device Integration (FDI) – Part 7: FDI Communication Devices*

NOTE IEC 62769-7 is technically identical to FDI-2027.

3 Terms, definitions, abbreviated terms and acronyms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61158-5-9, IEC 61784-1, IEC 61784-2, IEC 61784-3, IEC 61804, IEC 62541-100, IEC 62769-2, IEC 62769-4, IEC 62769-5, IEC 62769-6 and IEC 62769-7 apply.

3.2 Abbreviated terms and acronyms

For the purposes of this document, the following abbreviations apply:

CFF	common file format
CP	communication profile (see IEC 61784-1 or IEC 61784-2)
CPF	communication profile family (see IEC 61784-1 or IEC 61784-2)
EDD	Electronic Device Description (see IEC 61804)
FB	function block
IM	Information Model
SMIB	system management information base
VFD	virtual field device

4 Conventions

[IEC 62769-101-1:2015](https://standards.iteh.ai/catalog/standards/sist/03ce453-9318-4251-a1f5-1f4de564fb39/iec-62769-101-1-2015)

4.1 EDDL syntax

<https://standards.iteh.ai/catalog/standards/sist/03ce453-9318-4251-a1f5-1f4de564fb39/iec-62769-101-1-2015>

This part of IEC 62769 specifies content for the EDD component that is part of an FDI Communication Package. EDDL syntax uses the font `Courier New`. EDDL syntax is used for method signature, variable, data structure and component declarations.

4.2 XML syntax

XML syntax examples use the font `Courier New`. The XML syntax is used to describe XML document schema.

EXAMPLE: `<xsd:simpleType name="Example">.`

4.3 Capitalizations

The IEC 62769 series uses capitalized terms to emphasize that these terms have an FDI specific meaning.

Some of these terms use an acronym as a prefix for example

- FDI Client, or
- FDI Server.

Some of these terms are compound terms such as:

- Communication Servers, or
- Profile Package.

Parameter names or attributes are concatenated to a single term, where the original terms start in this term with a capital letter such as:

- ProtocolSupportFile, or
- ProtocolType.

Parameter names or attributes can also be constructed by using an underscore character to concatenate two or more terms such as:

- PROFILE_ID, or
- Profibus_PA_Network.

5 Profile for CP 1/1 (FOUNDATION™ H1)

5.1 General

This profile specifies the protocol specifics needed for FDI Packages describing communication servers, gateways and devices.

5.2 Catalog profile

5.2.1 Protocol support file

5.2.1.1 Capability file

Each CP 1/1 FDI Device Package shall contain a capability file. The capability file part is described in Table 1.

Table 1 – Capability File part

Parameter	Description
Content Type:	txt/plain
Root Namespace:	Not applicable
Source Relationship:	http://fdi-cooperation.com/2010/relationships/attachment-protocol
Filename:	Use file extension .CFF

5.2.2 CommunicationProfile definition

IEC 62769-4 defines a CommunicationProfile enumeration type for the Catalog XML schema. Table 2 defines the CP 1/1 specific values for this enumeration.

Table 2 – CommunicationProfile definition

CommunicationProfile	Description
foundation_h1	CP 1/1 device type with a function block application

5.2.3 Profile device

Not supported in this standard.

5.2.4 Protocol version information

IEC 62769-4 defines an element type named InterfaceT for the Catalog XML Schema. Element type InterfaceT contains an element named Version which is supposed to provide

version information about the applied communication protocol profile. The value follows the IEC 62769-4 defined version information schema defined in element type VersionT.

The major version part of VersionT shall be set to the ITK_VER parameter. The minor and builds parts shall be set to 0.

EXAMPLE For ITK_VER 5, the value for InterfaceT is 5.0.0.

5.3 Associating a Package with a CP 1/1 device

5.3.1 Device type identification mapping

CP 1/1 device types are uniquely identified by the parameters MANUFAC_ID, DEVICE_TYPE and DEV_REV found in the Resource Block. These parameters are used to associate a given device instance to an FDI Device Package. These parameters are mapped to the FDI Device Package Catalog according to Table 3.

Table 3 – Device type catalog mapping

Catalog Element	CP Mapping
Manufacturer element of InterfaceT (IEC 62769-4)	MANUFAC_ID String format "0xdddd" where dddd is the MANUFAC_ID number in hexadecimal format.
DeviceModel element of InterfaceT (IEC 62769-4)	DEVICE_TYPE String format "0xdddd" where dddd is the DEVICE_TYPE number in hexadecimal format.
DeviceRevision element ListOfSupportedDeviceRevisionsT (IEC 62769-4)	DEV_REV String format "x.0.0" where x is the DEV_REV in decimal format (no leading zeros).

iTech STANDARD PREVIEW
(standards.iteh.ai)
IEC 62769-101-1:2015
<https://standards.iteh.ai/catalog/standards/sist/03ce453-9318-4251-a1f5-1f4de564f39/iec-62769-101-1-2015>

5.3.2 Device type revision mapping

Each device type is identified according to 5.3.1. A device may also include a parameter COMPATIBILITY_REV from the Resource Block. This parameter specifies the lowest device version (DEV_REV) that a new device can replace while maintaining compatibility with a prior FDI Device Package.

5.4 Information Model mapping

5.4.1 ProtocolType definition

Table 4 defines the ProtocolType used to identify CP 1/1 network communications.

Table 4 – ProtocolType Foundation_H1 definition

Attribute	Value				
BrowseName	Foundation_H1				
IsAbstract	False				
References	NodeClass	BrowseName	Data Type	TypeDefinition	ModellingRule
Inherits the properties of ProtocolType defined in IEC 62541-100.					

5.4.2 DeviceType mapping

Each device type inherits the properties of the DeviceType. The mapping of the inherited properties from the DeviceType is defined in Table 5.

Table 5 – Inherited DeviceType Property mapping

Property	CP Mapping
SerialNumber	DEV_ID (System Management Information Base)
RevisionCounter	-1 (not defined)
Manufacturer	MANUFAC_ID (Resource Block)
Model	DEV_TYPE (Resource Block)
DeviceManual	entry text string (not supported) ^a
DeviceRevision	DEV_REV (Resource Block)
SoftwareRevision	SOFTWARE_REV (if available, otherwise -1)
HardwareRevision	HARDWARE_REV (if available, otherwise -1)

^a Device manuals are exposed as attachments of the FDI Device Package.

5.4.3 FunctionalGroup Identification definition

As defined in IEC 62541-100, each device representation in the FDI Server hosted Information Model shall contain a protocol specific FunctionalGroup called Identification. This FunctionalGroup organizes variables found in the Resource Block of the device type instance. The FunctionalGroup Identification for CP 1/1 is defined in Table 6.

Table 6 – Identification Parameters

BrowseName	Data Type	Optional/Mandatory
MANUFAC_ID	UInt32	Mandatory
DEV_TYPE	UInt16	Mandatory
DEV_REV	UInt8	Mandatory
HARDWARE_REV	String	Optional
SOFTWARE_REV	String	Optional
COMPATIBILITY_REV	UInt8	Optional
CAPABILITY_LEV	UInt8	Optional
ITK_VER	UInt16	Mandatory
SIF_ITK_VER	UInt16	Optional
FD_VER	UInt16	Optional

5.4.4 BlockType property mapping

CP 1/1 device types are block-oriented according to IEC 62541-100. IEC 62769-5 specifies the mapping of EDDL BLOCK_A elements to block types and instances

The BLOCK_A maps as a subtype of the topology element BlockType and inherits the properties per IEC 62541-100. The mapping of the inherited properties of the BlockType is specified in Table 7.

Table 7 – Inherited BlockType property mapping

Property	CP Mapping (Block ParameterSet)
RevisionCounter	ST_REV
ActualMode	MODE_BLK.ACTUAL
PermittedMode	MODE_BLK.PERMITTED
NormalMode	MODE_BLK.NORMAL
TargetMode	MODE_BLK.TARGET

5.4.5 Mapping to Block ParameterSet

The ParameterSet is relative to each Block. The ParameterSet includes the CHARACTERISTICS records of the block and all the parameters found in the PARAMETERS, LOCAL_PARAMETERS and LIST_ITEMS.

The browse name of the parameters found in the PARAMETERS and LOCAL_PARAMETERS is the member name in the respective lists. For example, ST_REV is the browse name of the Static Revision parameter. LIST_ITEMS do not have member names; therefore the browse name of each LIST in the LIST_ITEMS is the item name of the list.

5.5 Topology elements

5.5.1 ConnectionPoint definition

The ConnectionPoint type ConnectionPoint_Foundation_H1 shall be used to identify CP 1/1 network communication and is defined in Table 8. The ConnectionPoint_Foundation_H1 type is a sub type of the abstract type ConnectionPointType defined in IEC 62541-100.

<https://standards.iteh.ai/catalog/standards/sist/03ce453-9318-4251-a1f5-101-1-2015>

The Address property shall be the H1 node address.

The OrdinalNumber property reflects the position of the VFD within the SMIB VFD list. For devices exposing multiple FB VFDs the OrdinalNumber property is mandatory to address the FB VFD. For devices with a single FB VFD the OrdinalNumber property can be omitted. Devices exposed as instances of type DeviceType define their connection points as components. Hence Devices with multiple FB VFDs shall contain multiple Connection Points, one per FB VFD.

The SIFConnection property denotes whether a safety instrumented function (SIF) connection is necessary or not according to the functional safety profile (IEC 61784-3:2010, Clause 6). CP 1/1 devices that implement the functional safety profile shall have a connection point as a component that has set this property to true. Devices supporting standard connections and SIF connections shall expose two Connections Points as components.

Table 8 – ConnectionPointType ConnectionPoint_Foundation_H1 definition

Attribute	Value				
BrowseName	ConnectionPoint_Foundation_H1				
IsAbstract	False				
References	NodeClass	BrowseName	Data Type	TypeDefinition	ModellingRule
Inherits the properties of ConnectionPointType defined in IEC 62541-100.					
HasProperty	Variable	Address	Byte	PropertyType	Mandatory
HasProperty	Variable	OrdinalNumber	Int32	PropertyType	Optional
HasProperty	Variable	SIFConnection	Boolean	PropertyType	Optional

The ConnectionPoint type ConnectionPoint_Foundation_H1 shall be described by an EDD element contained in a Communication Device related FDI Package that can drive a CP 1/1 network. Actual ConnectionPoint_Foundation_H1 properties are declared by VARIABLE constructs grouped together in a COLLECTION named Foundation_H1_ConnectionPoint_Properties.

```
COMPONENT ConnectionPoint_Foundation_H1
{
  LABEL "Foundation H1 Connection point";
  CLASSIFICATION NETWORK_CONNECTION_POINT;
  CAN_DELETE FALSE;
  PROTOCOL Foundation_H1;
  CONNECTION_POINT Foundation_H1_ConnectionPoint_Properties;
}
```

```
VARIABLE Address
{
  LABEL "H1 Node address";
  HELP "Address of the H1 Node";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER (1)
  {
    MIN_VALUE 16;
    MAX_VALUE 255;
  }
  HANDLING READ & WRITE;
```

ITIH STANDARD PREVIEW
(standards.iteh.ai)

```
VARIABLE OrdinalNumber
{
  LABEL "OrdinalNumber address property";
  HELP "OrdinalNumber property to address the Function Block Application";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER (4);
  HANDLING READ & WRITE;
```

```
VARIABLE SIFConnection
{
  LABEL "SIFConnection address property";
  HELP "Connection point supports SIF Connections";
  CLASS DEVICE;
  TYPE ENUMERATED (1)
  {
    {0, "NO_SIFCONNECTION"} ,
    {1, "SIFCONNECTION"}
  }
  HANDLING READ & WRITE;
```

```
COLLECTION Foundation_H1_ConnectionPoint_Properties
{
  LABEL "FF H1 Connection Point data";
  MEMBERS
  {
    CONNECTION_POINT_ADDRESS, Address;
    CONNECTION_POINT_ORDINALNUMBER, OrdinalNumber;
    CONNECTION_POINT_SIFCONNECTION , SIFConnection;
  }
}
```