



Edition 2.1 2021-07 CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Powertrack systems – Part 22: Particular requirements for powertrack systems intended for onfloor or underfloor installation

Systèmes de conducteurs préfabriqués – <u>22014</u> Partie 22: Exigences particulières pour les systèmes de conducteurs <u>657/ec-</u> préfabriqués destinés au montage sur le sol ou sous le sol





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland

Tel.: +41 22 919 02 11 info@iec.ch www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.





Edition 2.1 2021-07 CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Powertrack systems – TANDARD PREVIEW Part 22: Particular requirements for powertrack systems intended for onfloor or underfloor installation

Systèmes de conducteurs préfabriqués – 22014 Partie 22: Exigences particulières pour les systèmes de conducteurs 657/ecpréfabriqués destinés au montage sur le sol ou sous le sol

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 29.060.10; 29.120.20

ISBN 978-2-8322-5022-8

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

 Registered trademark of the International Electrotechnical Commission Marque déposée de la Commission Electrotechnique Internationale

iTeh STANDARD PREVIEW (standards.iteh.ai)

IEC 61534-22:2014

https://standards.iteh.ai/catalog/standards/sist/38dac4a9-489d-400b-a5fb-5c232ac3fb57/iec-61534-22-2014





Edition 2.1 2021-07 CONSOLIDATED VERSION

REDLINE VERSION

VERSION REDLINE



Powertrack systems – Part 22: Particular requirements for powertrack systems intended for onfloor or underfloor installation

Systèmes de conducteurs préfabriqués – <u>22014</u> Partie 22: Exigences particulières pour les systèmes de conducteurs <u>657/ec</u>préfabriqués destinés au montage sur le sol ou sous le sol



CONTENTS

 Scope	
 Normative references Terms and definitions General requirements General notes on tests Ratings Classification Marking and documentation Construction Clearances, creepage distances and solid insulation 	5
 3 Terms and definitions 4 General requirements 5 General notes on tests 6 Ratings 7 Classification 8 Marking and documentation 9 Construction 10 Clearances, creepage distances and solid insulation 	5
 General requirements General notes on tests Ratings Classification Marking and documentation Construction Clearances, creepage distances and solid insulation 	5
 5 General notes on tests	6
 6 Ratings	6
 7 Classification	6
 8 Marking and documentation 9 Construction 10 Clearances, creepage distances and solid insulation 	6
9 Construction10 Clearances, creepage distances and solid insulation	8
10 Clearances, creepage distances and solid insulation	8
	9
11 Protection against electric shock	9
12 Terminals and terminations	9
13 Screws, current-carrying parts and connections	9
14 Mechanical strength	9
15 Insulation resistance test and dielectric strength test	18
16 Normal operation	18
17 Temperature rise	18
18 Short-circuit protection and short-circuit withstand strength	18
19 Resistance to heat	18
20 hFire hazardichi/ontalog/standarda/sist/38dan4a0.480d.400h.a5fb.5a232ac3fb57/iza.	18
21 External influences	19
22 Electromagnetic compatibility	19
Annex AA (informative) Illustrations of underfloor and onfloor installations	20
Annex BB (normative) Additional test requirements for PT systems already complying with IEC 61534-22: 2009	22
Figure 101 – External load test	10
Figure 102 – Traffic load test for flushfloor service units applied to a small surface area	14
Figure 103 – Traffic load test for flushfloor service units applied to a large surface area	16
Figure 104 – Test arrangement for fixing apparatus mounting device according to	17
Figure AA.1 – Illustrations of underfloor installations	· ·
Figure AA.2 – Example of installation onfloor	20

IEC 61534-22:2014+AMD1:2021 CSV - 3 - © IEC 2021

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWERTRACK SYSTEMS –

Part 22: Particular requirements for powertrack systems intended for onfloor or underfloor installation

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61534-22 edition 2.1 contains the second edition (2014-06) [documents 23A/702/FDIS and 23A/708/RVD] and its amendment 1 (2021-07) [documents 23A/927/CDV and 23A/940/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication. International Standard IEC 61534-22 has been prepared by subcommittee 23A: Cable management systems, of IEC Technical Committee 23: Electrical accessories.

This second edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- Clauses 18 to 22 have been adapted to IEC 61534-1:2011 and include short-circuit test requirements;
- addition of a new (500 N) classification for the resistance to traffic load applied to small surface areas on a flushfloor service unit;
- addition of a new classification for the non-automatic closing of the lid on flushfloor service units and appropriate tests;
- addition of tests for floor service units declared for use when a floor is wet-treated.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be used in conjunction with IEC 61534-1:2011, *Powertrack systems – Part 1: General requirements*.

This Part 22 supplements or modifies the corresponding clauses of IEC 61534-1. Where a particular clause or subclause of IEC 61534-1:2011 is not mentioned in this Part 22, that clause or subclause applies as far as is reasonable. Where this Part 22 states "addition" or "replacement", the relevant text of IEC 61534-1:2011 is to be adapted accordingly.

Subclauses, tables and figures which are in addition to those in IEC 61534-1:2011 are numbered starting with 101.

A list of all parts of IEC 61534 series, published under the general title *Powertrack systems,* can be found on the IEC website.

The following differences exist in the countries indicated below:

Subclause 7.105.2: In the United Kingdom, this classification is not permitted.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

POWERTRACK SYSTEMS –

Part 22: Particular requirements for powertrack systems intended for onfloor or underfloor installation

1 Scope

Clause 1 of IEC 61534-1:2011 and IEC 61534-1:2011/AMD1:2014 is applicable except as follows:

1.1 Addition:

This part of IEC 61534 specifies the particular requirements and tests for PT systems intended for mounting on, or under the floor level and floor service units which are mounted on the floor, under the floor or flush with the floor.

NOTE 1 Types and applications are shown in Figures AA.1a, AA.1b and AA.2

NOTE 2 Flushfloor PT systems, with the exception of flushfloor service units, are not covered by this standard.

2 Normative references TANDARD PREVIEW

Clause 2 of IEC 61534-1:2011 is applicable except as follows:

Addition:

IEC 61534-22:2014

IEC 61534-1:2011, *Powertrack systems – Part 1: General requirements -*5c232ac3lb57/lec-IEC 61534-1:2011/AMD1:2014 IEC 61534-1:2011/AMD2:2020

3 Terms and definitions

Clause 3 of IEC 61534-1:2011, and Clause 3 of IEC 61534-1:2011/AMD1:2014 and Clause 3 of IEC 61534-1:2011/AMD2:2020 is are applicable except as follows:

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

Additional terms and definitions:

3.101

underfloor PT system

PT system whose components, except flushfloor service units, are intended for installation beneath the finished floor and in normal use are not exposed to traffic loads

Examples are shown in Figures AA.1a and AA.1b

3.102 onfloor PT system

PT system whose components are mounted on the floor surface

An example is shown in Figure AA.2.

3.103

finished floor

floor which carries the traffic load and which may be made of concrete, wood, or the like and which may or may not be completed with floor covering material such as carpet, tile, paint, parquet or similar means

3.104

apparatus mounting device

system component to accommodate electrical apparatus, for example switches, socketoutlets, circuit-breakers

3.105

floor service unit

system component used with a floor system and intended to accommodate one or more electrical apparatus such as switches, socket-outlets, circuit-breakers either directly or by use of mounting devices

3.106

flushfloor service unit

floor service unit that is flush with the finished floor when the unit is not in use'

3.107

in-use floor service unit STANDARD PRE

floor service unit which has cables and/or cords connected to external electrical appliances

3.108

standards.iten.a

not in-use floor service unit

floor service unit which has no cables and/or cords connected to external electrical appliances

https://standards.iteh.ai/catalog/standards/sist/38dac4a9-489d-400b-a5fb-5c232ac3fb57/iec-

4 General requirements 61534-22-201

Clause 4 of IEC 61534-1:2011 and Clause 4 of IEC 61534-1:2011/AMD2:2020-is are applicable.

5 General notes on tests

Clause 5 of IEC 61534-1:2011 and Clause 5 of IEC 61534-1:2011/AMD2:2020—is are applicable.

6 Ratings

Clause 6 of IEC 61534-1:2011 is applicable.

7 Classification

Clause 7 of IEC 61534-1:2011 is applicable except as follows:

Replacement:

7.1 According to resistance to impact for installation and application

7.1.1 PT system for 5 J impact

IEC 61534-22:2014+AMD1:2021 CSV - 7 - © IEC 2021

7.1.2 PT system for 20 J impact

Additional subclauses:

7.101 According to floor treatment

- 7.101.1 Dry-treatment of floor
- 7.101.2 Wet-treatment of floor for not in-use floor service unit
- 7.101.3 Wet-treatment of floor for in-use floor service unit

7.102 According to the intended location

- 7.102.1 Underfloor PT system
- 7.102.2 Onfloor PT system
- 7.103 According to resistance to traffic load applied to small surface area on a flushfloor service unit
- 7.103.1 500 N
- 7.103.2 750 NITCH STANDARD PREVIEW
- 7.103.3 1 000 N (standards.iteh.ai
- 7.103.4 1 500 N

IEC 61534-22:2014

- 7.103.5 // 2.000 Ns.iteh.ai/catalog/standards/sist/38dac4a9-489d-400b-a5fb-5c232ac3fb57/iec-
- 7.103.6 2 500 N
- 7.103.7 3 000 N
- 7.104 Optional classification according to resistance to traffic load applied to large surface area on a flushfloor service unit
- 7.104.1 2 000 N
- 7.104.2 3 000 N
- 7.104.3 5 000 N
- 7.104.4 10 000 N
- 7.104.5 15 000 N

7.105 According to the type of lid used on flushfloor service units

- 7.105.1 Automatic closing of the lid
- 7.105.2 Non-automatic closing of the lid
- NOTE In the United Kingdom, classification 7.105.2 is not permitted.

8 Marking and documentation

Clause 8 of IEC 61534-1:2011, and Clause 8 of IEC 61534-1:2011/AMD1:2014 and Clause 8 of IEC 61534-1:2011/AMD2:2020 is are applicable.

9 Construction

Clause 9 of IEC 61534-1:2011 and Clause 9 of IEC 61534-1:2011/AMD2:2020-is are applicable except as follows:

Additional subclauses:

9.101 Underfloor powertrack system components shall withstand external loads during transport and installation but are not subjected to traffic loads in normal use.

Compliance is checked by the tests specified in 14.101.2.

9.102 Onfloor powertrack system components shall withstand external loads.

Compliance is checked by the tests specified in 14.101.3.

9.103 Flushfloor service units shall withstand traffic loads in accordance with 7.103 and 7.104.

Compliance is checked by the tests specified in 14.101.4.

9.104 Lids of flush floor service units shall be so designed that in normal use they cannot be detached without an intentional action and also resist movement or unintentional opening when subject to external load.

61534-22-2014

Compliance is checked by inspection and the test of 14.101.4 and 14.101.5 as appropriate.

Lids of flush floor service units declared according to 7.105.1 shall be so designed that in normal use they will close automatically.

Compliance is checked by inspection and manual test.

9.105 Floor service units declared according to 7.101.2 and 7.101.3 shall avoid water coming into contact with insulated conductors and live parts during wet-treatment of floor by one or a combination of the following methods which may vary within the system:

- method 1: ensuring by design that water does not come into contact with insulated conductors and live parts when the water level is 10 mm above the upper level of the floor covering;
- method 2: providing an IP rating not less than IPX4;
- method 3: providing manufacturer's instructions which require that insulated conductors and live parts are positioned not less than 10 mm above the upper level of the floor covering.

For method 1, compliance is checked by measurement. For method 2, compliance is checked by the test of 21.2.3.101. For method 3, compliance is checked by inspection.

9.106 Flushfloor service units shall be so constructed that when installed with the lid closed they shall not present a trip hazard. Any protrusion above the finished floor shall not be greater than 4 mm, or 8 mm in the case of a chamfered step with an angle not exceeding 45° with the horizontal surface. When the service unit is in use this requirement does not apply.

IEC 61534-22:2014+AMD1:2021 CSV -9-© IEC 2021 Compliance is checked by inspection.

10 Clearances, creepage distances and solid insulation

Clause 10 of IEC 61534-1:2011 is applicable.

11 Protection against electric shock

Clause 11 of IEC 61534-1:2011 and Clause 11 of IEC 61534-1:2011/AMD1:2014-is are applicable except as follows:

Additional subclause:

11.1.101 The minimum IP rating for powertrack system components accessible to ordinary persons during normal use shall be IP 3XD. This requirement does not apply to accessories.

12 Terminals and terminations

Clause 12 of IEC 61534-1:2011 is applicable.

13 Screws, current-carrying parts and connections

Clause 13 of IEC 61534-1:2011 and Clause 13 of IEC 61534-1:2011/AMD1:2014 is are applicable.

14 Mechanical strength

https://standards.iteh.avcatalog/standards/sist/38dac4a9-489d-400b-a5fb-5c232ac3fb57/iec-

Clause 14 of IEC 61534-1:2011 is applicable except as follows:

14.2 Impact test

Delete 14.2.

Additional subclauses:

14.101 External mechanical load test

14.101.1 General

Underfloor and onfloor PT systems and PT flushfloor service units, shall have sufficient mechanical strength against external mechanical loads likely to occur during normal use:

- underfloor PT system components by the test of 14.101.2;
- onfloor PT system components by the tests of 14.101.3;
- flushfloor service units by the test of 14.101.4 and 14.101.5 as appropriate.

Any part for temporary use only during the installation phase does not need to comply with these tests but may be included for the test to allow compliance of other parts.

14.101.2 Load test for underfloor powertrack system components

14.101.2.1 General

Powertrack (PT) systems including tap-off units shall have sufficient mechanical strength against external loads likely to occur during installation and use.

14.101.2.2 Powertrack

The test shall be performed on a sample consisting of two lengths of powertrack each with a minimum length of 0,5 m which are connected together with the necessary connectors and with a supply connector at each end of the sample.

The sample is positioned on a horizontal rigid support. A steel cube of (50 ± 0.5) mm with an edge radius of approximately 1 mm is placed centrally on the joint. In the case of multi-compartment powertrack whose partition walls provide support, the middle of the largest compartment is selected, see Figure 101.



Key

- b width of the largest compartment
- *d* width of the smallest compartment
- L length of sample
- F applied vertical force

Figure 101 – External load test

A vertical force of (750 \pm 10) N is gradually applied over (60 \pm 1) s and maintained for a further (120 \pm 5) s centrally to the cube.

IEC 61534-22:2014+AMD1:2021 CSV - 11 - © IEC 2021

During the test, there shall be no deformation that impairs electrical safety.

In case of doubt, the sample shall conform to Clause 10 and 11.1.1.1.

After the test, the sample shall show no signs of damage, nor any cracks visible to normal or corrected vision without additional magnification.

After removal of the external load, the continuity of the protective circuit shall remain unaffected.

A current of (25 ± 1) A a.c. having a nominal frequency of 50 Hz or 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed between the earthing terminals at each end of the sample. Measurement of the voltage drop shall be made within 120 s after the initiation of the current flow. The impedance per metre, calculated from the measurement of the voltage drop between the two supply connectors, shall not exceed the value declared by the manufacturer or 0,05 Ω /m whichever is the lower.

14.101.2.3 Tap-off units

A tap-off unit shall be centrally installed on a length of powertrack which has a minimum length of 0,5 m.

The powertrack is positioned on a horizontal rigid support. A steel cube of (50 ± 0.5) mm with an edge radius of approximately 1 mm is placed centrally on the tap-off unit.

A vertical force of (750 \pm 10) N is gradually applied over (60 \pm 1) s and maintained for a further (120 \pm 5) s centrally to the cube.

During the test, there shall be no deformation that impairs electrical safety.

https://standards.iteh.ai/catalog/standards/sist/38dac4a9-489d-400b-a5fb-5c232ac3fb57/iec-

In case of doubt, the sample shall conform to Clause 10 and 11.1.1.1.

After the test, the sample shall show no signs of damage, nor any cracks visible to normal or corrected vision without additional magnification.

After removal of the external load, the continuity of the protective circuit shall remain unaffected.

A current of (25 ± 1) A a.c. having a nominal frequency of 50 Hz or 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed between the earthing terminal or contact of the tap-off unit and the nearest point on the protective earth busbar with the tap-off unit fully engaged as in normal use. Measurement of the voltage drop shall be made within 120 s after the initiation of the current flow. The impedance calculated from the measurement of the voltage drop between the two points stated shall not exceed the value declared by the manufacturer or 0,05 Ω /m whichever is the lower.

14.101.3 Load test for onfloor PT system components

14.101.3.1 General

PT systems including tap-off units shall have sufficient mechanical strength against external loads likely to occur during installation and use.