

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



Self-ballasted compact fluorescent lamps for general lighting services –  
Performance requirements

(standards.iteh.ai)

Lampes à fluorescence compactes à ballast intégré pour l'éclairage général –  
Exigences de performances

<https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms, containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Catalogue IEC - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

#### Recherche de publications IEC - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [csc@iec.ch](mailto:csc@iec.ch).

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Self-ballasted compact fluorescent lamps for general lighting services –  
Performance requirements**  
(standards.iteh.ai)

**Lampes à fluorescence compactes à ballast intégré pour l'éclairage général –  
Exigences de performances**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.140.30

ISBN 978-2-8322-3661-1

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD .....	4
1 Scope .....	6
2 Normative references .....	6
3 Terms and definitions .....	7
4 Marking .....	10
5 Test conditions .....	11
6 Performance criteria: assessment and compliance .....	11
6.1 General.....	11
6.2 Performance requirements.....	12
Annex A (normative) General conditions for measurement of photometric and electrical characteristics and requirements for test equipment .....	14
A.1 Method of measuring lamp characteristics .....	14
A.2 Lamp stabilization .....	14
A.3 Lamp ageing and life test.....	15
A.4 Electrical measurement.....	15
A.5 Photometric measurements.....	15
A.6 Time and cycles measurement.....	15
Annex B (normative) Test for starting time .....	16
B.1 General.....	16
B.2 Test conditions .....	16
B.3 Test procedure.....	16
B.4 Calculations.....	17
Annex C (normative) Test for run-up time .....	18
C.1 General.....	18
C.2 Test conditions .....	18
C.3 Test procedure.....	19
C.4 Calculations .....	20
Annex D (normative) Measurement of initial luminous efficacy and lumen maintenance .....	21
D.1 General.....	21
D.2 Test conditions .....	21
D.3 Test procedure.....	21
D.4 Initial luminous efficacy test .....	21
D.4.1 Test procedure .....	21
D.4.2 Calculations.....	22
D.5 Lumen maintenance test .....	22
Annex E (normative) Test for low temperature and low supply voltage starting.....	23
E.1 General.....	23
E.2 Test conditions .....	23
E.3 Test procedure.....	23
Annex F (normative) Test for switching withstand .....	24
Annex G (normative) Test for lamp life.....	25
Annex H (normative) Tests for compatibility with dimmers and switches.....	26
H.1 Inrush current .....	26
H.2 Specific requirements for dimmable lamps .....	27
Annex I (normative) Measurement of displacement factor .....	28

I.1	General.....	28
I.2	Phase-angle definition .....	28
I.3	Measurements requirements .....	29
I.3.1	Measurement circuit and supply source .....	29
I.3.2	Requirements for measurement equipment.....	29
I.3.3	Test conditions .....	29
Annex J (informative)	Explanation of displacement and distortion factors.....	30
J.1	General.....	30
J.2	Recommended values for displacement factor .....	30
Bibliography	.....	31
Figure B.1	– Typical setup for starting time test .....	17
Figure C.1	– Typical setup for run-up time test.....	19
Figure D.1	– Measurement of luminous flux .....	21
Figure H.1	– Typical inrush current profile.....	26
Figure H.2	– Current spikes before $I_{peak}$ are ignored .....	27
Figure H.3	– Waveform generator circuit for inrush current .....	27
Figure I.1	– Definition of the first harmonic current phase-angle ( $\varphi_1$ ) ( $I_1$ leads $U_{mains}$ ), $\varphi_1 > 0$ ) .....	28
Figure I.2	– Definition of the first harmonic current phase-angle ( $\varphi_1$ ) ( $I_1$ lags $U_{mains}$ ), $\varphi_1 < 0$ ) .....	29
Table 1	– Locations where marking of rated values is required .....	10
Table 2	– Equivalency with non-directional incandescent lamps.....	11
Table 3	– Sample sizes, compliance criteria and test conditions .....	12
Table A.1	– Conditioning, off time and stabilization time .....	15
Table H.1	– Inrush current limitations and test conditions .....	26
Table J.1	– Recommended values for displacement factor.....	30

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SELF-BALLASTED COMPACT FLUORESCENT  
LAMPS FOR GENERAL LIGHTING SERVICES –  
PERFORMANCE REQUIREMENTS**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60969 has been prepared by subcommittee 34A: Lamps, of IEC technical committee 34: Lamp and related equipment.

This second edition cancels and replaces the first edition published in 1988, Amendment 1:1991 and Amendment 2:2000. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) title change;
- b) scope is now limited to compact fluorescent lamps, but expanded to cover all lamps of voltages greater than 50 V and all power ratings;
- c) introduction of requirements for lamp equivalency claims, switching withstand, starting time, low temperature, run up time, treatment of claims for different operating conditions;
- d) enhanced assessment and compliance criteria especially for lifetime;
- e) introduction in-rush test conditions and displacement factor.

The text of this standard is based on the following documents:

FDIS	Report on voting
34A/1923/FDIS	34A/1945/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of January 2017 have been included in this copy.

## iTeh STANDARD PREVIEW

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

[IEC 60969:2016](#)

<https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016>

# SELF-BALLASTED COMPACT FLUORESCENT LAMPS FOR GENERAL LIGHTING SERVICES – PERFORMANCE REQUIREMENTS

## 1 Scope

This document specifies performance requirements together with test methods and conditions required to show compliance of self-ballasted compact fluorescent lamps intended for general lighting services.

This document applies to self-ballasted compact fluorescent lamps of voltages > 50 V and all power ratings with lamp caps complying with IEC 60061-1.

NOTE Some features of this document could be applicable to self-ballasted compact fluorescent lamps of voltages  $\leq 50$  V and to other types of self-ballasted gas discharge lamps.

The requirements of this document relate only to type testing.

The performance requirements specified in this document are additional to the safety requirements specified in IEC 60968.

It can be expected that self-ballasted compact fluorescent lamps, which comply with this document, will start and operate satisfactorily at normal conditions (voltages between 92 % and 106 % of rated supply voltage, ambient air temperature of between -10 °C and 40 °C and in a luminaire complying with IEC 60598-1).

<https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016>

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60630, *Maximum lamp outlines for incandescent lamps*

IEC 60968, *Self-ballasted fluorescent lamps for general lighting services – Safety requirements*

IEC 61000-3-2:2014, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current  $\leq 16$  A per phase)*

IEC 61000-4-7, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*

IEC TR 61341, *Method of measurement of centre beam intensity and beam angle(s) of reflector lamps*

CIE 015-2004, *Colorimetry*

CIE 13.3, *Method of Measuring and Specifying Colour Rendering Properties of Light Source*



### 3 Terms and definitions

For the purposes of this document the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1

##### **self-ballasted lamp**

integrated lamp

unit which cannot be dismantled without being permanently damaged, provided with a lamp cap and incorporating a light source and any additional elements necessary for starting and stable operation of the light source

Note 1 to entry: A self-ballasted lamp is referred to as a lamp in this document.

[SOURCE: IEC 60968:2015, 3.1, modified – The admitted term and note have been added]

#### 3.2

##### **new lamp**

lamp which has not been energized since manufacture

#### 3.3

##### **rated value**

quantity value, assigned by the supplier, for a lamp characteristic under specified operating conditions

[IEC 60969:2016](https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016)

[https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-](https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016)

EXAMPLE Rated luminous flux.

[b11df773f807/iec-60969-2016](https://standards.iteh.ai/catalog/standards/sist/ee55211f-0b9d-4ec3-be13-b11df773f807/iec-60969-2016)

#### 3.4

##### **test voltage**

input voltage at which tests are carried out

[SOURCE: IEC 62612:2013, 3.2, modified – The word "input" has been added.]

#### 3.5

##### **initial value**

photometric and electrical characteristic measured at the end of a 100 h ageing period

#### 3.6

##### **lamp failure**

moment at which the lamp fails to light up, fails to remain alight or delivers low light output (in case of doubt, low light output refers to less than approximately 50 % of rated light output)

#### 3.7

##### **lamp life**

<of an individual lamp> number of operating hours to lamp failure

#### 3.8

##### **median of lamp life**

number of operating hours elapsed at which point 50 % of a representative group of lamps have failed, when operated under specified test conditions

**3.9  
starting time**

time required for a lamp to develop an electrically stable arc discharge, the time being measured from the moment the lamp circuit is energized

**3.10  
run-up time**

time required for a lamp to reach a specified percentage of its (stable) luminous flux, the time being measured from the moment the lamp circuit is energized

**3.11  
displacement factor**

cosine of the phase-angle between the fundamental harmonic current and the mains voltage

Note 1 to entry: Displacement factor is explained in Annex J.

**3.12  
distortion factor**

factor indicating the level of harmonic current distortion

Note 1 to entry: Distortion factor is explained in Annex J.

**3.13  
power factor**

under periodic conditions, ratio of the absolute value of the active power to the apparent power

Note 1 to entry: Alternatively, the power factor is the product of the displacement and distortion factor.

**3.14  
lumen maintenance**

luminous flux at a given time in the life of a lamp divided by the initial luminous flux of the lamp

Note 1 to entry: Lumen maintenance is expressed as a percentage of the initial luminous flux.

**3.15  
lamp type**

lamps that, independent of the type of cap, have identical rated values in relation to the relevant compliance test

**3.16  
lamp stabilization time**

time required for a lamp to reach stable conditions for measurement

**3.17  
type test**

test or series of tests made on a type test sample, for the purpose of checking compliance of the design of a given product with the requirements of the relevant standard

[SOURCE: IEC 60598-1:2014, 1.2.44]

**3.18  
type test sample**

sample consisting of one or more similar units submitted by the manufacturer or responsible vendor for the purpose of a type test

[SOURCE: IEC 60598-1:2014, 1.2.45]

**3.19****luminous efficacy**

quotient of the lamp luminous flux by the lamp power consumption

**3.20****beam angle**

angle between two imaginary lines in a plane through the optical beam axis, such that these lines pass through the centre of the front face of the lamp and through points at which the luminous intensity is 50 % of the centre beam intensity

[SOURCE: IEC TR 61341:2010, 2.4]

**3.21****ageing**

preconditioning of lamps by operating them at controlled conditions for a specified period

**3.22****supplier**

manufacturer, responsible vendor or importer

**3.23****dimnable lamp**

lamp that is capable of producing varying levels of light when paired with a control or dimmer

**3.24****inrush current**

<of lamp> transient current associated with energizing a lamp

**3.25****chromaticity coordinates**

ratio of each of a set of three tristimulus values to their sum

IEC 60969:2016

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

[SOURCE: IEC 60050-845:1987, 845-03-33, modified – The notes have been deleted]

**3.26****correlated colour temperature****CCT**

temperature of the Planckian radiator whose perceived colour most closely resembles that of a given stimulus at the same brightness and under specified viewing conditions

Note 1 to entry: The correlated colour temperature is expressed in K.

Note 2 to entry: This note applies to the French language only.

[SOURCE: IEC 60050-845:1987, 845-03-50, modified – The abbreviated term has been added and the notes have been replaced]

**3.27****colour rendering index****CRI**

measure of the degree to which the psychophysical colour of an object illuminated by the test illuminant conforms to that of the same object illuminated by the reference illuminant, suitable allowance having been made for the state of chromatic adaptation

Note 1 to entry: This note applies to the French language only.

[SOURCE: IEC 60050-845:1987, 845-02-61]

**3.28  
colour code**

3-digit code expressing the rated colour rendering index and the rated correlated colour temperature as described in IEC TR 62732

Note 1 to entry: The light colour designation is detailed in IEC TR 62732.

**4 Marking**

For this performance standard the following data shall be provided (in addition to the mandatory data required by IEC 60968) by the supplier and located as specified in Table 1. The rated values refer to performance claims under the general conditions for measurement as specified in Clause A.1.

**Table 1 – Locations where marking of rated values is required**

Parameter (rated)	Product	Product packaging	Product datasheets or leaflets
a) Initial luminous flux of the lamp (lm) (luminous flux for reflector lamps is under consideration)	-	x	x
b) Beam angle (degrees) and centre beam intensity (cd) measured in accordance with IEC TR 61341 for reflector lamps	-	x	x
c) Initial luminous efficacy (lm/W)	-	-	x
d) Correlated colour temperature (K) For the product a colour code is permissible	x	x	x
e) Colour rendering index For the packaging a colour code is permissible	-	x	x
f) Chromaticity coordinates	-	-	x
g) Median lamp life (h)	-	x	x
h) Lumen maintenance (%) Including operating hours at which lumen maintenance value(s) are claimed	-	-	x
i) Switching withstand (no. of cycles)	-	-	x
j) Special operating requirements e.g. dimming, orientation (base up/down), restricted operating temperature range	-	x	x
k) Starting time (s)	-	-	x
l) Low temperature starting time (s) (and temperature if different from -10 °C)	-	-	x
m) Run-up time (s)	-	x	x
n) Displacement factor	-	-	x
o) Dimensions (mm)	-	-	x
p) Performance claims for different conditions	-	-	x
q) Location of additional information (how to find product datasheets or leaflets)	-	x	-

(x = required, – = not required but optional)

NOTE In Japan, the power factor is used instead of displacement factor and the requirement on colour classification and indication is specified in JIS Z9112.

If equivalence with an incandescent lamp is claimed, the claimed equivalent incandescent lamp power (rounded to 1 W) for lamps with CCT values less than 4 500 K shall be that

corresponding in Table 2 below unless superseded by regional requirements. The intermediate values of both the luminous flux and the claimed incandescent lamp power (rounded to 1 W) shall be calculated by linear interpolation between two adjacent values.

**Table 2 – Equivalency with non-directional incandescent lamps**

Claimed equivalent incandescent lamp power W	(for 220-240 V regions)	(for 110-120 V regions)
	Minimum rated luminous flux lm	Minimum rated luminous flux lm
15	125	
25	229	250
40	432	450
60	741	800
75	970	1 100
100	1 398	1 600
150	2 253	2 550
200	3 172	

## 5 Test conditions

Conditions for testing are given in Annex A.

For lamps with special features for example dimming and daylight sensing, the supplier shall provide advice on how to disable these features in order to test the lamp.

Where applicable, sample sizes and compliance conditions for various requirements are given in Table 3.

Where a supplier claims suitability for operation at different conditions (for instance, at higher voltage, temperature or humidity) then:

- a) lamps shall be tested under claimed different conditions; and
- b) lamps shall start and operate satisfactorily under claimed different conditions; and
- c) lamps shall meet the performance claims under the claimed different conditions, which may differ from the general conditions for measurement specified in Clause A.1.

## 6 Performance criteria: assessment and compliance

### 6.1 General

A lamp, on which compliance with this document is claimed, shall comply with the requirements of IEC 60968.

A lamp shall be designed so that its performance is reliable in normal and accepted use. In general this can be achieved by satisfying the requirements of 6.2.

The requirements and information given apply to 95 % of production.

NOTE It can be expected that the type test samples submitted by the supplier for type test to the requirements and tolerances of this document will, in principle, consist of units having characteristics typical of the manufacturer's production and being as close to the production centre point values as reasonably possible.

It can be expected with the tolerances given in this document that products manufactured in accordance with the type test sample will comply with this document for the majority of production. Due to the production spread

however, it is inevitable that there will sometimes be products outside the specified tolerances. For guidance on sampling plans and procedures for inspection by attributes, refer to ISO 2859 and for inspection by variables refer to ISO 3951.

## 6.2 Performance requirements

Lamps shall be assessed against all the parameters listed in Table 3. Minimum sample sizes for each test are specified in column C, compliance conditions for all parameters and test conditions are listed in column D and column E.

**Table 3 – Sample sizes, compliance criteria and test conditions**

A	B	C	D	E
Row	Parameter for test	Minimum type test sample size	Compliance	Test condition for compliance
1	Initial power	10	Mean measured value shall not exceed 108 % of rated value, and all samples shall measure below 115 % of rated value.	Annex A
2	Displacement factor <sup>a</sup>	10	All samples shall measure equal to or greater than the rated displacement factor value minus 0,05.  NOTE In Japan, the power factor instead of displacement factor is used.	Annex I
3	Distortion factor (harmonics) <sup>a</sup>	10	All samples shall be within limits for harmonics according to IEC 61000-3-2.	IEC 61000-3-2
4	Initial luminous flux	10	Mean measured value shall be greater than or equal to 90 % of rated value, and all samples shall measure greater than or equal to 85 % of rated value.	Annex D
5	Beam angle (reflector lamps)	1	Measured beam angle shall be within ±25 % of rated value.	IEC TR 61341
6	Centre beam intensity (reflector lamps)	1	Mean measured centre beam intensity shall be equal to or greater than 75 % of the rated value.	IEC TR 61341
7	Chromaticity coordinates <sup>b</sup>	10	Chromaticity coordinates of at least 90 % of the samples shall measure less than or equal to 5 SDCM (standard deviation of colour matching) from the rated value.	CIE 015
8	Colour rendering index (CRI)	10	All samples shall measure equal to or greater than the rated CRI value minus 3.	CIE 13.3
9	Starting time	6	Mean measured value shall be less than or equal to 1,5 s, and all samples shall start within 2,0 s.  Mean measured value shall be ≤110% of rated value.	Annex B
10	Low temperature and low supply voltage starting	6	All lamps shall start within the time if specified by the supplier or within 10 s maximum.	Annex E
11	Run-up time	6	The mean measured time, to reach 60% of initial luminous flux, shall be less than or equal to 110 % of the rated time.  All samples shall reach 60% of initial luminous flux within 150 % of the rated time.	Annex C
12	Lumen maintenance	10	Mean measured value(s) shall be equal to or greater than 90 % of the rated value(s).  All samples shall measure equal or greater than 85 % of the rated value(s).	Annex D

A	B	C	D	E
Row	Parameter for test	Minimum type test sample size	Compliance	Test condition for compliance
13	Premature lamp failure rate (if claimed)	10	After the operating hours specified by the supplier have elapsed, the proportion of lamp failures shall be less than or equal to the rated value.	Annex G
14	Lifetime	10 or 20	Assess lifetime based on either of the following tests (Based on Weibull shape factor 3 <sup>c</sup> ):  Test 10 samples to 100 % of rated life Pass if less than or equal to 6 failures Fail if equal or greater than 7 failures. Test 20 samples to 90 % of rated life  Pass if less than or equal to 10 failures Fail if equal or greater than 11 failures.	Annex G
15	Switching withstand	10	Assess switching withstand based on the following test (Based on Weibull shape factor 3 <sup>c</sup> ):  Test 10 samples to the rated number of switching cycles Pass if less than or equal to 6 failures Fail if equal or greater than 7 failures.	Annex F
16	Dimensions	6	All samples shall comply with rated minimum and maximum specifications. Mean measured dimension shall be within 90 % and 110 % of rated value. <sup>d</sup>  If dimensional equivalence with incandescent lamps is claimed then lamps shall comply with IEC 60630.	Physical measurements
17	Inrush current	1	Inrush current shall not exceed given limits	Annex H
18	Performance under different conditions	In accordance with the relevant type test in this table	Claims for performance at different conditions (voltages or temperatures outside of normal conditions, including high humidity) shall be tested under those conditions using the relevant annexes to this document (altering test conditions to suit different conditions). Under these conditions:  a) lamps shall start and operate satisfactorily, and  b) lamps shall meet all performance claims, which may differ from the performance claims under the general conditions for measurement specified in Clause A.1.	In accordance with the relevant type test in this table
NOTE There are local and regional regulations for many of these and other parameters.				
<p><sup>a</sup> The relationship between power factor, displacement and distortion factors are explained in Annex J.</p> <p><sup>b</sup> Preferred rated chromaticity coordinates are the standardised chromaticity coordinates for 2 700 K, 3 000 K, 3 500 K, 4 000 K, 5 000 K and 6 500 K as defined in IEC 60081, Annex D.</p> <p><sup>c</sup> Statistical tools, such as Weibull analysis and parametric fits may be used to estimate median lamp life of the sample.</p> <p><sup>d</sup> Supplier should advise sizes to allow assessment, and these should be clear if maximum or rated dimensions.</p>				