



SLOVENSKI STANDARD
SIST-TP CLC/TR 61804-4:2007
01-december-2007

**Funkcijski bloki (FB) za nadzor procesov - 4. del: Vodilo za interoperabilnost EDD
(IEC/TR 61804-4:2006)**

Function blocks (FB) for process control - Part 4: EDD Interoperability Guideline

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: CLC/TR 61804-4:2007

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbc8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbc8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
-----------	---	---

SIST-TP CLC/TR 61804-4:2007 **en**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

**Function blocks (FB) for process control -
Part 4: EDD interoperability guideline
(IEC/TR 61804-4:2006)**

Blocs fonction
pour les processus industriels -
Partie 4: Recommandations
pour l'interopérabilité EDD
(CEI/TR 61804-4:2006)

Funktionsbausteine
für die Prozessautomation -
Teil 4: Leitfaden für die Interoperabilität
von EDD-Anwendungen
(IEC/TR 61804-4:2006)

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

This Technical Report was approved by CENELEC on 2007-04-09.

[SIST-TP CLC/TR 61804-4:2007](#)

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of the Technical Report IEC/TR 61804-4:2006, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement and control, was submitted to vote and was approved by CENELEC as CLC/TR 61804-4 on 2007-04-09.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the Technical Report IEC/TR 61804-4:2006 was approved by CENELEC as a Technical Report without any modification.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)
<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-351	- ¹⁾	International Electrotechnical Vocabulary (IEV) - Part 351: Automatic control	-	-
IEC 61804-2	2006	Function blocks (FB) for process control - Part 2: Specification of FB concept	EN 61804-2	2007
IEC 61804-3	2006	Function blocks (FB) for process control - Part 3: Electronic device description language (EDDL)	EN 61804-3	2007
ISO/IEC 15948	2004	Information technology - Computer graphics and image processing - Portable Network Graphics (PNG) - Functional specification	-	-

STANDARD PREVIEW
Standards.iteh.ai
[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)
<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

¹⁾ Undated reference.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](#)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

TECHNICAL REPORT

IEC TR 61804-4

First edition
2006-12

Function blocks (FB) for process control –

Part 4: EDD interoperability guideline

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

© IEC 2006 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XA**

For price, see current catalogue

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions, abbreviated terms and acronyms.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms and acronyms.....	8
4 User interface support.....	8
4.1 Overview.....	8
4.2 Menu conventions for applications.....	8
4.3 Menu conventions for PC-based applications.....	8
4.4 Menu conventions for all applications.....	16
4.5 User interface extensions.....	16
4.6 Layout rules.....	21
4.7 Default menu styles.....	29
5 Additional user interface elements.....	30
5.1 Overview.....	30
5.2 Graph and chart.....	31
5.3 IMAGE.....	45
5.4 GRID.....	46
6 EDDL data description.....	47
6.1 Variables.....	47
6.2 EDDL application stored device data.....	48
7 EDDL built-in library.....	57
7.1 User interface built-ins.....	57
Annex A (informative) Technology specific guidance.....	59
Figure 1 – Example of an EDD application for diagnostics.....	13
Figure 2 – Example of an EDD application for process variables.....	14
Figure 3 – Example of an EDD application for primary variables.....	14
Figure 4 – Example of an EDD application for process-related device features.....	15
Figure 5 – Example of an EDD application for device features.....	15
Figure 6 – Example of an EDD application for a variable of type BIT_ENUMERATED.....	20
Figure 7 – Example of an EDD for an overview menu.....	22
Figure 8 – Example of an EDD application for an overview window.....	22
Figure 9 – Example of an EDD using COLUMNBREAK.....	22
Figure 10 – Example of an EDD application for an overview window.....	23
Figure 11 – Example of an EDD application for an overview window.....	23
Figure 12 – Example of an EDD application for an overview window.....	24
Figure 13 – Example of an EDD for in-line graphs and charts.....	24
Figure 14 – Example of an EDD application for an in-line graph.....	25
Figure 15 – Example of an EDD for full-width graphs and charts.....	25

Figure 16 – Example of an EDD application for a full-width graph	26
Figure 17 – Example of an EDD for nested containers	27
Figure 18 – Example of an EDD application for nested containers.....	27
Figure 19 – Example of an EDD for EDIT_DISPLAYS	28
Figure 20 – Example of an EDD application for EDIT_DISPLAYS.....	28
Figure 21 – Example of an EDD for images	29
Figure 22 – Example of an EDD application for images.....	29
Figure 23 – HEIGHT and WIDTH attributes for CHART and GRAPH	31
Figure 24 – EMPHASIS attribute to differentiate one or more SOURCES or WAVEFORMs	32
Figure 25 – Example of a chart with one curve in a dialogue	34
Figure 26 – Graph and the visual elements.....	37
Figure 27 – Result of the EDD example	47
Figure 28 – Example of a file declaration	49
Figure 29 – Example of comparing valve signatures	50
Figure 30 – Example of more complex file declaration	51
Figure 31 – Example of reviewing the stored radar signals.....	52
Table 1 – List of defined menu identifiers	9
Table 2 – List of defined menu identifiers	30
Table 3 – Image formats	45

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FUNCTION BLOCKS (FB) FOR PROCESS CONTROL –

Part 4: EDD interoperability guideline

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example, "state of the art".

Technical reports do not necessarily have to be reviewed until the data they provide are considered to be no longer valid or useful by the maintenance team.

IEC 61804-4, which is a Technical Report, has been prepared by subcommittee 65C: Digital communications, of IEC technical committee 65: Industrial-process measurement and control.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
65C/410/DTR	65C/417/RVC

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all the parts of the IEC 61804 series, under the general title *Function blocks (FB) for process control*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

INTRODUCTION

This Technical Report

- contains an overview of the use of EDDL;
- provides examples demonstrating the use of the EDDL constructs;
- shows how the use cases are fulfilled; and
- shows the proper EDD application interpretation for each example.

This Technical Report is not an EDDL tutorial and is not intended to replace the EDDL specification.

Instructions are provided for the EDD application, which describe what is to be performed without prescribing the technology used in the host implementation. For example, the FILE construct describes data that is to be stored by the EDD application on behalf of the EDD. The FILE construct does not specify how the data is to be stored. The EDD application can use a database, a flat file, or any other implementation it chooses.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST-TP CLC/TR 61804-4:2007](https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007)

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

FUNCTION BLOCKS (FB) FOR PROCESS CONTROL –

Part 4: EDD interoperability guideline

1 Scope

This part of IEC 61804 is a guideline to support EDD interoperability. This Technical Report is intended to ensure that field device developers use the EDDL constructs consistently and that the EDD applications have the same interpretations of the EDD. It supplements the EDDL specification to promote EDDL application interoperability and improve EDD portability between EDDL applications.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-351, *International Electrotechnical Vocabulary (IEV) – Part 351: Automatic control*

IEC 61804-2:2006, *Function blocks (FB) for process control – Part 2: Specification of FB concept*

IEC 61804-3:2006 *Function blocks (FB) for process control – Part 3: Electronic Device Description Language (EDDL)*

<https://standards.iteh.ai/catalog/standards/sist/36d5fcb5-dbe8-4a69-998b-ac98e16d0afb/sist-tp-clc-tr-61804-4-2007>

ISO/IEC 15948:2004, *Information technology – Computer graphics and image processing – Portable Network Graphics (PNG) – Functional specification*

3 Terms, definitions, abbreviated terms and acronyms

3.1 Terms and definitions

For the purposes of this document, some of the terms and definitions in IEC 60050-351, as well as the following, some of which have been compiled from the referenced documents, apply.

3.1.1

EDD developer

individual or team that develops an EDD

3.1.2

EDD application

software or programmes utilizing the EDD to guide the operation of the application

NOTE These applications include configuration tools, calibrators, instrument management packages, and instrument simulators

3.1.3

end user

individual using the field device and/or the EDDL application

3.2 Abbreviated terms and acronyms

CP	Communication Profile
CPF	Communication Profile Family
EDD	Electronic Device Description. A platform and application-independent model or description of a field device written using EDDL. An EDD describes the properties, standard procedures and status associated with a device.
EDDL	Electronic Device Description Language
FF	Fieldbus Foundation; see www.fieldbus.org
HCF	HART® Communication Foundation; see www.hartcomm.org
OPC	Open connectivity; OPC Foundation; see www.opcfoundation.org
PC	Personal computer
PNO	PROFIBUS Nutzerorganisation e.V.; see www.profibus.com

4 User interface support

4.1 Overview

Most EDD applications can be characterized as either a PC application or a hand-held application. Due to the relatively small screen of a hand-held device, hand-held applications can only display a small amount of information at any given time. On the other hand, PC applications can provide a much more beneficial user interface, largely due to their larger screen size.

[SIST-TP CLC/TR 61804-4:2007](https://standards.iso/ai/catalog/standards/sist/3615615-dbe8-4a69-998b-99816d0afb/sist-tr-clc-tr-61804-4-2007)

To support the capabilities of PC applications, the MENU construct has been extended in IEC 61804-3 compared to IEC 61804-2. Due to the differences in the user interfaces of PC applications and hand-held applications, it is expected that many devices will define two MENU hierarchies – one for hand-held applications and the other for PC applications. Some MENUs may be used in both hierarchies. Therefore, the entire hierarchy need not be specified twice.

Different menu structures for different classes of applications are possible. This guideline may be used to create menu structures in an EDD that are interpreted by applications in an unambiguous way. To promote interoperability across applications, it is highly recommended that all EDD applications follow this guideline.

4.2 Menu conventions for applications

There are existing solutions for hand-held application menus and these solutions can be used. This technical report does not provide specific conventions for hand-held applications.

4.3 Menu conventions for PC-based applications

4.3.1 Overview

EDD applications use special menus in the EDDs to show the user interface of the device. Such menus are defined for diagnostic, process variables, device features, and offline configuration. Defined identifiers are defined for the different root menus. Other submenus can be underneath these root menus.

4.3.2 Diagnostic

The diagnostic menu includes views that show the device state, detailed diagnostic information and may include graphical views that show, for example, a valve signature.

4.3.3 Process variables

The process variable menu includes views that show process measurements and set points with their quality and important information for process operators, for example, ranges.

4.3.4 Device features

The device feature menu includes features for device support. These features can be split into process-related and device-specific features. This structure is not required if the number of features is too small for splitting. Submenus that represent any structuring are allowed on the device feature menu. In case of such submenus, the menus that are underneath can be split into process-related and device-specific features.

4.3.5 Offline configuring

This menu hierarchy includes parameters, variables, and methods for offline configuration. It contains, in particular, all of the application-specific parameters of the device and may also contain important read-only and writeable variables. For more information about application-specific parameters, see 4.4. The menu can have offline methods, for example, configuration assistants.

4.3.6 Overview defined identifiers

Table 1 lists defined menu identifiers.

Table 1 – List of defined menu identifiers

Menu Identifier	Short description
diagnostic_root_menu	Diagnostic view
process_variables_root_menu	Process variable views
device_root_menu	Device feature views
offline_root_menu	Menu hierarchy for offline configuration

4.3.7 Example of EDD menu structure

This is an example of additional menus that can be added to an EDD for PC applications. These menus are additional to the existing menus for the applications. This example is HART-specific. Examples for Foundation Fieldbus¹ and PROFIBUS² would be very similar.

```

MENU diagnostic_root_menu
{
    LABEL "Diagnostics";
    STYLE MENU;
    ITEMS
    {
        status_window,          /* menu: style=window */
        self_test              /* method */
    }
}

MENU status_window
{
    LABEL "Status";
    STYLE WINDOW;
    ITEMS
    {
        standard_diagnostics_page, /* menu: style=page */
        devspec_diagnostics_page  /* menu: style=page */
    }
}

```

¹ Communication Profile Family CPF 1 according to IEC 61784-1:2003, *Digital data communications for measurement and control – Part 1: Profile sets for continuous and discrete manufacturing relative to fieldbus use in industrial control systems*.

² CP3/1 and CP3/2 of Communication Profile Family CPF 3 according to IEC 61784-1 (see footnote 3).