



SLOVENSKI STANDARD

SIST EN 50131-2-3:2009

01-januar-2009

Nadomešča:

SIST-TS CLC/TS 50131-2-3:2005

Alarmni sistemi - Sistemi za javljanje vloma in ropa - 2-3. del: Zahteve za mikrovalovne javljalnike

Alarm systems - Intrusion and hold-up systems -- Part 2-3: Requirements for microwave detectors

Alarmanlagen - Einbruch- und Überfallmeldeanlagen -- Teil 2-3: Anforderungen an Mikrowellenmelder

Systemes d'alarme - Systemes d'alarme contre l'intrusion et les hold-up -- Partie 2-3: Exigences pour détecteurs à hyperfréquences

Ta slovenski standard je istoveten z: EN 50131-2-3:2008

ICS:

13.310	Varstvo pred kriminalom	Protection against crime
13.320	Alarmni in opozorilni sistemi	Alarm and warning systems

SIST EN 50131-2-3:2009

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50131-2-3:2009

<https://standards.iteh.ai/catalog/standards/sist/a26cade0-265e-48be-8044-2729d9d3c434/sist-en-50131-2-3-2009>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50131-2-3

September 2008

ICS 13.320

Supersedes CLC/TS 50131-2-3:2004

English version

**Alarm systems -
Intrusion and hold-up systems -
Part 2-3: Requirements for microwave detectors**

Systemes d'alarme -
Systemes d'alarme contre l'intrusion
et les hold-up -
Partie 2-3: Exigences pour detecteurs
à hyperfréquences

Alarmanlagen -
Einbruch- und Überfallmeldeanlagen -
Teil 2-3: Anforderungen
an Mikrowellenmelder

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This European Standard was approved by CENELEC on 2008-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 79, Alarm systems.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50131-2-3 on 2008-05-01.

This European Standard supersedes CLC/TS 50131-2-3:2004.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2009-05-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2011-05-01

EN 50131 will consist of the following parts, under the general title *Alarm systems – Intrusion and hold-up systems*:

Part 1	System requirements
Part 2-2	Intrusion detectors – Passive infrared detectors
Part 2-3	Requirements for microwave detectors
Part 2-4	Requirements for combined passive infrared and microwave detectors
Part 2-5	Requirements for combined passive infrared and ultrasonic detectors
Part 2-6	Intrusion detectors – Opening contacts (magnetic)
Part 2-7-1	Intrusion detectors – Glass break detectors – Acoustic
Part 2-7-2	Intrusion detectors – Glass break detectors – Passive
Part 2-7-3	Intrusion detectors – Glass break detectors – Active
Part 3	Control and indicating equipment
Part 4	Warning devices
Part 5-3	Requirements for interconnections equipment using radio frequency techniques
Part 6	Power supplies
Part 7	Application guidelines
Part 8	Security fog devices

Contents

	Page
Introduction.....	5
1 Scope.....	6
2 Normative references	6
3 Definitions and abbreviations.....	6
3.1 Definitions	6
3.2 Abbreviations	7
4 Functional requirements	7
4.1 Event processing.....	7
4.2 Detection.....	9
4.3 Operational requirements	10
4.4 Immunity to incorrect operation	10
4.5 Tamper security	11
4.6 Electrical requirements.....	12
4.7 Environmental classification and conditions.....	13
5 Marking, identification and documentation	13
5.1 Marking and/or identification.....	13
5.2 Documentation	13
6 Testing	14
6.1 General test conditions.....	14
6.2 Basic detection test	15
6.3 Walk testing	15
6.4 Switch-on delay, time interval between signals and indication of detection	18
6.5 Self tests	18
6.6 Immunity to incorrect operation	18
6.7 Tamper security	18
6.8 Electrical tests.....	20
6.9 Environmental classification and conditions.....	22
6.10 Marking, identification and documentation	23
Annex A (normative) Dimensions & requirements of the standardised test magnets.....	24
Annex B (normative) General testing matrix.....	27
Annex C (informative) Walk test diagrams	28
Annex D (informative) Equipment for walk test velocity control.....	31
Annex E (informative) Immunity to microwave signal interference by fluorescent lights	32
Annex F (informative) Example list of small tools	33
Annex G (normative) Test for resistance to re-orientation of adjustable mountings	34
Bibliography.....	35

Figures

Figure A.1 – Test magnet - Magnet Type 1	25
Figure A.2 – Test magnet - Magnet Type 2	26
Figure C.1 – Detection across the boundary	28
Figure C.2 – Detection within the boundary.....	28
Figure C.3 – High velocity and intermittent movement.....	29
Figure C.4 – Close-in detection.....	29
Figure C.5 – Significant range reduction	30
Figure E.1 – Immunity to fluorescent lamp interference.....	32
Figure G.1 – Re-orientation test.....	34

Tables

Table 1 – Events to be processed by grade	8
Table 2 – Generation of signals or messages	8
Table 3 – General walk test velocity and attitude requirements	9
Table 4 – Tamper security requirements	12
Table 5 – Electrical requirements	12
Table 6 – Range of materials for masking tests	20
Table 7 – Operational tests.....	23
Table 8 – Endurance tests	23

SIST EN 50131-2-3:2009
<https://standards.iteh.ai/catalog/standards/sist/a26cade0-265e-48be-8044-2729d9d3c434/sist-en-50131-2-3-2009>

Introduction

This standard deals with microwave detectors (to be referred to as the detector) used as part of intrusion alarm systems installed in buildings. It includes four security grades and four environmental classes.

The purpose of a detector is to emit microwave radiation and analyse returned signals to detect an intruder and to provide the necessary range of signals or messages to be used by the rest of the intrusion alarm system.

The number and scope of these signals or messages will be more comprehensive for systems that are specified at the higher grades.

This specification is only concerned with the requirements and tests for the detector. Other types of detector are covered by other documents identified as EN 50131-2 series.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 50131-2-3:2009](https://standards.iteh.ai/catalog/standards/sist/a26cade0-265e-48be-8044-2729d9d3c434/sist-en-50131-2-3-2009)

<https://standards.iteh.ai/catalog/standards/sist/a26cade0-265e-48be-8044-2729d9d3c434/sist-en-50131-2-3-2009>

1 Scope

This European Standard is for microwave detectors installed in buildings and provides for security grades 1 to 4 (see EN 50131-1), specific or non-specific wired or wire-free detectors, and uses environmental classes I to IV (see EN 50130-5). This standard does not include requirements for microwave detectors intended for use outdoors.

A detector shall fulfil all the requirements of the specified grade.

Functions additional to the mandatory functions specified in this standard may be included in the detector, providing they do not influence the correct operation of the mandatory functions.

The standard does not apply to system interconnections.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50130-4	Alarm systems – Part 4: Electromagnetic compatibility – Product family standard: Immunity requirements for components of fire, intruder and social alarm systems
EN 50130-5	Alarm systems – Part 5: Environmental test methods
EN 50131-1	Alarm systems – Intrusion and hold-up systems – Part 1: System requirements
EN 50131-6	Alarm Systems – Intrusion and hold-up systems – Part 6: Power supplies
EN 60068-1	Environmental testing – Part 1: General and guidance (IEC 60068-1)
EN 60068-2-52	Environmental testing – Part 2: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution) (IEC 60068-2-52)

3 Definitions and abbreviations

For the purposes of this document, the following terms and definitions apply in addition to those given in EN 50131-1.

3.1 Definitions

3.1.1

basic detection target

microwave reflector designed to verify the operation of a detector

3.1.2

incorrect operation

physical condition that causes an inappropriate signal or message from a detector

3.1.3

masking

interference with the detector input capability by the introduction of a physical barrier such as metal, plastics, paper or sprayed paints or lacquers in close proximity to the detector

3.1.4**microwave detector**

detector having an active microwave emitter and receiver installed in the same casing

3.1.5**simulated walk test target**

non-human or synthetic microwave reflector designed to simulate the standard walk test target

3.1.6**standard walk test target**

human being of standard weight and height clothed in close fitting clothing appropriate to the simulation of an intruder

3.1.7**walk test**

operational test during which a detector is stimulated by the standard walk test target in a controlled environment

3.1.8**walk test attitude, crawling**

crawling attitude shall consist of the standard walk test target moving with hands and knees in contact with the floor

3.1.9**walk test attitude, upright**

upright attitude shall consist of the standard walk test target standing and walking with arms by the sides of the body. The standard walk test target begins and ends a traverse with feet together

3.2 Abbreviations

HDPE

High Density PolyEthylene

EMC

ElectroMagnetic Compatibility

SWT

Standard Walk-test Target

BDT

Basic Detection Target

FOV

Field Of View

4 Functional requirements**4.1 Event processing**

Detectors shall process the events shown in Table 1. Detectors shall generate signals or messages as shown in Table 2.

Table 1 – Events to be processed by grade

Event	Grade			
	1	2	3	4
Intrusion detection	M	M	M	M
Tamper detection	Op	M	M	M
Masking detection	Op	Op	M	M
Significant reduction of range	Op	Op	Op	M
Low supply voltage	Op	Op	M	M
Total loss of power supply	Op	M	M	M
Local self test	Op	Op	M	M
Remote self test	Op	Op	Op	M
M = Mandatory Op = Optional				

Table 2 – Generation of signals or messages

Event	Signals or messages		
	Intrusion	Tamper	Fault
No event	NP	NP	NP
Intrusion	M	NP	NP
Tamper	NP	M	NP
Masking ^a	M	Op	M
Significant reduction of range ^a	M	Op	M
Low supply voltage	Op	Op	M
Total loss of power supply ^b	M	Op	Op
Local self test pass	NP	NP	NP
Local self test fail	NP	NP	M
Remote self test pass	M	NP	NP
Remote self test fail	NP	NP	M
M = Mandatory NP = Not Permitted Op = Optional NOTE 1 This permits two methods of signalling a masking or reduction of range event: either by the intrusion signal and fault signal, or by a dedicated masking or reduction of range signal or message. Use of the intrusion signal and fault signal is preferable, as this requires fewer connections between CIE and detector. If multiple events overlap there will be some signal combinations that may be ambiguous. To overcome this ambiguity it is suggested that detectors should not signal 'intrusion' and 'fault' at the same time except to indicate masking. This implies that the detector should prioritise signals, e.g. 1 Intrusion, 2 Fault, 3 Masking. NOTE 2 When, in Table 1, an event may optionally generate signals or messages, they shall be as shown in this table. NOTE 3 It is accepted that a bus system may send out dedicated signals or messages and does not necessarily have to follow the mapping of Table 2 provided that all of the required events are signalled.			
^a An independent signal or message may be provided instead.			
^b Alternatively total loss of power supply shall be determined by loss of communication with the detector.			

4.2 Detection

4.2.1 Detection performance

The detector shall generate an intrusion signal or message when the standard or simulated walk-test target moves at velocities and attitudes specified in Table 3. For detection across the boundary the walk-test distance shall be 1,5 m either side of the boundary. For detection within the boundary the walk-test distance shall be 3,0 m.

Table 3 – General walk test velocity and attitude requirements

Test	Grade 1	Grade 2	Grade 3	Grade 4
Detection across the boundary	Required	Required	Required	Required
Velocity	1,0 ms ⁻¹	1,0 ms ⁻¹	1,0 ms ⁻¹	1,0 ms ⁻¹
Attitude	Upright	Upright	Upright	Upright
Detection within the boundary	Required	Required	Required	Required
Velocity	0,3 ms ⁻¹	0,3 ms ⁻¹	0,2 ms ⁻¹	0,1 ms ⁻¹
Attitude	Upright	Upright	Upright	Upright
Detection at high velocity	Not required	Required	Required	Required
Velocity	N/A	2,0 ms ⁻¹	2,5 ms ⁻¹	3,0 ms ⁻¹
Attitude	N/A	Upright	Upright	Upright
Close-in detection performance	Required	Required	Required	Required
Distance	2,0 m	2,0 m	0,5 m	0,5 m
Velocity	0,5 ms ⁻¹	0,4 ms ⁻¹	0,3 ms ⁻¹	0,2 ms ⁻¹
Attitude	Upright	Upright	Crawling	Crawling
Intermittent movement detection performance^a	Not required	Not required	Required	Required
Velocity	N/A	N/A	1,0 ms ⁻¹	1,0 ms ⁻¹
Attitude	N/A	N/A	Upright	Upright
Significant reduction of specified range^b	Not required	Not required	Not required	Required
Velocity	N/A	N/A	N/A	1,0 ms ⁻¹
Attitude	N/A	N/A	N/A	Upright
<p>^a For grade 3 and 4 detectors, the intermittent movement shall consist of the SWT walking 1 m at a velocity of 1,0 ms⁻¹ then pausing for 5 s before continuing. The sequence shall be maintained until the SWT has traversed through the entire detection area. This constitutes one walk test. The test shall be repeated in each of the directions shown in Figure C.3.</p> <p>^b The means to detect a significant reduction in range may be met either by detectors having the appropriate function (4.2.3) or by suitable system design. Two or more devices (e.g. a detector in conjunction with a camera, active transmitter or additional detector), may cooperate and interconnect with the system to provide means to detect a significant reduction of range.</p>				

4.2.2 Indication of detection

An indicator shall be provided at the detector to indicate when an intrusion signal or message has been generated. At grades 1 and 2 this indicator shall be capable of being enabled and disabled either remotely at Access Level 2 and/or locally after removal of a cover which provides tamper detection as described in Tables 1 and 4. At grades 3 and 4 this indicator shall be capable of being enabled and disabled remotely at Access Level 2.

4.2.3 Significant reduction of range

Grade 4 detectors shall detect significant reduction of range or coverage area due, for example, to deliberate or accidental introduction of objects or obstructions into the coverage area.

Range reduction along the principal axis of detection of more than 50 % shall generate a signal or message within 180 s, according to the requirements of Table 2 and Table 3.

If additional equipment is required to detect significant reduction of range, reference shall be made to this equipment and its operation in the manufacturer's documentation.

4.3 Operational requirements

4.3.1 Time interval between intrusion signals or messages

Detectors using wired interconnections shall be able to provide an intrusion signal or message not more than 15 s after the end of the preceding intrusion signal or message.

Detectors using wire free interconnections shall be able to provide an intrusion signal or message after the end of the preceding intrusion signal or message within the following times:

- Grade 1 300 s;
- Grade 2 180 s;
- Grade 3 30 s;
- Grade 4 15 s.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

4.3.2 Switch on delay

[SIST EN 50131-2-3:2009](#)

<https://standards.iteh.ai/catalog/standards/sist/a26cade0-265e-48be-8044-17259c45706c/en-50131-2-3-2009>

The detector shall meet all functional requirements within 180 s of the power supply reaching its nominal voltage as specified by the manufacturer.

4.3.3 Self tests

4.3.3.1 Local self test

The detector shall automatically test itself at least once every 24 h according to the requirements of Tables 1 and 2. If normal operation of the detector is inhibited during a local self-test, the detector inhibition time shall be limited to a maximum of 30 s in any period of 2 h.

4.3.3.2 Remote self test

A detector shall process remote self tests and generate signals or messages in accordance with Tables 1 and 2 within 10 s of the remote self test signal being received, and shall return to normal operation within 30 s of the remote test signal being received.

4.4 Immunity to incorrect operation

The detector shall be considered to have sufficient immunity to incorrect operation if the following requirements have been met. No intrusion signal or message shall be generated during the tests.

4.4.1 Immunity to microwave signal interference by fluorescent lights

The detector shall not generate any signals or messages due to the operation of a fluorescent light source mounted nearby.