

**IEC 61892-2**  
**(Second edition – 2012)**

**Mobile and fixed offshore units – Electrical installations –**

**Part 2: System design**

**CORRIGENDUM 1**

**4.2.6.**

*Delete the Note.*

*Replace the existing text in this clause with the following new text:*

If main power is supplied externally, the arrangement is to be such that the requirement of 4.2.3 b) is met by a local generator, or alternatively a second independent external supply. The local generator shall not be the emergency generator.

iTech Standards  
(<https://standards.iteh.ai>)  
Document Preview

[IEC 61892-2:2012/COR1:2013](https://standards.iteh.ai/catalog/standards/iec/1513d384-d71d-40e2-b95a-738bf97a658c/iec-61892-2-2012-cor1-2013)

<https://standards.iteh.ai/catalog/standards/iec/1513d384-d71d-40e2-b95a-738bf97a658c/iec-61892-2-2012-cor1-2013>