



**SLOVENSKI STANDARD**  
**SIST EN 60598-2-22:2000/A2:2008**  
**01-julij-2008**

---

**Svetilke - 2-22. del: Posebne zahteve - Svetilke za nujnostno razsvetljavo (IEC 60598-2-22:1997/A2:2008)**

Luminaires - Part 2-22: Particular requirements - Luminaires for emergency lighting (IEC 60598-2-22:1997/A2:2008)

Leuchten - Teil 2-22: Besondere Anforderungen - Leuchten für Notbeleuchtung (IEC 60598-2-22:1997/A2:2008)

Luminaires - Partie 2-22: Regles particulieres - Luminaires pour éclairage de secours (CEI 60598-2-22:1997/A2:2008)

**ITh STANDARD PREVIEW**  
**(standards.iteh.ai)**  
<https://standards.iteh.ai/catalog/standards/sist/3511846f-b8a0-4fb3-bfd8-dd24e7e395de/sist-en-60598-2-22-2000-a2-2008>

**Ta slovenski standard je istoveten z: EN 60598-2-22:1998/A2:2008**

---

**ICS:**

29.140.40      Svetila      Luminaires

**SIST EN 60598-2-22:2000/A2:2008      en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 60598-2-22:2000/A2:2008

<https://standards.iteh.ai/catalog/standards/sist/3511846f-b8a0-4fb3-bfd8-dd24e7e395de/sist-en-60598-2-22-2000-a2-2008>

English version

**Luminaire -  
Part 2-22: Particular requirements -  
Luminaire for emergency lighting  
(IEC 60598-2-22:1997/A2:2008)**

Luminaire -  
Partie 2-22: Règles particulières -  
Luminaire pour éclairage de secours  
(CEI 60598-2-22:1997/A2:2008)

Leuchten -  
Teil 2-22: Besondere Anforderungen -  
Leuchten für Notbeleuchtung  
(IEC 60598-2-22:1997/A2:2008)

**iTeh STANDARD PREVIEW**

This amendment A2 modifies the European Standard EN 60598-2-22:1998; it was approved by CENELEC on 2008-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 34D/883/FDIS, future amendment 2 to IEC 60598-2-22:1997, prepared by SC 34D, Luminaires, of IEC TC 34, Lamps and related equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A2 to EN 60598-2-22:1998 on 2008-03-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2008-12-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2011-03-01

---

## Endorsement notice

The text of amendment 2:2008 to the International Standard IEC 60958-2-22:1997 was approved by CENELEC as an amendment to the European Standard without any modification.

---

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 60598-2-22:2000/A2:2008

<https://standards.iteh.ai/catalog/standards/sist/3511846f-b8a0-4fb3-bfd8-dd24e7e395de/sist-en-60598-2-22-2000-a2-2008>

## Annex ZB (informative)

### A-deviations

**A-deviation:** National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC member.

This European Standard falls under Directive 2006/95/EC.

NOTE (from CEN/CENELEC IR Part 2:2006, 2.17) Where standards fall under EC Directives, it is the view of the Commission of the European Communities (OJ No C 59, 1982-03-09) that the effect of the decision of the Court of Justice in case 815/79 Cremonini/Vrankovich (European Court Reports 1980, p. 3583) is that compliance with A-deviations is no longer mandatory and that the free movement of products complying with such a standard should not be restricted except under the safeguard procedure provided for in the relevant Directive.

A-deviations in an EFTA-country are valid instead of the relevant provisions of the European Standard in that country until they have been removed.

**Replace the existing A-deviations by the following:**

<u>Clause</u>	<u>Deviation</u>
22.5.18 and 22.10.1	<b>France</b> (Arrêté relatif à la sécurité dans les établissements recevant du public – Article EL 10 § 1).  In premises open to the public, electrical installations shall have only permanent fittings.
22.6.6 and 22.3.7	<b>France</b> (Règlement de sécurité contre les risques d'incendie et de panique dans les établissements recevant du public - Article EC 5 § 3).  The lamps for general purpose lighting and the lamps for emergency lighting shall be inserted in separate luminaires.
22.15	<b>France</b> (Règlement de sécurité contre les risques d'incendie et de panique dans les établissements recevant du public - Article EC 5 § 2).  The external parts of fixed or suspended luminaires shall also withstand the glow wire test at 850 °C.
22.16.2 and 22.16.3	<b>France</b> (Règlement de sécurité contre les risques d'incendie et de panique dans les établissements recevant du public - Articles EC 9 et EC 10).  Characteristics of the products are only based on the rated lumen output and therefore photometric characteristics of the luminaire may not to be provided, or checked.

---

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 60598-2-22:2000/A2:2008

<https://standards.iteh.ai/catalog/standards/sist/3511846f-b8a0-4fb3-bfd8-dd24e7e395de/sist-en-60598-2-22-2000-a2-2008>



# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

AMENDMENT 2  
AMENDEMENT 2

Luminaires – **iTeh STANDARD PREVIEW**  
Part 2-22: Particular requirements – Luminaires for emergency lighting  
(standards.iteh.ai)

Luminaires – **SIST EN 60598-2-22:2000/A2:2008**  
Partie 2-22: Règles particulières – Luminaires pour éclairage de secours  
<http://standards.iteh.ai/catalog/standards/sist/60598-2-22-2000-a2-2008/dd24e7e395de/sist-en-60598-2-22-2000-a2-2008>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

C

## FOREWORD

This amendment has been prepared by subcommittee 34D: Luminaires, of IEC technical committee 34:Lamps and related equipment.

The text of this amendment is based on the following documents:

FDIS	Report on voting
34D/883/FDIS	34D/887/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

Page 13

### 22.5 Marking

Replace the existing first paragraph with the following: [SIST EN 60598-2-22:2000/A2:2008](http://standards.iteh.ai/catalog/standards/sist-en-60598-2-22-2000-a2-2008)  
<http://standards.iteh.ai/catalog/standards/sist-en-60598-2-22-2000-a2-2008>

The provisions of section 3 of IEC 60598-1 shall apply together with the requirements of 22.5.1 to 22.5.20 below.

#### 22.5.3

*Replace the existing note with:*

NOTE The information relating to correct lamp replacement may include the number, type, rated voltage and rated wattage, etc. Luminaires containing non-replaceable lamp(s) need not meet this subclause.

#### 22.5.7

*Add the following after the existing paragraph:*

NOTE Luminaires containing non-replaceable battery need not meet this subclause.

For luminaires with non-replaceable batteries, such information shall be provided in a label to be observed during installation, according to 3.2b) of IEC 60598-1.

Page 15

#### 22.5.10

*Replace the existing text with:*

In the instruction leaflet supplied with the self-contained emergency luminaire, the manufacturer shall state that the replacement of the battery or of the whole luminaire (if having non-replaceable lamp(s) and/or battery) is needed when they no longer meet their rated duration of operation.