

---

**Električni rotacijski stroji - 1. del: Nazivni podatki in preskus lastnosti**

Rotating electrical machines - Part 1: Rating and performance

Drehende elektrische Maschinen - Teil 1: Bemessung und Betriebsverhalten

Machines électriques tournantes - Partie 1: Caractéristiques assignées et caractéristiques de fonctionnement

(standards.iteh.ai)

**Ta slovenski standard je istoveten z: IEC 60034-1 Ed. 13.0**

<https://standards.iteh.ai/catalog/standards/sist/2afc416d-d2bc-42c1-b128-5bba304b15d0/sist-iec-60034-1-2019>

**ICS:**

|           |                              |                               |
|-----------|------------------------------|-------------------------------|
| 29.160.01 | Rotacijski stroji na splošno | Rotating machinery in general |
|-----------|------------------------------|-------------------------------|

**SIST IEC 60034-1:2019****en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST IEC 60034-1:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/2afc416d-d2bc-42c1-b128-5bba304bf5d0/sist-iec-60034-1-2019>



# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

Rotating electrical machines –  
Part 1: Rating and performance

Machines électriques tournantes –  
Partie 1: Caractéristiques assignées et caractéristiques de fonctionnement

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.160.01

ISBN 978-2-8322-4210-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

|  |    |
|--|----|
| FOREWORD .....   | 6  |
| 1 Scope .....  | 9  |
| 2 Normative references .....   | 9  |
| 3 Terms and definitions .....  | 10 |
| 4 Duty .....   | 15 |
| 4.1 Declaration of duty .....  | 15 |
| 4.2 Duty types .....   | 16 |
| 4.2.1 Duty type S1 – Continuous running duty .....   | 16 |
| 4.2.2 Duty type S2 – Short-time duty .....   | 17 |
| 4.2.3 Duty type S3 – Intermittent periodic duty .....  | 17 |
| 4.2.4 Duty type S4 – Intermittent periodic duty with starting .....                              | 18 |
| 4.2.5 Duty type S5 – Intermittent periodic duty with electric braking .....                      | 20 |
| 4.2.6 Duty type S6 – Continuous operation periodic duty .....                                    | 21 |
| 4.2.7 Duty type S7 – Continuous operation periodic duty with electric braking .....              | 22 |
| 4.2.8 Duty type S8 – Continuous operation periodic duty with related<br>load/speed changes ..... | 22 |
| 4.2.9 Duty type S9 – Duty with non-periodic load and speed variations .....                      | 24 |
| 4.2.10 Duty type S10 – Duty with discrete constant loads and speeds .....                        | 24 |
| 5 Rating .....   | 26 |
| 5.1 Assignment of rating .....   | 26 |
| 5.2 Classes of rating .....  | 26 |
| 5.2.1 Rating for continuous running duty .....   | 26 |
| 5.2.2 Rating for short-time duty .....   | 26 |
| 5.2.3 Rating for periodic duty .....   | 26 |
| 5.2.4 Rating for non-periodic duty .....   | 27 |
| 5.2.5 Rating for duty with discrete constant loads and speeds .....                              | 27 |
| 5.2.6 Rating for equivalent loading .....  | 27 |
| 5.3 Selection of a class of rating .....   | 27 |
| 5.4 Allocation of outputs to class of rating .....   | 28 |
| 5.5 Rated output .....   | 28 |
| 5.5.1 DC generators .....  | 28 |
| 5.5.2 AC generators .....  | 28 |
| 5.5.3 Motors .....   | 28 |
| 5.5.4 Synchronous condensers .....   | 28 |
| 5.6 Rated voltage .....  | 28 |
| 5.6.1 DC generators .....  | 28 |
| 5.6.2 AC generators .....  | 29 |
| 5.7 Co-ordination of voltages and outputs .....  | 29 |
| 5.8 Machines with more than one rating .....   | 29 |
| 6 Site conditions .....  | 29 |
| 6.1 General .....  | 29 |
| 6.2 Altitude .....   | 29 |
| 6.3 Maximum ambient air temperature .....  | 29 |
| 6.4 Minimum ambient air temperature .....  | 30 |
| 6.5 Water coolant temperature .....  | 30 |
| 6.6 Standstill, storage and transport .....  | 30 |

|        |  |    |
|--------|--|----|
| 6.7    | Purity of hydrogen coolant .....   | 30 |
| 7      | Electrical operating conditions .....  | 30 |
| 7.1    | Electrical supply.....   | 30 |
| 7.2    | Form and symmetry of voltages and currents .....   | 31 |
| 7.2.1  | AC motors .....  | 31 |
| 7.2.2  | AC generators .....  | 32 |
| 7.2.3  | Synchronous machines.....  | 32 |
| 7.2.4  | DC motors supplied from static power converters .....  | 33 |
| 7.3    | Voltage and frequency variations during operation .....  | 34 |
| 7.4    | Three-phase a.c. machines operating on unearthed systems .....   | 36 |
| 7.5    | Voltage (peak and gradient) withstand levels .....   | 36 |
| 8      | Thermal performance and tests .....  | 37 |
| 8.1    | Thermal class .....  | 37 |
| 8.2    | Reference coolant.....   | 37 |
| 8.3    | Conditions for thermal tests .....   | 38 |
| 8.3.1  | Electrical supply .....  | 38 |
| 8.3.2  | Temperature of machine before test .....   | 38 |
| 8.3.3  | Temperature of coolant.....  | 38 |
| 8.3.4  | Measurement of coolant temperature during test .....   | 38 |
| 8.4    | Temperature rise of a part of a machine.....   | 39 |
| 8.5    | Methods of measurement of temperature .....  | 39 |
| 8.5.1  | General .....  | 39 |
| 8.5.2  | Resistance method .....  | 39 |
| 8.5.3  | Embedded temperature detector (ETD) method .....   | 39 |
| 8.5.4  | Thermometer method .....   | 39 |
| 8.6    | Determination of winding temperature.....  | 39 |
| 8.6.1  | Choice of method .....   | 39 |
| 8.6.2  | Determination by resistance method .....   | 40 |
| 8.6.3  | Determination by ETD method .....  | 42 |
| 8.6.4  | Determination by thermometer method .....  | 42 |
| 8.7    | Duration of thermal tests .....  | 43 |
| 8.7.1  | Rating for continuous running duty .....   | 43 |
| 8.7.2  | Rating for short-time duty .....   | 43 |
| 8.7.3  | Rating for periodic duty.....  | 43 |
| 8.7.4  | Ratings for non-periodic duty and for duty with discrete constant loads .....  | 43 |
| 8.8    | Determination of the thermal equivalent time constant for machines of duty type S9 .....   | 43 |
| 8.9    | Measurement of bearing temperature.....  | 43 |
| 8.10   | Limits of temperature and of temperature rise .....  | 44 |
| 8.10.1 | General .....  | 44 |
| 8.10.2 | Indirect cooled windings .....   | 44 |
| 8.10.3 | Direct cooled windings.....  | 49 |
| 8.10.4 | Adjustments to take account of hydrogen purity on test .....   | 50 |
| 8.10.5 | Permanently short-circuited windings, magnetic cores and all structural components (other than bearings) whether or not in contact with insulation ..... | 50 |
| 8.10.6 | Commutators and sliprings, open or enclosed and their brushes and brushgear .....  | 50 |
| 9      | Other performance and tests .....  | 52 |

|        |  |    |
|--------|--|----|
| 9.1    | Routine tests.....   | 52 |
| 9.2    | Withstand voltage test.....  | 53 |
| 9.3    | Occasional excess current .....  | 55 |
| 9.3.1  | General .....  | 55 |
| 9.3.2  | Generators .....   | 56 |
| 9.3.3  | Motors (except commutator motors and permanent magnet motors) .....  | 56 |
| 9.3.4  | Commutator machines .....  | 56 |
| 9.4    | Momentary excess torque for motors .....   | 56 |
| 9.4.1  | Polyphase induction motors and d.c. motors .....   | 56 |
| 9.4.2  | Polyphase synchronous motors .....   | 57 |
| 9.4.3  | Other motors .....   | 57 |
| 9.5    | Pull-up torque .....   | 57 |
| 9.6    | Safe operating speed of cage induction motors .....  | 57 |
| 9.7    | Overspeed .....  | 58 |
| 9.8    | Short-circuit current for synchronous machines.....  | 59 |
| 9.9    | Short-circuit withstand test for synchronous machines .....  | 59 |
| 9.10   | Commutation test for commutator machines.....  | 60 |
| 9.11   | Total harmonic distortion ( <i>THD</i> ) for synchronous machines .....  | 60 |
| 9.11.1 | General .....  | 60 |
| 9.11.2 | Limits .....   | 60 |
| 9.11.3 | Tests .....  | 60 |
| 10     | Rating plates .....  | 60 |
| 10.1   | General.....   | 60 |
| 10.2   | Marking.....   | 61 |
| 11     | Miscellaneous requirements.....  | 62 |
| 11.1   | Protective earthing of machines.....   | 62 |
| 11.2   | Shaft-end key(s) .....   | 64 |
| 12     | Tolerances .....   | 64 |
| 12.1   | General.....   | 64 |
| 12.2   | Tolerances on values of quantities .....   | 64 |
| 13     | Electromagnetic compatibility (EMC) .....  | 66 |
| 13.1   | General.....   | 66 |
| 13.2   | Immunity.....  | 66 |
| 13.2.1 | Machines not incorporating electronic circuits.....  | 66 |
| 13.2.2 | Machines incorporating electronic circuits.....  | 67 |
| 13.3   | Emission .....   | 67 |
| 13.4   | Immunity tests .....   | 67 |
| 13.5   | Emission measurements .....  | 67 |
| 14     | Safety.....  | 67 |
|        | Annex A (informative) Guidance for the application of duty type S10 and for establishing the value of relative thermal life expectancy <i>TL</i> ..... | 69 |
|        | Annex B (informative) Electromagnetic compatibility (EMC) limits .....   | 70 |
|        | Bibliography.....  | 71 |
|        | Figure 1 – Continuous running duty – Duty type S1.....   | 16 |
|        | Figure 2 – Short-time duty – Duty type S2.....   | 17 |
|        | Figure 3 – Intermittent periodic duty – Duty type S3.....  | 18 |
|        | Figure 4 – Intermittent periodic duty with starting – Duty type S4 .....   | 19 |

|   |    |
|---|----|
| Figure 5 – Intermittent periodic duty with electric braking – Duty type S5 .....  | 20 |
| Figure 6 – Continuous operation periodic duty – Duty type S6 .....  | 21 |
| Figure 7 – Continuous operation periodic duty with electric braking – Duty type S7 .....  | 22 |
| Figure 8 – Continuous operation periodic duty with related load/speed changes – Duty type S8 .....  | 23 |
| Figure 9 – Duty with non-periodic load and speed variations – Duty type S9 .....  | 24 |
| Figure 10 – Duty with discrete constant loads – Duty type S10 .....   | 26 |
| Figure 11 – Voltage and frequency limits for generators.....  | 36 |
| Figure 12 – Voltage and frequency limits for motors.....  | 36 |
|   |    |
| Table 1 – Preferred voltage ratings .....   | 29 |
| Table 2 – Unbalanced operating conditions for synchronous machines .....  | 33 |
| Table 3 – CCC symbol designation.....   | 34 |
| Table 4 – Primary functions of machines.....  | 35 |
| Table 5 – Reference coolant (see also Table 11) .....   | 37 |
| Table 6 – Time interval .....   | 41 |
| Table 7 – Measuring points.....   | 44 |
| Table 8 – Limits of temperature rise of windings indirectly cooled by air.....  | 46 |
| Table 9 – Limits of temperature rise of windings indirectly cooled by hydrogen .....  | 47 |
| Table 10 – Adjustments to limits of temperature rise at the operating site of indirect cooled windings to take account of non-reference operating conditions and ratings .....                | 48 |
| Table 11 – Assumed maximum ambient temperature.....   | 49 |
| Table 12 – Adjusted limits of temperature rise at the test site ( $\Delta\theta_T$ ) for windings indirectly cooled by air to take account of test site operating conditions .....            | 50 |
| Table 13 – Limits of temperature of directly cooled windings and their coolants .....   | 51 |
| Table 14 – Adjustments to limits of temperature at the operating site for windings directly cooled by air or hydrogen to take account of non-reference operating conditions and ratings ..... | 51 |
| Table 15 – Adjusted limits of temperature at the test site $\theta_T$ for windings directly cooled by air to take account of test site operating conditions .....                             | 52 |
| Table 16 – Minimum routine tests for machines assembled and tested in the factory of the manufacturer.....  | 53 |
| Table 17 – Withstand voltage tests .....  | 54 |
| Table 18 – Maximum safe operating speed ( $\text{min}^{-1}$ ) of three-phase single-speed cage induction motors for voltages up to and including 1 000 V.....                                 | 58 |
| Table 19 – Overspeeds .....   | 59 |
| Table 20 – Cross-sectional areas of earthing conductors .....   | 64 |
| Table 21 – Schedule of tolerances on values of quantities .....   | 65 |
| Table B.1 – Electromagnetic emission limits per CISPR 11 Class B Group 1.....   | 70 |
| Table B.2 – Electromagnetic emission limits per CISPR 11 Class A Group 1.....   | 70 |

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## ROTATING ELECTRICAL MACHINES –

## Part 1: Rating and performance

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60034-1 has been prepared by IEC technical committee 2: Rotating machinery.

This thirteenth edition cancels and replaces the twelfth edition published in 2010. It constitutes a technical revision.



The main technical changes with regard to the previous edition are as follows:

| Clause or subclause | Change  |
|---------------------|---|
| 3.25                | Shorter time to thermal equilibrium   |
| 5.5.2               | Note on P-Q capability diagram for synchronous generators   |
| 6.4                 | Clarification added that other conditions can be agreed on  |
| 6.6                 | Clarification added that standstill is explicitly included; note added  |
| 7.1                 | Clarification on bus transfer or fast reclosing<br>Capability to withstand impulse voltages in case of machines connected to a U converter  |
| 7.2.4               | New Table 3 for identification code   |
| 7.3                 | Table 4 corrected to reflect current scope of IEC 60034-3   |
| 7.5                 | Voltage withstand level for machines connected to a converter   |
| 8.3.4               | Measurement of ambient air temperature in case of open machines   |
| 8.6.3.4             | Notes on ETD in the end windings of high voltage machines and on ETD use to monitor strand blockage in case of directly liquid cooled windings  |
| 8.10                | Clarification on temperature limit<br>Clarification on temperature difference between method R and method ETD<br>Clarification that temperature limit acc. to method R must always be kept<br>Note on measured temperature limits between methods R and ETD<br>Table 8 and Table 11 extended incorporating thermal class 200 (N)<br>Line 4c) of Table 8 restricted to field windings of DC machines<br>Temperature limits in Table 8 changed according to 2/1737/DC and the comments received on this document<br>Physically correct formula in Table 10, item 1b |
| 9.1                 | Clarification on machines that are subject to routine testing   |
| 9.2                 | Separate withstand voltage testing of phases<br>Clarification on frequency and time instant for withstand voltage test<br>Note on leakage current during withstand voltage test<br>Note referring to IEC 60027  |
| 10.2                | Information on IVIC on rating plate or in documentation<br>Clarification added to item f<br>IC code and design letter for locked-rotor apparent power on rating plate   |
| 11.1                | Clarification on cross-sectional area of earthing conductor for generators<br>Note on grounding for small machines added  |
| 12.2                | Tolerance on field current of synchronous machines added<br>Tolerance on power factor applies also for PM synchronous machines operated directly at the lines<br>Contradiction between tolerances on efficiency and on losses clarified   |
| 13.1                | Changed as proposed by ACEC<br>Note for large generators added  |
| 13.3                | Changed as proposed by ACEC   |
| 13.5                | Changed as proposed by ACEC   |
| Annex B             | DC power supply added   |

The text of this standard is based on the following documents:

| FDIS        | Report on voting |
|-------------|------------------|
| 2/1857/FDIS | 2/1863/RVD       |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60034 series, published under the general title *Rotating electrical machines*, can be found on the IEC website.

NOTE A table of cross-references of all IEC TC 2 publications can be found in the IEC TC 2 dashboard on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**ITEH STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST IEC 60034-1:2019

<https://standards.iteh.ai/catalog/standards/sist/2afc416d-d2bc-42c1-b128-5bba304b5d0/sist-iec-60034-1-2019>

## ROTATING ELECTRICAL MACHINES –

### Part 1: Rating and performance

#### 1 Scope

This part of IEC 60034 is applicable to all rotating electrical machines except those covered by other IEC standards, for example, IEC 60349.

Machines within the scope of this document may also be subject to superseding, modifying or additional requirements in other standards, for example, IEC 60079 and IEC 60092.

NOTE If particular clauses of this document are modified to meet special applications, for example machines subject to radioactivity or machines for aerospace, all other clauses apply insofar as they are compatible.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60027-1, *Letter symbols to be used in electrical technology – Part 1: General*

IEC 60027-4, *Letter symbols to be used in electrical technology – Part 4: Rotating electric machines*

IEC 60034-2 (all parts), *Rotating electrical machines – Part 2: Standard methods for determining losses and efficiency from tests (excluding machines for traction vehicles)*

IEC 60034-3, *Rotating electrical machines – Part 3: Specific requirements for synchronous generators driven by steam turbines or combustion gas turbines*

IEC 60034-5, *Rotating electrical machines – Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) – Classification*

IEC 60034-6, *Rotating electrical machines – Part 6: Methods of cooling (IC code)*

IEC 60034-8, *Rotating electrical machines – Part 8: Terminal markings and direction of rotation*

IEC 60034-12:2016, *Rotating electrical machines – Part 12: Starting performance of single-speed three-phase cage induction motors*

IEC 60034-15, *Rotating electrical machines – Part 15: Impulse voltage withstand levels of form-wound stator coils for rotating a.c. machines*

IEC 60034-18 (all parts), *Rotating electrical machines – Part 18: Functional evaluation of insulation systems*

IEC 60034-18-41, *Rotating electrical machines – Part 18-41: Partial discharge free electrical insulation systems (Type I) used in rotating electrical machines fed from voltage converters – Qualification and quality control tests*

IEC TS 60034-25, *Rotating electrical machines – Part 25: AC electrical machines used in power drive systems – Application guide*

IEC 60034-29, *Rotating electrical machines – Part 29: Equivalent loading and superposition techniques – Indirect testing to determine temperature rise*

IEC 60034-30-1, *Rotating electrical machines – Part 30-1: Efficiency classes of line operated A.C. motors (IE-code)*

IEC 60038, *IEC standard voltages*

IEC 60050-411:1996, *International Electrotechnical Vocabulary (IEV) – Chapter 411: Rotating machines*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60072 (all parts), *Dimensions and output series for rotating electrical machines*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60204-11, *Safety of machinery – Electrical equipment of machines – Part 11: Requirements for HV equipment for voltages above 1 000 V a.c. or 1 500 V d.c. and not exceeding 36 kV*

IEC 60335-1:2010, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61148, *Terminal markings for valve device stacks and assemblies and for power conversion equipment*

IEC 61293, *Marking of electrical equipment with ratings related to electrical supply – Safety requirements*

CISPR 11, *Industrial, scientific and medical equipment – Radiofrequency disturbance characteristics – Limits and methods of measurement*

CISPR 14 (all parts), *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus*

CISPR 16 (all parts), *Specification for radio disturbance and immunity measuring apparatus and methods*

### **3 Terms and definitions**

For the purposes of this document, the terms and definitions in IEC 60050-411, some of which are repeated here for convenience, and the following apply.

NOTE 1 For definitions concerning cooling and coolants, other than those in 3.17 to 3.22, see IEC 60034-6.

NOTE 2 For the purposes of this document, the term 'agreement' means 'agreement between the manufacturer and purchaser'.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

### 3.1

#### rated value

quantity value assigned, generally by a manufacturer, for a specified operating condition of a machine

Note 1 to entry: The rated voltage or voltage range is the rated voltage or voltage range between lines at the terminals.

[SOURCE: IEC 60050-411:1996, 411-51-23]

### 3.2

#### rating

set of rated values and operating conditions

[SOURCE: IEC 60050-411:1996, 411-51-24]

### 3.3

#### rated output

value of the output included in the rating

### 3.4

#### load

all the values of the, *in case of a generator*, electrical and, *in case of a motor*, mechanical quantities that signify the demand made on a rotating machine by an electrical circuit or a mechanism at a given instant

[SOURCE: IEC 60050-411:1996, 411-51-01, modified: modification indicated in italics]

### 3.5

#### no-load <operation>

state of a machine rotating with zero output power (*but under otherwise normal operating conditions*)

[SOURCE: IEC 60050-411:1996, 411-51-02, modified: modification indicated in italics]

### 3.6

#### full load

load which causes a machine to operate at its rating

[SOURCE: IEC 60050-411:1996, 411-51-10]

### 3.7

#### full load value

quantity value for a machine operating at full load

Note 1 to entry: This concept applies to power, torque, current, speed, etc.

[SOURCE: IEC 60050-411:1996, 411-51-11]

**3.8****de-energized and rest**

complete absence of all movement and of all electrical supply or mechanical drive

[SOURCE: IEC 60050-411:1996, 411-51-03]

**3.9****duty**

statement of the load(s) to which the machine is subjected, including, if applicable, starting, electric braking, no-load and rest and de-energized periods, and including their durations and sequence in time

[SOURCE: IEC 60050-411:1996, 411-51-06]

**3.10****duty type**

continuous, short-time or periodic duty, comprising one or more loads remaining constant for the duration specified, or a non-periodic duty in which generally load and speed vary within the permissible operating range

[SOURCE: IEC 60050-411:1996, 411-51-13]

**3.11****cyclic duration factor**

ratio between the period of loading, including starting and electric braking, and the duration of the duty cycle, expressed as a percentage

[SOURCE: IEC 60050-411:1996, 411-51-09]

**3.12****locked-rotor torque**

smallest measured torque the motor develops at its shaft and with the rotor locked, over all angular positions, at rated voltage and frequency

[SOURCE: IEC 60050-411:1996, 411-48-06]

**3.13****locked-rotor current**

greatest steady-state r.m.s. current taken from the line with the motor held at rest, over all angular positions of its rotor, at rated voltage and frequency

[SOURCE: IEC 60050-411:1996, 411-48-16]

**3.14****pull-up torque <of an a.c. motor>**

smallest steady-state asynchronous torque which the motor develops between zero speed and the speed which corresponds to the breakdown torque, when the motor is supplied at the rated voltage and frequency

Note 1 to entry: This definition does not apply to those asynchronous motors of which the torque continually decreases with increase in speed.

Note 2 to entry: In addition to the steady-state asynchronous torques, harmonic synchronous torques, which are a function of rotor load angle, will be present at specific speeds.

At such speeds, the accelerating torque may be negative for some rotor load angles.

Experience and calculation show this to be an unstable operating condition and therefore harmonic synchronous torques do not prevent motor acceleration and are excluded from this definition.

**3.15****breakdown torque <of an a.c. motor>**

maximum steady-state asynchronous torque which the motor develops without an abrupt drop in speed, when the motor is supplied at the rated voltage and frequency

Note 1 to entry: This definition does not apply to motors with torques that continually decrease with increase in speed.

**3.16****pull-out torque <of a synchronous motor>**

maximum torque which the synchronous motor develops at synchronous speed with rated voltage, frequency and field current

**3.17****cooling**

procedure by means of which heat resulting from losses occurring in a machine is given up to a primary coolant, which may be continuously replaced or may itself be cooled by a secondary coolant in a heat exchanger

[SOURCE: IEC 60050-411:1996, 411-44-01]

**3.18****coolant**

medium, liquid or gas, by means of which heat is transferred

[SOURCE: IEC 60050-411:1996, 411-44-02]

**3.19****primary coolant**

medium, liquid or gas, which, being at a lower temperature than a part of a machine and in contact with it, removes heat from that part

[SOURCE: IEC 60050-411:1996, 411-44-03]

**3.20****secondary coolant**

medium, liquid or gas, which, being at a lower temperature than the primary coolant, removes the heat given up by this primary coolant by means of a heat exchanger or through the external surface of the machine

[SOURCE: IEC 60050-411:1996, 411-44-04]

**3.21****direct cooled winding****inner cooled winding**

winding mainly cooled by coolant flowing in direct contact with the cooled part through hollow conductors, tubes, ducts or channels which, regardless of their orientation, form an integral part of the winding inside the main insulation

Note 1 to entry: In all cases when 'indirect' or 'direct' is not stated, an indirect cooled winding is implied.

[SOURCE: IEC 60050-411:1996, 411-44-08]

**3.22****indirect cooled winding**

any winding other than a direct cooled winding

Note 1 to entry: In all cases when 'indirect' or 'direct' is not stated, an indirect cooled winding is implied.