

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Uninterruptible power systems (UPS) –
Part 1: Safety requirements**

**Alimentations sans interruption (ASI) –
Partie 1: Exigences de sécurité**

[IEC 62040-1:2017](#)

<https://standards.iteh.ai/catalog/standards/sist/8b8e2331-cf3-4f54-afc9-cf22aff68b9e/iec-62040-1-2017>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 62040-1

Edition 2.2 2022-11
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Uninterruptible power systems (UPS) –
Part 1: Safety requirements**

**Alimentations sans interruption (ASI) –
Partie 1: Exigences de sécurité**

<https://standards.iteh.ai/catalog/standards/sist/8b8e2331-cf3-4f54-afc9-cf22aff68b9e/iec-62040-1-2017>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.200

ISBN 978-2-8322-6193-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**Uninterruptible power systems (UPS) –
Part 1: Safety requirements**

**Alimentations sans interruption (ASI) –
Partie 1: Exigences de sécurité**

IEC 62040-1:2017

<https://standards.iteh.ai/catalog/standards/sist/8b8e2331-cf3-4f54-afc9-cf22aff68b9e/iec-62040-1-2017>

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Protection against hazards	15
5 Test requirements.....	29
6 Information and marking requirements.....	42
Annexes	49
Annex A (normative) Additional information for protection against electric shock.....	50
Annex M (informative) Test probes for determining access	51
Annex AA (informative) Minimum and maximum cross-section of copper conductors suitable for connection to terminals for external conductor	52
Annex BB (normative) Reference loads.....	54
Annex CC (normative) Ventilation of lead-acid battery compartments	58
Annex DD (informative) Guidance for disconnection of batteries during shipment	61
Annex EE (informative) Short-time withstand current test procedure – Guidance and typical values.....	63
Annex FF (informative) Maximum heating effect in transformer tests.....	67
Annex GG (normative) Requirements for the mounting means of rack-mounted equipment.....	69
Bibliography.....	71
Figure 101 – Examples of design of openings preventing vertical access.....	18
Figure 102 – Test circuit for load-induced change of reference potential – Single-phase output.....	35
Figure 103 – Test circuit for load-induced change of reference potential – Three-phase output	35
Figure 104 – Voltage backfeed warning label.....	45
Figure M.101 – Jointed test finger (IP2X).....	52
Figure BB.1 – Reference resistive load	54
Figure BB.2 – Reference inductive-resistive load (series)	55
Figure BB.3 – Reference inductive-resistive load (parallel)	55
Figure BB.4 – Reference capacitive-resistive load (series).....	55
Figure BB.5 – Reference capacitive-resistive load (parallel).....	55
Figure BB.6 – Reference non-linear load	56
Figure DD.1 – Precautionary label for products shipped with the battery disconnected	61
Figure DD.2 – Precautionary label for products shipped with the battery connected.....	62
Figure EE.1 – 3-wire test circuit for UPS short-time withstand current.....	63
Figure EE.2 – 4-wire test circuit for UPS short-time withstand current.....	64
Figure EE.3 – 2-wire test circuit for single phase UPS short-time withstand current	65
Table 1 – Alphabetical list of terms	9

Table 101 – UPS input port configuration.....	16
Table 102 – Overvoltage categories.....	19
Table 103 – Maximum temperature limits for magnetic components during stored energy mode of operation	22
Table 22 – Test overview	29
Table 104 – Short-time withstand current.....	37
Table 105 – Temperature limits for transformer windings	40
Table A.101 – Comparison of limits of working voltage	50
Table AA.1 – Conductor cross-sections (extract from IEC 61439-1:2011).....	53
Table FF.1 – Test steps	67

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62040-1:2017](https://standards.iteh.ai/catalog/standards/sist/8b8e2331-cf3-4f54-afc9-cf22aff68b9e/iec-62040-1-2017)

<https://standards.iteh.ai/catalog/standards/sist/8b8e2331-cf3-4f54-afc9-cf22aff68b9e/iec-62040-1-2017>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UNINTERRUPTIBLE POWER SYSTEMS (UPS) –**Part 1: Safety requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 62040-1 edition 2.2 contains the second edition (2017-07) [documents 22H/217/FDIS and 22H/218/RVD] and its corrigendum (2019-10), its amendment 1 (2021-05) [documents 22H/269/FDIS and 22H/271/RVD] and its amendment 2 (2022-11) [documents 22H/288/CDV and 22H/298/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 62040-1 has been prepared by subcommittee 22H: Uninterruptible power systems (UPS), of IEC technical committee 22: Power electronic systems and equipment.

This second edition constitutes a technical revision.

This edition includes the following significant technical change with respect to the previous edition: the reference document has been changed from IEC 60950-1:2005 (safety for IT equipment) to IEC 62477-1 (group safety standard for power electronic converters).

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard is to be read in conjunction with IEC 62477-1:2012.

The provisions of the general rules dealt within IEC 62477-1:2012 are only applicable to this document insofar as they are specifically cited. Clauses and subclauses of IEC 62477-1:2012 that are applicable in this document are identified by reference to IEC 62477-1:2012, for example, "Clause 4 of IEC 62477-1:2012 applies, except as follows".

The exceptions are then listed. The exceptions can take the form of a deletion, a replacement or an addition of subclauses, tables, figures or annexes.

Subclauses, tables and figures that are additional to those in IEC 62477-1:2012 are, in this document, identified by a suffix in the format of X.10x, for example 4.3.101.

Annexes that are additional to those in IEC 62477-1:2012 are, in this document, lettered AA, BB, etc.

In this document, the following print types are used:

- requirements and normative annexes: roman type
- compliance statements and test specifications: *italic type*
- notes and other informative matter: smaller roman type
- normative conditions within tables: smaller roman type
- terms that are defined in Clause 3: **bold**

A list of all parts in the IEC 62040 series, published under the general title *Uninterruptible Power Systems (UPS)*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC technical sub-committee 22H: Uninterruptible power systems (UPS) carefully considered the relevance of each paragraph of IEC 62477-1:2012 in UPS applications. This part of IEC 62040 utilizes IEC 62477-1:2012 as a reference document and references, adds, replaces or modifies requirements as relevant. This is because product-specific topics not covered by the reference document are the responsibility of the technical committee using the reference document.

IEC 62477-1:2012 relates to products that include power electronic converters, with a rated system voltage not exceeding 1 000 V AC or 1 500 V DC. It specifies requirements to reduce risks of fire, electric shock, thermal, energy and mechanical hazards, except functional safety as defined in IEC 61508 (all parts). The objectives of this document are to establish a common terminology and basis for the safety requirements of products that contain power electronic converters across several IEC technical committees.

IEC 62477-1:2012 was developed with the intention:

- to be used as a reference document for product committees inside IEC technical committee 22: Power electronic systems and equipment in the development of product standards for power electronic converter systems and equipment;
- to replace IEC 62103 as a product family standard providing minimum requirements for safety aspects of power electronic converter systems and equipment in apparatus for which no product standard exists; and

NOTE The scope of IEC 62103 contains reliability aspects, which are not covered by this document.

- to be used as a reference document for product committees outside TC 22 in the development of product standards of power electronic converter systems and equipment intended for renewable energy sources. TC 82, TC 88, TC 105 and TC 114, in particular, have been identified as relevant technical committees at the time of publication.

<https://standards.iec.ai/catalog/standards/sist/8b8e2331-cff3-4f54-af9-cf22aff68b9e/iec-62040-1-2017-amd1-2021-amd2-2022>
The reference document, being a group safety standard, will not take precedence over this product-specific standard according to IEC Guide 104. IEC Guide 104 provides information about the responsibility of product committees to use group safety standards for the development of their own product standards.

UNINTERRUPTIBLE POWER SYSTEMS (UPS) –

Part 1: Safety requirements

1 Scope

This part of IEC 62040 applies to movable, stationary, fixed or built-in **UPS** for use in low-voltage distribution systems and that are intended to be installed in an area accessible by an **ordinary person** or in a restricted access area as applicable, that deliver fixed frequency AC output voltage with port voltages not exceeding 1 000 V AC or 1 500 V DC and that include an energy storage device. It applies to pluggable and to permanently connected **UPS**, whether consisting of a system of interconnected units or of independent units, subject to installing, operating and maintaining the **UPS** in the manner prescribed by the manufacturer.

NOTE 1 Typical **UPS** configurations, including voltage and/or frequency converters and other topologies, are described in IEC 62040-3, the test and performance product standard for **UPS**.

NOTE 2 **UPS** generally connect to their energy storage device through a DC link. A chemical battery is used throughout the standard as an example of an energy storage device. Alternative devices exist, and as such, where "battery" appears in the text of this document, this is to be understood as "energy storage device".

This document specifies requirements to ensure safety for the **ordinary person** who comes into contact with the **UPS** and, where specifically stated, for the **skilled person**. The objective is to reduce risks of fire, electric shock, thermal, energy and mechanical hazards during use and operation and, where specifically stated, during service and maintenance.

This product standard is harmonized with the applicable parts of group safety publication IEC 62477-1:2012 for power electronic converter systems and contains additional requirements relevant to **UPS**.

This document does not cover:

- UPS that have a DC output;
- systems for operation on moving platforms including, but not limited to, aircrafts, ships and motor vehicles;
- external AC or DC input and output distribution boards covered by their specific product standard;
- stand-alone static transfer systems (STS) covered by IEC 62310-1;
- systems wherein the output voltage is directly derived from a rotating machine;
- telecommunications apparatus other than **UPS** for such apparatus;
- functional safety aspects covered by IEC 61508 (all parts).

NOTE 3 Even if this document does not cover the applications listed above, it is commonly taken as a guide for such applications.

NOTE 4 Specialized **UPS** applications are generally governed by additional requirements covered elsewhere, for example **UPS** for medical applications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Clause 2 of IEC 62477-1:2012 applies, except as follows:

Add the following normative references:

IEC 60364-4-42, *Low-voltage electrical installations – Part 4-42: Protection for safety – Protection against thermal effects*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC TR 60755, *General requirements for residual current operated protective devices*

IEC 60947-2:2006, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*¹

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

IEC 61000-2-2:2002, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signaling in public low-voltage power supply systems*

IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*

IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC 62040-2:2005, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*²

IEC 62477-1:2012, *Safety requirements for power electronic converter systems and equipment – Part 1: General*

3 Terms and definitions

Clause 3 of IEC 62477-1:2012 applies, except as follows:

Add the following new terms and definitions, and new notes:

¹ 4th edition (2006). This 4th edition has been replaced in 2016 by a 5th edition IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*.

² 2nd edition (2005). This 2nd edition has been replaced in 2016 by a 3rd edition IEC 62040-2:2016, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*.

Table 1 – Alphabetical list of terms

Terms	Term number		Terms	Term number	
	62040-1	62477-1		62040-1	62477-1
adjacent circuit		3.1	power semiconductor device		3.34
active power	3.111		primary power	3.108	
apparent power	3.112		prospective short-circuit current	3.122	
backfeed	3.127		protective equipotential bonding		3.36
backfeed protection	3.128		protective class I		3.37
basic insulation		3.2	protective class II		3.38
basic protection		3.3	protective class III		3.39
bypass	3.110		protective earthing (PE)		3.40
commissioning test		3.4	PE conductor		3.41
cord	3.109		protective impedance		3.42
decisive voltage class (DVC)		3.5	(electrically) protective screening		3.43
double insulation		3.6	protective separation		3.44
DVC As		3.7	PEC		3.45
DVC Ax		3.8	PECS		3.46
earth fault	3.131		rated conditional short-circuit current	3.120	
electrical breakdown		3.9	rated current	3.117	
(electrical) insulation		3.10	rated load	3.115	
(electronic) (power) conversion		3.11	rated peak withstand current	3.118	
enclosure		3.12	rated short-time withstand current	3.119	
enhanced protection		3.13	rating	3.113	
expected lifetime		3.14	rated value	3.114	
Extra Low Voltage (ELV)		3.15	rated voltage	3.116	
fault protection		3.16	reference non-linear load	3.126	
field wiring terminal		3.17	reference test load	3.125	
fire enclosure		3.18	reinforced insulation		3.47
functional insulation		3.19	restricted access area		3.48
hazardous energy	3.107		routine test		3.49
hazardous live part		3.20	sample test		3.50
hazardous voltage	3.106		SELV (systems)		3.51
installation		3.21	short-circuit backup protection		3.52
instructed person	3.103		service access area	3.105	
linear load	3.123		short-circuit protective device (SCPD)	3.130	
live part		3.22	simple separation		3.53
low impedance path	3.121		single fault condition		3.54
low voltage		3.23	skilled person	3.102	
mains supply		3.24	startle reaction		3.55
muscular reaction (inability to let go)		3.25	supplementary insulation		3.56

Terms	Term number		Terms	Term number	
	62040-1	62477-1		62040-1	62477-1
non-linear load	3.124		surge protective device (SPD)		3.57
non-mains supply		3.26	system		3.58
open type		3.27	system voltage		3.59
ordinary person	3.104		stored energy mode	3.129	
output short-circuit current		3.28	temporary overvoltage		3.60
PELV (systems)		3.29	touch current		3.61
Permanently connected		3.30	type test		3.62
pluggable equipment type A		3.31	ventricular fibrillation		3.63
pluggable equipment type B		3.32	working voltage		3.64
port		3.33	uninterruptible power system (UPS)	3.101	
			zone of equipotential bonding		3.65

Note 1 to entry: Where the terms "voltage" and "current" are used, RMS values are implied unless otherwise specified.

Note 2 to entry: Non-sinusoidal signals are measured with appropriate true RMS measuring instruments.

3.101 uninterruptible power system UPS

combination of convertors, switches and energy storage devices (such as batteries), constituting a power system for maintaining continuity of load power in case of input power failure

Note 1 to entry: Continuity of load power occurs when voltage and frequency are within rated steady-state and transient tolerance bands, and with distortion and interruptions within the limits specified for the output port. Input power failure occurs when voltage and frequency are outside rated steady-state and transient tolerance bands, or with distortion or interruptions outside the limits specified for the **UPS**.

3.102 skilled person

person with relevant education and experience to enable him or her to perceive risks and to avoid hazards which the equipment can create

Note 1 to entry: Such person has access to restricted access areas.

[SOURCE: IEC 60050-195:1998, 195-04-01, modified – The word "(electrically)" has been deleted from the term, and "electricity" has been replaced by "the equipment" in the definition. The note has been added.]

3.103 instructed person

person adequately advised or supervised by **skilled persons** to enable him or her to perceive risks and to avoid hazards which the equipment can create

Note 1 to entry: Such person has access to restricted access areas.

Note 2 to entry: Examples of activities performed by an **instructed person** can be found in IEC 61140:2001, Clause 8.

[SOURCE: IEC 60050-195:1998, 195-04-02, modified – The word "(electrically)" has been deleted from the term, and the notes have been added.]

3.104

ordinary person

person who is neither a **skilled person** nor an **instructed person**

Note 1 to entry: Such person does not have access to a restricted access area and is not trained to identify hazards. Such person may otherwise have access to the equipment or may be in the vicinity of the equipment. An ordinary person will not intentionally create hazards nor have access to hazardous parts under normal and **single fault conditions**.

[SOURCE: IEC 60050-195:1998, 195-04-03, modified – The note has been added.]

3.105

service access area

area accessible by **skilled persons** by the use of a tool, where it is necessary for **skilled person** to have access regardless of the equipment being energized

3.106

hazardous voltage

voltage exceeding 42,4 V peak, or 60 V DC, existing in a circuit that does not meet the requirements for either a limited current circuit or a TNV-1 circuit

Note 1 to entry: A limited current circuit is understood in the context of "protection by means of protective impedance" as described in IEC 62477-1:2012, 4.4.5.4.

[SOURCE: IEC 60950-1:2005, 1.2.8.6 modified – TNV has been replaced by TNV-1.]

3.107

hazardous energy

available power level of 240 VA or more, having a duration of 60 s or more, or a stored energy level of 20 J or more (for example, from one or more capacitors), at a potential of 2 V or more

Note 1 to entry: See IEC 62477-1:2012, 4.5.1.2.

3.108

primary power

power supplied by an electrical utility company or by a local generator

3.109

cord

flexible cable with a limited number of conductors of small cross-sectional area

[SOURCE: IEC 60050-461:2008, 461-06-15.]

3.110

bypass

alternative power path, either internal or external to the **UPS**

3.111

active power

under periodic conditions, mean value, taken over one period T , of the instantaneous power p

$$P = \frac{1}{T} \int_0^T p dt$$

Note 1 to entry: Under sinusoidal conditions, the **active power** is the real part of the complex power \underline{S} , thus $P = \text{Re } \underline{S}$

Note 2 to entry: The coherent SI unit for **active power** is watt, W.