

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Profiles –
Part 5-17: Installation of fieldbuses – Installation profiles for CPF 17**

**Réseaux de communication industriels – Profils –
Partie 5-17: Installation des bus de terrain – Profils d'installation pour CPF 17**

ITIH STANDARD PREVIEW
(standards.iteh.ai)
IEC 61784-5-17:2013
<https://standards.iteh.ai/catalog/standards/sist/a92c0d0c-d30f-415f-86c1-d19e007c0fd2/iec-61784-5-17-2013>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 61784-5-17

Edition 1.0 2013-09

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Profiles –
Part 5-17: Installation of fieldbuses – Installation profiles for CPF 17**

**Réseaux de communication industriels – Profils –
Partie 5-17: Installation des bus de terrain – Profils d'installation pour CPF 17**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

U

ICS 25.040.40; 35.100.40

ISBN 978-2-8322-1069-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions and abbreviated terms	8
4 CPF 17: Overview of installation profiles	8
5 Installation profile conventions	8
6 Conformance to installation profiles.....	9
Annex A (Normative) CP 17/1 (RAPIEnet) specific installation profile.....	10
A.1 Installation profile scope.....	10
A.2 Normative references	10
A.3 Installation profile terms, definitions, and abbreviated terms.....	10
A.3.1 Terms and definitions	10
A.3.2 Abbreviated terms	10
A.3.3 Conventions for installation profiles.....	10
A.4 Installation planning	10
A.4.1 General.....	10
A.4.1.1 Objective	10
A.4.1.2 Cabling in industrial premises	10
A.4.1.3 The planning process.....	10
A.4.1.4 Specific requirements for CPs.....	10
A.4.1.5 Specific requirements for generic cabling in accordance with ISO/IEC 24702.....	10
A.4.2 Planning requirements.....	10
A.4.2.1 Safety	10
A.4.2.2 Security	10
A.4.2.3 Environmental considerations and EMC	10
A.4.2.4 Specific requirements for generic cabling in accordance with ISO/IEC 24702.....	11
A.4.3 Network capabilities	11
A.4.3.1 Network topology	11
A.4.3.2 Network characteristics.....	11
A.4.4 Selection and use of cabling components.....	12
A.4.4.1 Cable selection	12
A.4.4.2 Connecting hardware selection	14
A.4.4.3 Connections within a channel/permanent link.....	15
A.4.4.4 Terminators	16
A.4.4.5 Device location and connection.....	16
A.4.4.6 Coding and labelling	16
A.4.4.7 Earthing and bonding of equipment and devices and shielded cabling.....	16
A.4.4.8 Storage and transportation of cables.....	17
A.4.4.9 Routing of cables	18
A.4.4.10 Separation of circuit.....	18
A.4.4.11 Mechanical protection of cabling components	18

A.4.4.12	Installation in special areas.....	18
A.4.5	Cabling planning documentation.....	19
A.4.5.1	Common description	19
A.4.5.2	Cabling planning documentation for CPs.....	19
A.4.5.3	Network certification documentation.....	19
A.4.5.4	Cabling planning documentation for generic cabling in accordance with ISO/IEC 24702.....	19
A.4.6	Verification of cabling planning specification	19
A.5	Installation implementation	19
A.5.1	General requirements.....	19
A.5.1.1	Common description	19
A.5.1.2	Installation of CPs.....	19
A.5.1.3	Installation of generic cabling in industrial premises.....	19
A.5.2	Cable installation.....	19
A.5.2.1	General requirements for all cabling types	19
A.5.2.2	Installation and routing.....	20
A.5.2.3	Specific requirements for CPs.....	20
A.5.2.4	Specific requirements for wireless installation	20
A.5.2.5	Specific requirements for generic cabling in accordance with ISO/IEC 24702.....	21
A.5.3	Connector installation.....	21
A.5.3.1	Common description	21
A.5.3.2	Shielded connectors.....	21
A.5.3.3	Unshielded connectors.....	21
A.5.3.4	Specific requirements for CPs.....	21
A.5.3.5	Specific requirements for generic cabling in accordance with ISO/IEC 24702.....	21
A.5.4	Terminator installation.....	21
A.5.5	Device installation	21
A.5.5.1	Common description	21
A.5.5.2	Specific requirements for CPs.....	21
A.5.6	Coding and labelling.....	21
A.5.6.1	Common description	21
A.5.6.2	Specific requirements for CPs.....	21
A.5.7	Earthing and bonding of equipment and devices and shield cabling.....	21
A.5.7.1	Common description	21
A.5.7.2	Bonding and earthing of enclosures and pathways.....	21
A.5.7.3	Earthing methods.....	21
A.5.7.4	Shield termination methods.....	22
A.5.7.5	Specific requirements for CPs.....	22
A.5.7.6	Specific requirements for generic cabling in accordance with ISO/IEC 24702.....	22
A.5.8	As-implemented cabling documentation.....	22
A.6	Installation verification and installation acceptance test.....	22
A.6.1	General.....	22
A.6.2	Installation verification.....	22
A.6.2.1	General.....	22
A.6.2.2	Verification according to cabling planning documentation.....	22
A.6.2.3	Verification of earthing and bonding.....	22
A.6.2.4	Verification of shield earthing.....	22

A.6.2.5	Verification of cabling system.....	22
A.6.2.6	Cable selection verification	23
A.6.2.7	Connector verification	23
A.6.2.8	Connection verification.....	23
A.6.2.9	Terminators verification.....	23
A.6.2.10	Coding and labelling verification	23
A.6.2.11	Verification report	23
A.6.3	Installation acceptance test	23
A.6.3.1	General.....	23
A.6.3.2	Acceptance test of Ethernet based cabling.....	23
A.6.3.3	Acceptance test of non-Ethernet-based cabling.....	24
A.6.3.4	Specific requirements for wireless installation	24
A.6.3.5	Acceptance test report	24
A.7	Installation administration.....	24
A.8	Installation maintenance and installation troubleshooting	24
Figure 1	– Standards relationships.....	7
Table A.1	– Network characteristics for balanced cabling based on Ethernet	11
Table A.2	– Network characteristics for optical fibre cabling.....	12
Table A.3	– Information relevant to copper cable fixed cables.....	13
Table A.4	– Information relevant to copper cable cords.....	13
Table A.5	– Information relevant to optical fibre cables	14
Table A.6	– Connectors for balanced cabling CPs based on Ethernet	14
Table A.7	– Optical fibre connecting hardware.....	15
Table A.8	– Relationship between FOC and fibre types (CP 17/1).....	15
Table A.9	– Parameters for balanced cables	19
Table A.10	– Parameters for silica optical fibre cables	20

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –****Part 5-17: Installation of fieldbuses –
Installation profiles for CPF 17**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61784-5-17 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This standard is to be used in conjunction with IEC 61918:2013.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/738/FDIS	65C/743/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 61784-5 series, under the general title *Industrial communication networks – Profiles – Installation of fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This International Standard is one of a series produced to facilitate the use of communication networks in industrial control systems.

IEC 61918:2013 provides the common requirements for the installation of communication networks in industrial control systems. This installation profile standard provides the installation profiles of the communication profiles (CP) of a specific communication profile family (CPF) by stating which requirements of IEC 61918 fully apply and, where necessary, by supplementing, modifying, or replacing the other requirements (see Figure 1).

For general background on fieldbuses, their profiles, and relationship between the installation profiles specified in this standard, see IEC 61158-1.

Each CP installation profile is specified in a separate annex of this standard. Each annex is structured exactly as the reference standard IEC 61918 for the benefit of the persons representing the roles in the fieldbus installation process as defined in IEC 61918 (planner, installer, verification personnel, validation personnel, maintenance personnel, administration personnel). By reading the installation profile in conjunction with IEC 61918, these persons immediately know which requirements are common for the installation of all CPs and which are modified or replaced. The conventions used to draft this standard are defined in Clause 5.

The provision of the installation profiles in one standard for each CPF (for example IEC 61784-5-17 for CPF 17), allows readers to work with standards of a convenient size.




Figure 1 – Standards relationships

INDUSTRIAL COMMUNICATION NETWORKS – PROFILES –

Part 5-17: Installation of fieldbuses – Installation profiles for CPF 17

1 Scope

This part of IEC 61784-5 specifies the installation profiles for CPF 17 (RAPIEnet¹).

The installation profiles are specified in the annex. This annex is read in conjunction with IEC 61918:2013.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61918:2013, *Industrial communication networks – Installation of communication networks in industrial premises*

The normative references of IEC 61918:2013, Clause 2, apply.

<https://standards.iteh.ai/catalog/standards/sist/a92c0d6c-d58f-4f3f-88c1-d19e007c0fd2/iec-61784-5-17-2013>

3 Terms, definitions and abbreviated terms

For the purpose of this document, the terms, definitions and abbreviated terms of IEC 61918:2013, Clause 3, apply.

4 CPF 17: Overview of installation profiles

CPF 17 consists of one communication profile as specified in IEC 61784-2.

The installation requirements for CP 17/1 (RAPIEnet) are specified in Annex A.

5 Installation profile conventions

The numbering of the clauses and subclauses in the annexes of this standard corresponds to the numbering of IEC 61918 main clauses and subclauses.

The annex clauses and subclauses of this standard supplement, modify, or replace the respective clauses and subclauses in IEC 61918.

Where there is no corresponding subclause of IEC 61918 in the normative annexes in this standard, the subclause of IEC 61918 applies without modification.

¹ RAPIEnet is a trade name of LSIS. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name RAPIEnet. Use of the trade name RAPIEnet requires permission of the trade name holder.

The annex heading letter represents the installation profile assigned in Clause 4. The annex heading number shall represent the corresponding numbering of IEC 61918.

EXAMPLE “Subclause A.4.4” in IEC 61784-5-17 means that CP 17/1 specifies the subclause 4.4 of IEC 61918.

All main clauses of IEC 61918 are cited and apply in full unless otherwise stated in each normative installation profile annex.

If all subclauses of a (sub)clause are omitted, then the corresponding IEC 61918 (sub)clause applies.

If in a (sub)clause it is written “Not applicable.”, then the corresponding IEC 61918 (sub)clause does not apply.

If in a (sub)clause it is written “*Addition:*”, then the corresponding IEC 61918 (sub)clause applies with the additions written in the profile.

If in a (sub)clause it is written “*Replacement:*”, then the text provided in the profile replaces the text of the corresponding IEC 61918 (sub)clause.

NOTE A replacement can also comprise additions.

If in a (sub)clause it is written “*Modification:*”, then the corresponding IEC 61918 (sub)clause applies with the modifications written in the profile.

If all (sub)clauses of a (sub)clause are omitted but in this (sub)clause it is written “(Sub)clause *x* has addition:” (or “replacement:”) or “(Sub)clause *x* is not applicable.”, then (sub)clause *x* becomes valid as declared and all the other corresponding IEC 61918 (sub)clauses apply.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
<https://standards.iteh.ai/catalog/standards/sist/a92c0d6c-d58f-4f3f-88c1-d19e007c0f12/iec-61784-5-17-2013>

6 Conformance to installation profiles

Each installation profile within this standard includes part of IEC 61918:2013. It may also include defined additional specifications.

A statement of compliance to an installation profile of this standard shall be stated² as either

Compliance to IEC 61784-5-17:2013³ for CP 17/m<name> or

Compliance to IEC 61784-5-17 (Ed.1.0) for CP 17/m <name>

where the name within the angle brackets < > is optional and the angle brackets are not to be included. The m within CP 17/m shall be replaced by the profile number 1.

NOTE The name can be the name of the profile, for example RAPIEnet.

If the name is a trade name then the permission of the trade name holder shall be required.

Product standards shall not include any conformity assessment aspects (including quality management provisions), neither normative nor informative, other than provisions for product testing (evaluation and examination).

² In accordance with ISO/IEC Directives

³ The date should not be used when the edition number is used.

Annex A (Normative)

CP 17/1 (RAPIEnet) specific installation profile

A.1 Installation profile scope

Addition:

This standard specifies the installation profile for Communication Profile CP 17/1 (RAPIEnet). The CP 17/1 is specified in IEC 61784-2.

A.2 Normative references

A.3 Installation profile terms, definitions, and abbreviated terms

A.3.1 Terms and definitions

A.3.2 Abbreviated terms

A.3.3 Conventions for installation profiles

Not applicable.

A.4 Installation planning

[IEC 61784-5-17:2013](https://standards.iteh.ai/catalog/standards/sist/a92c0d6c-d58f-4f3f-88c1-d19e007c0fd2/iec-61784-5-17-2013)

<https://standards.iteh.ai/catalog/standards/sist/a92c0d6c-d58f-4f3f-88c1-d19e007c0fd2/iec-61784-5-17-2013>

A.4.1 General

A.4.1.1 Objective

A.4.1.2 Cabling in industrial premises

A.4.1.3 The planning process

A.4.1.4 Specific requirements for CPs

Not applicable.

A.4.1.5 Specific requirements for generic cabling in accordance with ISO/IEC 24702

A.4.2 Planning requirements

A.4.2.1 Safety

A.4.2.1.1 General

A.4.2.1.2 Electric safety

A.4.2.1.3 Functional safety

A.4.2.1.4 Intrinsic safety

A.4.2.1.5 Safety of optical fibre communication systems

A.4.2.2 Security

A.4.2.3 Environmental considerations and EMC

A.4.2.3.1 Description methodology**A.4.2.3.2 Use of the described environment to produce a bill of material****A.4.2.4 Specific requirements for generic cabling in accordance with ISO/IEC 24702****A.4.3 Network capabilities****A.4.3.1 Network topology****A.4.3.1.1 Common description****A.4.3.1.2 Basic physical topologies for passive networks**

Not applicable.

A.4.3.1.3 Basic physical topologies for active networks**A.4.3.1.4 Combination of basic topologies**

Not applicable.

A.4.3.1.5 Specific requirements for CPs

Not applicable.

A.4.3.1.6 Specific requirements for generic cabling in accordance with ISO/IEC 24702**A.4.3.2 Network characteristics****A.4.3.2.1 General**

[IEC 61784-5-17:2013](https://standards.iteh.ai/catalog/standards/sist/a92c0d6c-d58f-4f3f-88c1-d19e007c0fd2/iec-61784-5-17-2013)

A.4.3.2.2 Network characteristics for balanced cabling not based on Ethernet

Not applicable.

A.4.3.2.3 Network characteristics for balanced cabling based on Ethernet

Replacement:

Table A.1 provides values based on the template given in IEC 61918:2013, Table 2.

Table A.1 – Network characteristics for balanced cabling based on Ethernet

Characteristic	CP 17/1
Supported data rates (Mbit/s)	100, 1 000
Supported channel length (m) ^b	100
Number of connections in the channel (max.) ^{a,b}	4
Patch cord length (m) ^a	See IEC 61918:2013, Clause 4 and ISO/IEC 24702
Channel class per ISO/IEC 24702 (min.) ^b	Class D
Cable category per ISO/IEC 24702 (min.) ^c	5
Connecting HW category per ISO/IEC 24702 (min.)	5
Cable types	Application dependent
^a See A.4.4.3.2 ^b For the purpose of this table the channel definitions of ISO/IEC 24702 are applicable. ^c Additional information is available in IEC 61156 series.	

A.4.3.2.4 Network characteristics for optical fibre cabling

Replacement:

Table A.2 provides values based on the template given in IEC 61918:2013, Table 3.

Table A.2 – Network characteristics for optical fibre cabling

CP 17/1		
Optical fibre type	Description	
Single mode silica	Bandwidth (MHz) or equivalent at λ (nm)	–
	Minimum length (m)	0
	Maximum length ^a (m)	10 000
	Maximum channel insertion loss/optical power budget (dB)	2
	Connecting hardware	See A.4.4.2.5
Multimode silica	Modal bandwidth (MHz × km) at λ (nm)	500 at 1 300
	Minimum length (m)	0
	Maximum length ^a (m)	2 000
	Maximum channel insertion loss/optical power budget (dB)	3
	Connecting hardware	See A.4.4.2.5
POF	Modal bandwidth (MHz × km) at λ (nm)	–
	Minimum length (m)	–
	Maximum length ^a (m)	–
	Maximum channel insertion loss/optical power budget (dB)	–
	Connecting hardware	–
Hard clad silica	Modal bandwidth (MHz × km) at λ (nm)	–
	Minimum length (m)	–
	Maximum length ^a (m)	–
	Maximum channel insertion loss/optical power budget (dB)	–
	Connecting hardware	–
^a This value is reduced by connections, splices and bends in accordance with formula (1) in 4.4.3.4.1 of IEC 61918:2013.		

A.4.3.2.5 Specific network characteristics

A.4.3.2.6 Specific requirements for generic cabling in accordance with ISO/IEC 24702

A.4.4 Selection and use of cabling components

A.4.4.1 Cable selection

A.4.4.1.1 Common description

A.4.4.1.2 Copper cables

A.4.4.1.2.1 Balanced cables for Ethernet-based CPs

Replacement:

Table A.3 provides values based on the template given in IEC 61918:2013, Table 4.

Table A.3 – Information relevant to copper cable: fixed cables

Characteristic	CP 17/1
Nominal impedance of cable (tolerance)	100 Ω \pm 15 Ω (IEC 61156-5)
DCR of conductors	Compliant to ISO/IEC 11801
DCR of shield	Compliant to ISO/IEC 11801
Number of conductors	4 or 8
Shielding	–
Colour code for conductor	WH, BU / YE, OG (if 4 conductors) T568B (if 8 conductors)
Jacket colour requirements	–
Jacket material	–
Resistance to harsh environment (e.g. UV, oil resist, LS0H)	–
Agency ratings	–
Cable characteristics	In twisted pairs

Replacement:

Table A.4 provides values based on the template given in IEC 61918:2013, Table 5.

Table A.4 – Information relevant to copper cable: cords
(standards.iteh.ai)

Characteristic	CP 17/1
Nominal impedance of cable (tolerance)	100 Ω \pm 15 Ω (IEC 61156-5)
DCR of conductors	Compliant to ISO/IEC 11801
DCR of shield	Compliant to ISO/IEC 11801
Number of conductors	4 or 8
Length	\leq 100m
Shielding	–
Colour code for conductor	WH, BU / YE, OG (if 4 conductors) T568B (if 8 conductors)
Jacket colour requirements	–
Jacket material	–
Resistance to harsh environment (e.g. UV, oil resist, LS0H)	–
Agency ratings	–
Cable characteristics	In twisted pairs

A.4.4.1.2.2 Copper cables for non-Ethernet-based CPs

Not applicable.

A.4.4.1.3 Cables for wireless installation

A.4.4.1.4 Optical fibre cables

Replacement:

Table A.5 provides values based on the template given in IEC 61918:2013, Table 6.