

INTERNATIONAL STANDARD



**Low-voltage switchgear and controlgear –
Part 5-1: Control circuit devices and switching elements – Electromechanical
control circuit devices**

Withhold

IEC 60947-5-1:2016

<https://standards.iteh.ai/standards/iec/60947-5-1:2016>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

INTERNATIONAL STANDARD



**Low-voltage switchgear and controlgear –
Part 5-1: Control circuit devices and switching elements – Electromechanical
control circuit devices**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.40; 29.130.20

ISBN 978-2-8322-3431-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	9
1 General.....	12
1.1 Scope and object	12
1.2 Normative references	13
2 Terms and definitions	15
2.1 Basic terms and definitions.....	18
2.2 Control switches.....	18
2.3 Parts of control switches	21
2.4 Operation of control switches	23
2.4.1 Operation of contactor relays	23
2.4.2 Operation of pilot switches	24
2.4.3 Operation of rotary switches.....	24
2.4.4 Operation of mechanically operated control switches	25
3 Classification.....	26
3.1 Contact elements	26
3.2 Control switches.....	26
3.3 Control circuit devices	27
3.4 Time delay switching elements	27
3.5 Control switch mounting	27
4 Characteristics	27
4.1 Summary of characteristics	27
4.1.1 General	27
4.1.2 Operation of a control switch	27
4.2 Type of control circuit device or switching element.....	27
4.2.1 Kind of control circuit device.....	27
4.2.2 Kind of switching elements	28
4.2.3 Number of poles.....	28
4.2.4 Kind of current	28
4.2.5 Interrupting medium	28
4.2.6 Operating conditions	28
4.3 Rated and limiting values for switching elements	28
4.3.1 General	28
4.3.2 Rated voltages (of a switching element).....	29
4.3.3 Currents	29
4.3.4 Rated frequency.....	29
4.3.5 Vacant	29
4.3.6 Normal and abnormal load characteristics	29
4.3.7 Short-circuit characteristics	30
4.4 Utilization categories for switching elements	30
4.5 Vacant.....	30
4.6 Vacant.....	30
4.7 Vacant.....	30
4.8 Vacant.....	30
4.9 Switching overvoltages Vacant	30
4.10 Electrically separated contact elements	30
4.11 Actuating quantities for pilot switches	30

4.12	Pilot switches having two or more contact elements	31
5	Product information	31
5.1	Nature of information.....	31
5.2	Marking.....	32
5.2.1	General	32
5.2.2	Terminal identification and marking	32
5.2.3	Functional markings	32
5.2.4	Emergency stop	32
5.2.5	Operating diagram	32
5.2.6	Time delay markings	33
5.3	Instructions for installation, operation and maintenance	33
5.4	Additional information.....	33
6	Normal service, mounting and transport conditions.....	33
6.3.1	Mounting of single hole mounted devices.....	33
7	Constructional and performance requirements.....	35
7.1	Constructional requirements.....	35
7.1.1	General	35
7.1.2	Materials.....	35
7.1.3	Current-carrying parts and their connections.....	36
7.1.4	Clearances and creepage distances.....	36
7.1.7	Conditions for control switches suitable for isolation	36
7.1.8	Terminals.....	37
7.1.14	Class II control circuit devices.....	37
7.1.15	Requirements for control devices with integrally connected cables	37
7.2	Performance requirements.....	37
7.2.3	Dielectric properties	37
7.2.4	Ability to make and break under normal and abnormal load conditions	37
7.2.5	Conditional short-circuit current.....	38
7.2.6	Switching overvoltages Vacant.....	38
7.2.7	Additional requirements for control switches suitable for isolation.....	38
7.2.8	Maximum recovery time	38
7.3	Electromagnetic compatibility (EMC).....	38
7.3.1	General	38
7.3.2	Immunity.....	38
7.3.3	Emission.....	39
8	Tests.....	45
8.1	Kinds of test.....	45
8.1.1	General	45
8.1.2	Type tests.....	45
8.1.3	Routine tests	45
8.1.4	Sampling tests	46
8.1.5	Special tests	46
8.2	Compliance with constructional requirements.....	46
8.2.1	Materials.....	46
8.2.2	Equipment	47
8.2.3	Enclosures for equipment.....	47
8.2.4	Mechanical and electrical properties of terminals	47
8.2.5	Verification of actuating force (or moment).....	48

8.2.6	Verification of limitation of rotation (of a rotary switch)	48
8.2.7	Conduit pull-out test, torque test and bending test with metallic conduits	48
8.3	Performance	49
8.3.1	Test sequences	49
8.3.2	General test conditions	49
8.3.3	Performance under no-load, normal load and abnormal load conditions	50
8.3.4	Performance under conditional short-circuit current	53
8.4	Tests for EMC	54
8.4.1	General	54
8.4.2	Immunity	54
8.4.3	Emission	55
8.4.4	Test results and test report	55
Annex A (normative)	Electrical ratings based on utilization categories (see 3.1)	63
Annex B (normative)	Example of inductive test loads for d.c. contacts	65
B.1	General	65
B.2	Construction	65
Annex C (normative)	Special tests – Durability tests	67
C.1	General	67
C.1.1	Durability declaration	67
C.1.2	Test procedures	67
C.1.3	Failure criteria	68
C.2	Mechanical durability	68
C.2.1	General	68
C.2.2	Test procedures	68
C.3	Electrical durability	68
C.3.1	General	68
C.3.2	Test procedures	68
Annex D	Clearances and creepage distances of control circuit devices Vacant	74
Annex E (normative)	Items subject to agreement between manufacturer and user	75
Annex F (normative)	Class II control circuit devices insulated by encapsulation	
Requirements and tests	76
F.1	General	76
F.2	Terms and definitions	76
F.5	Marking	76
F.7	Instructional and functional requirements	77
F.7.1	Choice of compound	77
F.7.2	Adhesion of the compound	77
F.7.3	Dielectric properties	77
F.8	Tests	77
F.8.1	Kind of tests	77
Annex G (normative)	Additional requirements for control circuit devices with integrally connected cables	80
G.1	General	80
G.2	Terms and definitions	80
G.7	Constructional and performance requirements	80
G.7.1	Constructional requirements	80
G.7.2	Performance requirements	81
G.8	Tests	81

G.8.1	General	81
G.8.2	Type tests	81
G.8.3	Results to be obtained	82
Annex H (normative)	Additional requirements for semiconductor switching elements for control circuit devices	83
H.1	General.....	83
H.1.1	Scope	83
H.1.2	Object	83
H.2	Terms and definitions	83
H.3	Classification	83
H.3.1	Semiconductor switching elements	83
H.4	Characteristics	84
H.4.1	Rated voltage	84
H.4.2	Utilization categories.....	84
H.5	Product information	84
H.7	Constructional and performance requirements	84
H.7.1	Performance requirements	84
H.7.2	Ability to make under abnormal and normal conditions	85
H.7.3	Conditional short-circuit current.....	85
H.7.4	Electromagnetic compatibility (EMC)	85
H.8	Tests	85
H.8.1	Type tests	85
H.8.2	Voltage drop (U_d).....	85
H.8.3	Minimum operational current (I_m).....	86
H.8.4	OFF-state current (I_r).....	86
H.8.5	Making and breaking capacities.....	86
H.8.6	Performance under short-circuit current conditions	86
H.8.7	Verification of electromagnetic compatibility.....	87
Annex J (normative)	Special requirements for indicator lights and indicating towers	91
J.1	General.....	91
J.1.1	Scope	91
J.1.2	Object	91
J.2	Terms and definitions	91
J.3	Classification	91
J.4	Characteristics	92
J.4.1	Rated operational voltage of an indicator light	92
J.4.2	Rated thermal power of an indicator light.....	92
J.4.3	Rated values of the lamp.....	92
J.5	Product information	92
J.6	Normal service, mounting and transport conditions	92
J.7	Constructional and performance requirements	93
J.8	Tests	94
J.8.3	Tests for indicator lights and indicating towers.....	94
J.8.4	Shock and vibration	95
J.8.5	Degree of protection for indicating towers.....	96
Annex K (normative)	Special requirements for control switches with direct opening action	97
K.1	General.....	97
K.1.1	Scope	97

K.1.2	Object	
K.2	Terms and definitions	97
K.3	Classification	97
K.4	Characteristics	98
K.4.4	Utilization categories for switching elements	98
K.5	Product information	98
K.5.2	Marking	98
K.5.4	Additional information	98
K.6	Normal service, mounting and transport conditions	99
K.7	Constructional and performance requirements	99
K.8	Tests	100
Annex L (normative) Special requirements for mechanically linked contact elements		103
L.1	General	103
L.1.1	Scope	
L.1.2	Object	
L.2	Terms and definitions	103
L.3	Classification	103
L.4	Characteristics	103
L.5	Product information	104
L.6	Normal service, mounting and transport conditions	104
L.7	Constructional and performance requirements	104
L.8	Tests	105
L.8.4	Special test for mechanically linked contact elements	105
Annex M (normative) Terminal marking, distinctive number and distinctive letter for control circuit devices		106
M.1	Scope	106
M.2	Terminal marking rule	106
M.2.1	General	106
M.2.2	Function digit	106
M.2.3	Sequence digit	106
M.2.4	Numbering method	107
M.3	Distinctive number and distinctive letter	107
M.3.1	General	107
M.3.2	Distinctive number	107
M.3.3	Distinctive letter	107
M.4	Terminal numbering sequence	107
M.5	Contactors designated by the distinctive letter E	108
M.6	Contactors designated by distinctive letters X, Y or Z	110
M.6.1	Contactors designated by the distinctive letter Z	110
M.6.2	Contactors designated by the distinctive letter X	110
M.6.3	Contactors designated by the distinctive letter Y	110
Annex N (normative) Procedure to determine reliability data for electromechanical devices in control circuits used in functional safety applications		111
N.1	General	111
N.1.1	Overview	111
N.1.2	Scope and object	111
N.1.3	General requirements	111
N.2	Terms, definitions and symbols	111
N.3	Method based on durability test results	111

N.3.1	General method	111
N.3.2	Test requirements	111
N.3.3	Number of samples	112
N.3.4	Characterization of a failure mode	112
N.3.5	Weibull modelling	112
N.3.6	Useful life and upper limit of failure rate	112
N.3.7	Reliability data	112
N.4	Data information	112
N.5	Example	112
Bibliography		113
Figure 1	– Examples of the recommended method for drawing an operating diagram of a rotary switch	57
Figure 2	– Operation of push-buttons	58
Figure 3	– Difference e between the over-travel of the actuator and that of the contact element	58
Figure 4	– Examples of contact elements (schematic sketches)	59
Figure 5	– Test circuits for multi-pole control switches – Contacts of same polarity, not electrically separated	60
Figure 6	– Test circuits for multi-pole control switches – Contacts of opposite polarity, and electrically separated	60
Figure 7	– Load L_d details for test conditions requiring different values of make and break current and/or power factor (time constant)	61
Figure 8	– Test circuit, conditional short-circuit current (see 8.3.4.2)	61
Figure 9	– Current/time limits for d.c. test loads (see 8.3.3.5.4)	62
Figure 10	– Voltage drop measurement at contact point of the clamping unit or terminal	62
Figure B.1	– Construction of load for d.c. contacts	66
Figure C.1	– Normal circuit (see C.3.2.2)	70
Figure C.2	– Simplified circuit (see C.3.2.2)	70
Figure F.1	– Insulation by encapsulation	77
Figure F.2	– Test apparatus	78
Figure H.1	– Relationship between U_e and U_B	84
Figure H.2	– Example of test circuit for the verification of voltage drop, minimum operational current and OFF-state current (see H.8.2, H.8.3 and H.8.4)	86
Figure H.3	– Short-circuit testing (see H.8.6.1)	87
Figure J.1	– Mounting dimensions for indicating tower socket	93
Figure J.2	– Mounting dimensions for temperature rise tests	94
Figure K.1	– Verification of robustness of the actuating system	102
Figure L.1	– Example of representation of NO and NC contacts which are mechanically linked and NC non-linked contact	104
Figure L.2	– Symbol for device containing mechanically linked contacts	104
Table 1	– Utilization categories for switching elements	30
Table 2	– Mounting hole diameter and dimensions of the key recess (if any)	34
Table 3	– Preferred minimum distances between centres of mounting holes	34
Table 4	– Verification of making and breaking capacities of switching elements under normal conditions corresponding to the utilization categories	40

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 5-1: Control circuit devices and switching elements –
Electromechanical control circuit devices**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60947-5-1 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage.

This fourth edition cancels and replaces the third edition published in 2003 and its Amendment 1:2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) update of normative references;
- b) update and restructuration of subclauses in 7.1;
- c) addition of material requirements and test;
- d) update of EMC requirements;
- e) clarification of requirements and update of 8.2;
- f) addition of requirements for screwless-type clamping units;
- g) update of existing Tables 4 and 5;
- h) addition of new Tables 6, 7, 8 and 9;
- i) addition of a new Figure 10 ;
- j) addition of a new Annex N.

The text of this standard is based on the following documents:

FDIS	Report on voting
121A/62/FDIS	121A/76/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard should be used in conjunction with IEC 60947-1.

The provisions of the general rules, IEC 60947-1, are applicable to this standard, where specifically called for. General rules, clauses and subclauses thus applicable, as well as tables, figures and annexes are identified by a reference to IEC 60947-1, for example 1.2.3, Table 4 or Annex A of IEC 60947-1:2007.

The following differing practices of a less permanent nature exist in the countries indicated below.

- 7.2.4.1: Making and breaking capacities (United States of America and Canada)
- 8.3.3.5.2: Test circuits and connections (United States of America and Canada)

A list of all the parts in the IEC 60947 series, under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigenda of July 2016 and April 2020 have been included in this copy.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60947-5-1:2016](https://standards.iteh.ai/standards/iec/60947-5-1:2016)

<https://standards.iteh.ai/standards/iec/60947-5-1:2016>

WITHDRAWN

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices

1 General

~~The provisions of the general rules, IEC 60947-1, are applicable to this standard, where specifically called for. General rules, clauses and subclauses thus applicable, as well as tables, figures and annexes are identified by a reference to IEC 60947-1, for example 1.2.3, Table 4 or Annex A of IEC 60947-1.~~

1.1 Scope and object

This part of IEC 60947 applies to control circuit devices and switching elements intended for controlling, signalling, interlocking, etc., of switchgear and controlgear.

It applies to control circuit devices having a rated voltage not exceeding 1 000 V a.c. (at a frequency not exceeding 1 000 Hz) or 600 V d.c.

However, for operational voltages below 100 V a.c. or d.c., see 4.3.2.2.

This standard applies to specific types of control circuit devices such as:

- manual control switches, for example push-buttons, rotary switches, foot switches, etc.;
- electromagnetically operated control switches, either time-delayed or instantaneous, for example contactor relays;
- pilot switches, for example pressure switches, temperature sensitive switches (thermostats), programmers, etc.;
- position switches, for example control switches operated by part of a machine or mechanism;
- associated control circuit equipment, for example indicator lights, etc.

NOTE 1 A control circuit device includes (a) control switch(es) and associated devices such as (an) indicator light(s).

NOTE 2 A control switch includes (a) switching element(s) and an actuating system.

NOTE 3 A switching element ~~may~~ can be a contact element or a semiconductor element.

It also applies to specific types of switching elements associated with other devices (whose main circuits are covered by other standards) such as:

- auxiliary contacts of a switching device (e.g. contactor, circuit breaker, etc.) which are not dedicated exclusively for use with the coil of that device;
- interlocking contacts of enclosure doors;
- control circuit contacts of rotary switches;
- control circuit contacts of overload relays.

Contactor relays ~~shall~~ also ~~meet~~ comply with the requirements and tests of IEC 60947-4-1 except for the utilization category which ~~shall~~ comply with this standard.

This standard does not include the relays covered in IEC 60255 or in the IEC 61810 series, nor automatic electrical control devices for household and similar purposes.