

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

Atmosphères explosives –
Partie 13: Protection du matériel par salle à surpression interne «p» et salle à ventilation artificielle «v»



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 21 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

Atmosphères explosives –
Partie 13: Protection du matériel par salle à surpression interne «p» et salle à ventilation artificielle «v»

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.260.20

ISBN 978-2-8322-6204-7

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	10
3 Terms and definitions	11
4 Requirements for all rooms.....	13
4.1 General.....	13
4.2 Type and level of protection	13
4.2.1 Pressurization "p"	13
4.2.2 Artificial ventilation "v"	14
4.3 Construction	14
4.4 Mechanical strength.....	14
4.5 Penetrations and seals	14
4.6 Personnel access doors.....	14
4.7 Inlets and outlets	15
4.8 Ducts	15
4.9 Purging and cleaning	15
4.9.1 General.....	15
4.9.2 Gases – Purging.....	15
4.9.3 Enclosures within the room.....	16
4.10 Ignition prevention under system failure.....	16
5 Clean air supply.....	16
5.1 General.....	16
5.2 Source of clean air.....	16
5.3 Environmental and air temperature conditions.....	17
5.4 Heating, ventilation and air conditioning services.....	17
6 Requirements for pressurized rooms	17
6.1 General.....	17
6.1.1 Design	17
6.1.2 Source of clean air	17
6.1.3 Flow	17
6.1.4 Pressurization system.....	17
6.1.5 Preventing the explosive atmosphere from entering through an open door.....	18
6.1.6 Airlock	18
6.1.7 Outward air velocity through a door	18
6.1.8 Air consuming device.....	19
6.1.9 Action when pressurization system fails.....	19
6.1.10 Re-energizing the room	19
6.2 Purging of rooms	19
6.2.1 General	19
6.2.2 Sequence of operations of the purging safety devices	20
6.2.3 Dusts – Cleaning	20
6.3 Minimum safety provisions, safety devices and electrical disconnects.....	20
6.3.1 Safety devices	20
6.3.2 Safety devices based upon level of protection	21

6.3.3	Gas detectors	21
6.4	Verification for pressurized rooms	21
6.4.1	General	21
6.4.2	Tests	21
6.4.3	Overpressure test	22
6.4.4	Purging test	22
6.4.5	Minimum pressure differential test	22
6.4.6	Confirmation of the ratings of the safety devices	22
6.4.7	Verification of sequence of operation of the safety devices	22
7	Requirements for artificially ventilated rooms	22
7.1	General	22
7.1.1	Design	22
7.1.2	Source of clean air	22
7.1.3	Minimum flow rate	23
7.1.4	Ventilation system	23
7.1.5	Air consuming device	24
7.1.6	Safety actions when ventilation system fails	24
7.1.7	Energizing the artificially ventilated area	24
7.2	Purging of artificially ventilated rooms	25
7.2.1	General	25
7.2.2	Sequence of operations of the purging safety devices	25
7.3	Minimum safety provisions, safety devices and electrical disconnects	25
7.3.1	Safety devices	25
7.3.2	Safety devices based upon equipment protection level	25
7.3.3	Artificial ventilation protection	26
7.3.4	Gas detectors	26
7.4	Loss of artificial ventilation	26
7.5	Verification for artificially ventilated rooms	27
7.5.1	General	27
7.5.2	Tests	27
7.5.3	Purging test	27
7.5.4	Minimum ventilation flow rate test	27
7.5.5	Confirmation of the ratings of the safety devices	27
7.5.6	Verification of sequence of operation of the safety devices	27
7.5.7	Testing of ventilation system	28
8	Marking	28
8.1	General	28
8.2	Marking of pressurized rooms	28
8.3	Marking for artificially ventilated rooms	29
9	Instructions	30
9.1	General	30
9.2	Technical documentation for pressurized rooms	30
9.3	Technical documentation for artificially ventilated rooms	30
9.4	Technical documentation for rooms protected by pressurization and artificial ventilation combined	31
9.5	Modifications	31
Annex A (informative)	Maintenance	32
A.1	Periodic verification	32
A.2	Modifications	32

Annex B (informative) Guidelines when pressurization or artificial ventilation is not immediately restored..... 33

Annex C (informative) Examples of applications and associated guidelines 34

 C.1 Examples of applications 34

 C.2 Guidelines for gas turbine enclosure/package 34

Bibliography..... 35

Table 1 – Exclusion of specific clauses or subclauses of IEC 60079-0 9

Table 2 – Safety devices for pressurized rooms 21

Table 3 – Safety actions for artificial ventilation failure..... 24

Table 4 – Required safety devices for artificial ventilation 26

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60079-13:2017](#)

<https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2275781bfc5d/iec-60079-13-2017>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
<https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456->
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-13 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This bilingual edition (2018-11) corresponds to the monolingual English version, published in 2017-05.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modification of the title of this document to include artificially ventilated room "v" in addition to pressurized room "p";
- b) addition of types of protection "pb", "pc", and "vc" and removal of types of protection "px", "py", "pz" and "pv";

- c) definition of the differences between pressurization and artificial ventilation types of protection;
- d) removal of protection of rooms with an inert gas or a flammable gas from the scope of this document;
- e) addition of an informative annex to include examples of applications where types of protection pressurization or artificial ventilation or pressurization and artificial ventilation can be used and associated guidelines.

The text of this document is based on the following documents:

FDIS	Report on voting
31/1309/FDIS	31/1317/RVD

Full information on the voting for the approval of this document can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This document is to be used in conjunction with the principles of hazardous area classification from IEC 60079-10-1 and artificial ventilation for the protection of analyser(s) houses from IEC 60079-16.

A list of all parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This part of IEC 60079 gives requirements for the design, construction, assessment, verification and marking of rooms used to protect internal equipment by pressurization or artificial ventilation or both as applicable when located in an explosive gas atmosphere or combustible dust atmosphere hazardous area with or without an internal source of a flammable gas or vapour. It also includes a room located in a non-hazardous area that has an internal source of release of a flammable gas or vapour.

This document deals with rooms that are partially constructed in a manufacturer's facility and intended to have the final installation completed on-site, as well as rooms that are constructed completely on-site. Rooms partially constructed in a manufacturer's facility may include third-party verification. For rooms built on-site, this document can be used by plant operators as a guide for assessment of those facilities.

This document represents a major technical revision of the requirements for equipment protection by pressurized room "p" and artificially ventilated room "v" and should be considered as introducing all new requirements.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 60079-13:2017](https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2275781bfc5d/iec-60079-13-2017)

<https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2275781bfc5d/iec-60079-13-2017>

EXPLOSIVE ATMOSPHERES –

Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

1 Scope

This part of IEC 60079 gives requirements for the design, construction, assessment, verification and marking of rooms used to protect internal equipment:

- located in a Zone 1 or Zone 2 or Zone 21 or Zone 22 explosive atmosphere (an area normally requiring an equipment protection level (EPL) Gb, Gc, Db or Dc) without an internal source of gas/vapour release and protected by pressurization;
- located in a Zone 2 explosive atmosphere (an area normally requiring EPL Gc) with or without an internal source of gas/vapour release and protected by artificial ventilation;
- located in a non-hazardous area, containing an internal source of gas/vapour release and protected by artificial ventilation;
- located in a Zone 1 or Zone 2 or Zone 21 or Zone 22 explosive atmosphere (an area normally requiring EPL Gb, Gc, Db or Dc), containing an internal source of gas/vapour release and protected by both pressurization and artificial ventilation.

The term "room" used in this document includes single rooms, multiple rooms, a complete building or a room contained within a building. A room is intended to facilitate the entry of personnel and includes inlet and outlet ducts. An acoustic hood and other like enclosures designed to permit the entry of personnel can be considered as a room.

[https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-](https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2375781bf5d/iec-60079-13-2017)

This document also includes requirements related safety devices and controls necessary to ensure that artificial ventilation, purging and pressurization is established and maintained.

A room assembled or constructed on site, can be either on land or off-shore. The room is primarily intended for installation by an end-user but could be constructed and assessed at a manufacturer's facility, where the final construction such as ducting can be completed on site.

Rooms can be located in an explosive gas atmosphere requiring EPL Gb or Gc, or a combustible dust atmosphere requiring EPL Db, or Dc.

This document does not specify the methods that may be required to ensure adequate air quality for personnel with regard to toxicity and temperature within the room. National or other regulations and requirements may exist to ensure the safety of personnel in this regard.

Protection of rooms by using an inert gas or a flammable gas is outside of the scope of this document. It is recognized that such applications are special cases, which in part may be addressed using the principles from IEC 60079-2, but in all probability will also be the subject of additional, stringent engineering standards, procedures and practices. Pressurized enclosures for equipment that are not intended to facilitate the entry of personnel are addressed in IEC 60079-2, and are not in the scope of this document.

NOTE Maintenance recommendations are contained in Annex A until they can be included in IEC 60079-17.

This document supplements and modifies the general requirements of IEC 60079-0, except exclusions as indicated in Table 1. Where a requirement of this document conflicts with a requirement of IEC 60079-0, the requirement of this document takes precedence.

Table 1 – Exclusion of specific clauses or subclauses of IEC 60079-0

Clause of IEC 60079-0		IEC 60079-0 application to IEC 60079-13
Ed. 6.0 (2011) (Informative)	Clause / subclause title (Normative)	
4	Equipment grouping	Applies
4.1	Group I	Excluded
4.2	Group II	Applies
4.3	Group III	Applies
4.4	Equipment for a particular explosive atmosphere	Applies
5.1	Environmental influences	Applies
5.1.1	Ambient temperature	Applies
5.1.2	External source of heating or cooling	Applies
5.2	Service temperature	Applies
5.3.1	Determination of maximum surface temperature	Applies
5.3.2.1	Group I electrical equipment	Excluded
5.3.2.2	Group II electrical equipment	Applies
5.3.2.3	Group III electrical equipment	Applies
5.3.3	Small component temperature for Group I and Group II electrical equipment	Excluded
6.1	General	Applies
6.2	Mechanical strength	Excluded
6.3	Opening times	Excluded
6.4	Circulating currents	Excluded
6.5	Gasket retention	Excluded
6.6	Electromagnetic and ultrasonic radiating equipment	Applies
7.1	General	Excluded
7.2	Thermal endurance	Excluded
7.3	Resistance to light	Modified
7.4	Electrostatic charges on external non-metallic materials	Excluded
7.5	Accessible metal parts	Excluded
8	Metallic enclosures and metallic parts of enclosures	Excluded
9	Fasteners	Excluded
10	Interlocking devices	Excluded
11	Bushings	Excluded
12	Materials used for cementing	Excluded
13	Ex components	Excluded
14	Connection facilities and termination compartments	Excluded
15	Connection facilities for earthing and bonding conductors	Excluded
16	Entries into enclosures	Excluded
17	Supplementary requirements for rotating electrical machines	Excluded
18	Supplementary requirements for switchgear	Excluded
19	Supplementary requirements for fuses	Excluded
20	Supplementary requirements for plugs and sockets	Excluded
21	Supplementary requirements for luminaires	Excluded
22	Supplementary requirements for caplights and handlights	Excluded
23	Equipment incorporating cells and batteries	Excluded
24	Documentation	Applies
25	Compliance of prototype or sample with documents	Applies
26.1	General	Applies
26.2	Test configuration	Applies
26.3	Tests in explosive test mixtures	Excluded

Clause of IEC 60079-0		IEC 60079-0 application to IEC 60079-13
Ed. 6.0 (2011) (Informative)	Clause / subclause title (Normative)	
26.4	Tests of enclosures	Excluded
26.5	Thermal tests	Excluded
26.6	Torque test for bushings	Excluded
26.7	Non-metallic enclosures or non-metallic parts of enclosures	Excluded
26.8	Thermal endurance to heat	Excluded
26.9	Thermal endurance to cold	Excluded
26.10	Resistance to light	Applies
26.11	Resistance to chemical agents for Group I electrical equipment	Excluded
26.12	Earth continuity	Excluded
26.13	Surface resistance test of parts of enclosures of non-metallic materials	Excluded
26.14	Measurement of capacitance	Excluded
26.15	Verification of ratings of ventilating fans	Excluded
26.16	Alternative qualification of elastomeric sealing O-rings	Excluded
27	Routine tests	Applies
28	Manufacturers responsibility	Applies
29.1	Applicability	Applies
29.2	Location	Modified
29.3	General	Modified
29.4	Ex marking for explosive gas atmospheres	Modified
29.5	Ex marking for explosive dust atmospheres	Applies
29.6	Combined types of protection	Applies
29.7	Multiple types of protection	Excluded
29.8	Ga using two independent Gb types of protection	Excluded
29.9	Ex components	Excluded
29.10	Small equipment and small Ex components	Excluded
29.11	Extremely small equipment and extremely small Ex components	Modified
29.12	Warning markings	Applies
29.13	Alternate marking of equipment protection levels (EPLs)	Excluded
29.14	Cells and batteries	Applies
30	Instructions	Modified
Annex A	Supplementary requirements for Ex cable glands	Excluded
Annex B	Requirements for Ex components	Excluded
Annex C	Example of rig for resistance to impact test	Excluded
Annex D	Introduction to an alternative risk assessment method encompassing "equipment protection levels" for Ex equipment	Applies
<p>Applies: this requirement of IEC 60079-0 is applied without change.</p> <p>Excluded: this requirement of IEC 60079-0 does not apply.</p> <p>Modified: this requirement of IEC 60079-0 is modified as detailed in this document.</p> <p>NOTE The applicable requirements of IEC 60079-0 are identified by the clause title which is normative. This table was written against the specific requirements of IEC 60079-0, Ed 6.0.</p>		

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition

cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-426, *International Electrotechnical Vocabulary – Part 426: Equipment for explosive atmospheres*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-10-1, *Explosive atmospheres – Part 10-1: Classification of areas – Explosive gas atmospheres*

IEC 60079-29 (all parts), *Explosive atmospheres – Gas detectors*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-426, IEC 60079-0 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE Unless otherwise specified, the terms "voltage" and "current" mean the RMS values of an alternating, direct or composite voltage or current.

3.1

airlock

means of egress, consisting of two interdependent doors designed to maintain the internal pressure of the room in order to prevent or significantly reduce the entry of a surrounding explosive atmosphere

3.2

alarm

piece of apparatus that generates a visual or audible signal that is intended to attract attention

[SOURCE: IEC 60050-426:2008, 426-09-05]

3.3

clean air

air that is essentially free of combustible dust, and contains no more than trace amounts of flammable vapour or gas

3.4

dilution

mixing of flammable vapour or gas with air which, over time, will reduce the flammable concentration

Note 1 to entry: For safety reasons, dilution to a level lower than the lower explosive limit (LEL) can be required if associated with the potential release there is an additional toxic or asphyxiant risk. Further guidance can be found in IEC 61285.

[SOURCE: IEC 60079-10-1:2015, 3.5.2, modified – The note to entry has been added.]

3.5**internal source of release**

point or location indoors from which a gas, vapour, mist or liquid may be released into the atmosphere such that an explosive gas atmosphere could be formed

3.6**limiting value**

lowest concentration value of the lower flammable limit (LFL) of each component involved, taking account of the most onerous conditions of concentration that may occur from every internal source of release within the room

3.7**lower flammable limit****LFL**

volume fraction of flammable gas or vapour in air below which an explosive gas atmosphere will not form, expressed as a percentage

Note 1 to entry: Although the lower explosive limit (LEL) is often used in place of the lower flammable limit (LFL), it should be recognized that the LFL is often slightly lower than the LEL.

Note 2 to entry: See IEC 60079-20-1.

[SOURCE: IEC 60079-2:2014, 3.24, modified – In the definition, the parentheses have been moved to a second note to entry, and the existing note has been replaced by a new note.]

3.8**opening**

inlet, outlet, door or non-airtight fixed panel

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.9**pressurization**

technique of guarding against the ingress of the external atmosphere into a room by maintaining clean air therein at a pressure above that of the external atmosphere

[IEC 60079-13:2017](https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-1e571093e601/iec-60079-13-2017)

<https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-1e571093e601/iec-60079-13-2017>

3.10**pressurization system**

grouping of safety devices and other components used to pressurize and monitor or control a pressurized room

3.11**restricted access door**

door with controlled or limited use or alarmed when open

3.12**safety device**

item used to implement or maintain the integrity of the type of protection

3.13**pressurized room**

room volume protected by pressurization and of sufficient size to permit the entry of a person who may occupy the room

3.14**artificially ventilated room**

room volume protected by artificial ventilation and of sufficient size to permit the entry of a person who may occupy the room

Note 1 to entry: The room volume can be an entire room (general) or part of a room (local ventilation).

3.15**purging**

operation of passing a quantity of clean air through the room and ducts in a pressurized or artificially ventilated room, so that the concentration of the explosive gas atmosphere is brought to a safe level

3.16**room volume**

<of the pressurized or artificially ventilated room> volume of the empty room and including any associated ducting without internal equipment

3.17**pressurization "pb"**

pressurized room that provides an equipment protection level Gb or Db

3.18**pressurization "pc"**

pressurized room that provides an equipment protection level Gc or Dc

3.19**artificial ventilation "vc"**

artificial ventilation of a room with or without an internal source of release, such that the room provides an equipment protection level Gc

3.20**artificial ventilation**

technique of guarding against an explosive atmosphere by the use of mechanical means to provide for the movement of air

3.21**ventilation system**

complete installation required to produce artificial ventilation

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60079-13:2017](https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2275781bfc5d/iec-60079-13-2017)

<https://standards.iteh.ai/catalog/standards/sist/e351c9f5-90ef-4e3e-b456-2275781bfc5d/iec-60079-13-2017>

4 Requirements for all rooms

4.1 General

Protection by pressurization and protection by artificial ventilation are separately described but may be combined to protect against hazards where required. Where both techniques are combined, then requirements for both shall apply. Unless otherwise identified in Clauses 6 or 7, the requirements in 4.2 to 4.10 apply to both protection techniques.

NOTE Annex C provides examples of applications and associated guidelines.

4.2 Type and level of protection

4.2.1 Pressurization "p"

Rooms with pressurization "p" and located in a hazardous area shall be one of the following:

- a) Level of protection "pb" (EPL Gb or Db). The pressurized room maintains an internal overpressure reducing the risk of ingress of an explosive atmosphere and is suitable for use in an area requiring EPL Gb or Db, permitting unprotected equipment to be installed within the pressurized room except for pressurization safety devices (see 6.3.1).
- b) Level of protection "pc" (EPL Gc or Dc). The pressurized room maintains an internal overpressure reducing the risk of the ingress of an explosive atmosphere and is suitable for use in an area requiring EPL Gc or Dc, permitting unprotected equipment to be installed within the pressurized room except for pressurization safety devices (see 6.3.1).