
Specifikacija vmesnika orodja procesne naprave - 303-2. del: Integracija komunikacijskih profilov - IEC 61784 CP 3/4, CP 3/5 in CP 3/6 (IEC 62453-303-2:2009)

Field device tool interface specification -- Part 303-2: Communication profile integration - IEC 61784 CP 3/4, CP 3/5 and CP 3/6

Field Device Tool (FDT)-Schnittstellenspezifikation - Teil 303-2: Integration von Kommunikationsprofilen - IEC 61784 Kommunikationsprofile (CP) 3/4, 3/5 und 3/6

Spécification des interfaces des outils des dispositifs de terrain (FDT) - Partie 303-2: Intégration des profils de communication - CEI 61784 CP 3/4, CP 3/5 et CP 3/6

Ta slovenski standard je istoveten z: EN 62453-303-2:2009

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.240.50	Uporabniške rešitve IT v industriji	IT applications in industry

SIST EN 62453-303-2:2010**en,fr**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62453-303-2:2010

<https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cffff9da/sist-en-62453-303-2-2010>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 62453-303-2

October 2009

ICS 25.040.40; 35.100.05; 35.110

English version

**Field device tool (FDT) interface specification -
Part 303-2: Communication profile integration -
IEC 61784 CP 3/4, CP 3/5 and CP 3/6
(IEC 62453-303-2:2009)**

Spécification des interfaces des outils
des dispositifs de terrain (FDT) -
Partie 303-2: Intégration des profils
de communication -
CEI 61784 CP 3/4, CP 3/5 et CP 3/6
(CEI 62453-303-2:2009)

Field Device Tool (FDT)-
Schnittstellenspezifikation -
Teil 303-2: Integration
von Kommunikationsprofilen -
Kommunikationsprofile (CP)
3/4, 3/5 und 3/6 nach IEC 61784
(IEC 62453-303-2:2009)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This European Standard was approved by CENELEC on 2009-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 65E/128/FDIS, future edition 1 of IEC 62453-303-2, prepared by SC 65E, Devices and integration in enterprise systems, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62453-303-2 on 2009-08-01.

Each part of the EN 62453-3xy series is intended to be read in conjunction with EN 62453-2.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2010-05-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2012-08-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 62453-303-2:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 61158

NOTE Harmonized in EN 61158 series (not modified).

[SIST EN 62453-303-2:2010](https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010)

<https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010>

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-5-10	– ¹⁾	Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements	EN 61158-5-10	2008 ²⁾
IEC 61158-6-10	– ¹⁾	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	EN 61158-6-10	2008 ²⁾
IEC 61784-2	– ¹⁾	Industrial communication networks - Profiles - Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3	EN 61784-2	2008 ²⁾
IEC 62453-1	2009	Field device tool (FDT) interface specification - Part 1: Overview and guidance	EN 62453-1	2009
IEC 62453-2	2009	Field device tool (FDT) interface specification - Part 2: Concepts and detailed description	EN 62453-2	2009

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62453-303-2:2010](https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010)

<https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010>



IEC 62453-303-2

Edition 1.0 2009-06

INTERNATIONAL STANDARD

**Field device tool (FDT) interface specification –
Part 303-2: Communication profile integration – IEC 61784 CP 3/4, CP 3/5 and
CP 3/6**

ITIL STANDARD PREVIEW
(standards.iteh.ai)
[SIST EN 62453-303-2:2010
https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010](https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE



ICS 25.040.40; 35.100.05; 35.110

ISBN 2-8318-1050-2

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions, symbols, abbreviated terms and conventions.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	8
3.3 Conventions.....	8
3.3.1 Data type names and references to data types.....	8
3.3.2 Vocabulary for requirements.....	8
3.3.3 Use of UML.....	8
4 Bus category.....	8
5 Access instance and device data.....	9
5.1 Process Channel objects provided by DTM.....	9
5.2 DTM services to access instance and device data.....	9
6 Protocol specific behavior.....	9
7 Protocol specific usage of general data types.....	9
8 Protocol specific common data types.....	11
9 Network management data types.....	11
9.1 General.....	11
9.2 Parameter access data types.....	11
10 Communication data types.....	17
11 Channel parameter data types.....	20
12 Device identification.....	23
12.1 Protocol specific handling of data type STRING.....	23
12.2 Device type identification data types.....	23
12.3 Topology scan data types.....	26
12.4 Scan identification data types.....	27
12.5 Device type identification data types.....	29
Bibliography.....	32
Figure 1 – Part 303-2 of the IEC 62453 series.....	6
Table 1 – Protocol identifier.....	8
Table 2 – Physical layer identifier.....	8
Table 3 – Protocol specific usage of general data types.....	9
Table 4 – Simple parameter access data types.....	11
Table 5 – Structured parameter access data types.....	14
Table 6 – Simple communication data types.....	17
Table 7 – Structured communication data types.....	18
Table 8 – Simple channel parameter data types.....	21
Table 9 – Structured channel parameter data types.....	22
Table 10 – Identification data types for PROFINET with pure DCP.....	24

Table 11 – Identification data types for PROFINET with I&M.....	25
Table 12 – Simple identification data types with protocol independent semantics.....	26
Table 13 – Structured identification data types with protocol independent semantics	26
Table 14 – Simple device type identification data types	26
Table 15 – Structured device type identification data type.....	27
Table 16 – Simple scan identification data types.....	27
Table 17 – Structured scan identification data types	28
Table 18 – Structured device type identification data types	29

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62453-303-2:2010](https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010)

<https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

**Part 303-2: Communication profile integration –
IEC 61784 CP 3/4, CP 3/5 and CP 3/6**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62453-303-2 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

This part, in conjunction with the other parts of the first edition of the IEC 62453 series cancels and replaces IEC/PAS 62453-1, IEC/PAS 62453-2, IEC/PAS 62453-3, IEC/PAS 62453-4 and IEC/PAS 62453-5 published in 2006, and constitutes a technical revision.

Each part of the IEC 62453-3xy series is intended to be read in conjunction with IEC 62453-2.

The text of this standard is based on the following documents:

FDIS	Report on voting
65E/128/FDIS	65E/141/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62453 series, under the general title *Field Device Tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IFU STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62453-303-2:2010

<https://standards.iteh.ai/catalog/standards/sist/d84bf9ed-2e61-442c-9b49-9573cfff9da/sist-en-62453-303-2-2010>

INTRODUCTION

This part of IEC 62453 is an interface specification for developers of FDT (Field Device Tool) components for function control and data access within a client/server architecture. The specification is a result of an analysis and design process to develop standard interfaces to facilitate the development of servers and clients by multiple vendors that need to interoperate seamlessly.

With the integration of fieldbuses into control systems, there are a few other tasks which need to be performed. In addition to fieldbus- and device-specific tools, there is a need to integrate these tools into higher-level system-wide planning- or engineering tools. In particular, for use in extensive and heterogeneous control systems, typically in the area of the process industry, the unambiguous definition of engineering interfaces that are easy to use for all those involved is of great importance.

A device-specific software component, called DTM (Device Type Manager), is supplied by the field device manufacturer with its device. The DTM is integrated into engineering tools via the FDT interfaces defined in this specification. The approach to integration is in general open for all kinds of fieldbuses and thus meets the requirements for integrating different kinds of devices into heterogeneous control systems.

Figure 1 shows how IEC 62453-303-2 is aligned in the structure of the IEC 62453 series.




Figure 1 – Part 303-2 of the IEC 62453 series