

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control room for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Salle de commande supplémentaire pour l'arrêt des réacteurs sans accès à la salle de commande principale

ITeH STANDARD PREVIEW
(standards.iteh.ai)

IEC 60965:2016
<https://standards.iteh.ai/catalog/standards/sis/25ad6965-416f-4432-9cc9-e97ecbe46309/iec-60965-2016>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control room for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Salle de commande supplémentaire pour l'arrêt des réacteurs sans accès à la salle de commande principale

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.120.20

ISBN 978-2-8322-3203-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	8
4 Abbreviations	9
5 Design principles	9
5.1 General.....	9
5.2 Main objectives	10
5.3 Safety principles	11
5.3.1 Design basis and design extension conditions	11
5.3.2 Functionality and qualification	12
5.3.3 Accessibility and operator transfer time	12
5.3.4 Control transfer, control prioritisation and security	12
5.3.5 Operational considerations	13
5.4 Human factors engineering principles	14
6 Design process.....	14
7 Functional design	15
7.1 General.....	15
7.2 Human factors.....	15
7.3 Location and access route	15
7.4 SCR environment.....	16
7.5 Space and configuration.....	16
7.6 Information and control equipment.....	17
7.7 Communication systems.....	17
7.8 Other equipment	18
7.9 Testing and inspection	18
8 System verification and validation	18
Annex A (informative) Assessment of safe transfer time window	20
Bibliography	21

ITeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 60965:2016

<https://standards.iteh.ai/catalog/standards/sist/25adb9b3-416f-4432-9ee9-e97ecbe46309/iec-60965-2016>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR POWER PLANTS – CONTROL ROOMS –
SUPPLEMENTARY CONTROL ROOM FOR REACTOR SHUTDOWN
WITHOUT ACCESS TO THE MAIN CONTROL ROOM**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
<https://standards.iteh.ai/catalog/standards/si/25db9b3-4166-4433-9e19-7e0c00000000/iec-60965-2016>
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60965 has been prepared by subcommittee 45A: Instrumentation, control and electrical systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) requirements associated with regular testing of the supplementary control room (SCR);
- b) requirements to assess the time available during which the reactor will be safe but unattended, in order to move from the main control room (MCR) to the SCR and for the SCR to become operational;
- c) reference to SSR-2/1 which includes the following new requirements:

- 1) the SCR should be functionally (as well as physically and electrically) separate from the MCR,
 - 2) consideration shall be given to the provision of shielding against radioactivity on the access paths to the SCR;
- d) reference to DS431, the revision of NS-G-1.3, including the following new requirements:
- 1) to implement at least two diverse methods for communication with a set of predefined locations,
 - 2) to implement features to support monitoring of trends in key plant parameters;
- e) requirements for the role, functional capability and robustness of the SCR in design extension conditions;

The text of this standard is based on the following documents:

FDIS	Report on voting
45A/1060/FDIS	45A/1078/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn, <https://standards.iteh.ai/catalog/standards/sist/25adb9b3-416f-4432-9ee9-97ecbe46309/iec-60965-2016>
- replaced by a revised edition, or
- amended.

INTRODUCTION

a) Technical background, main issues and organization of the standard

IEC 60965:1989 was developed to provide requirements relevant to the design of NPP supplementary control points for reactor shutdown without access to the main control room. The first edition of IEC 60965 has been used extensively within the nuclear industry. It was however recognized in 2007 that technical developments especially those which were based on software technology should be incorporated. It was also recognized that the relationships with the standard for the main control room (i.e. IEC 60964) and the derivative standards to that standard (i.e. IEC 61227, IEC 61771, IEC 61772, IEC 61839, and IEC 62241) should be clarified and conditioned. In 2009 the second edition of IEC 60965 was published.

In June 2013, during the Moscow meeting, WG A8 experts recommended a limited revision be launched to take into account the lessons learned from TEPCO Fukushima Daiichi accident and some comments formulated during the circulation of the published second edition. In the course of development of this revision, the title of the standard was amended to refer to Supplementary Control 'Room' for consistency with IAEA SSR-2/1.

This IEC standard specifically focuses on the functional design process of the supplementary control room of an NPP. It is intended that the standard be used by NPP designers, design authorities, vendors, utilities, and by licensors.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

IEC 60965 is the third level IEC SC 45A document tackling the issue of the design of a supplementary control room.

IEC 60965 is to be read in association with IEC 60964 for the design of the main control room (including the derivative standards mentioned above) which is the appropriate IEC SC 45A document providing guidance on operator controls, verification and validation of design, application of visual display units, functional analysis and assignment, and alarm functions and presentation.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this Standard

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control room of a nuclear power plant to meet safety requirements.

This standard is intended for application to a supplementary control room whose conceptual design is initiated after the publication of this standard. The recommendations of the standard may be used for refits, upgrades and modifications.

Aspects for which special recommendations have been provided in this Standard, in accordance with IAEA safety standards, are:

- definition of the MCR and plant design bases for which the supplementary control room are to be used;
- access by station staff to the supplementary control room in such emergencies;
- assurance for the station staff that the environment in the supplementary control room is safe when it is to be used;
- provision of information in the supplementary control room on the state of the reactor critical functions;
- transfer of control and indication functions from the main control room to the supplementary control room in emergencies;
- independence and separation of the cabling used by the supplementary control room from that used by the main control room;
- assurance that a safe state has been reached using the supplementary control room;

- communication facilities between the supplementary control room and to the station management.

To ensure that the Standard will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.

IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer-based systems, hardware aspects of computer-based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45A standard series corresponds to the Technical Reports which are not normative.

IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework. Regarding nuclear safety, it provides the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4 for the nuclear application sector, regarding nuclear safety. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 refers to ISO as well as to IAEA GS-R-3, IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements SSR-2/1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

NOTE It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied, that are based on the requirements of a standard such as IEC 61508.

NUCLEAR POWER PLANTS – CONTROL ROOMS – SUPPLEMENTARY CONTROL ROOM FOR REACTOR SHUTDOWN WITHOUT ACCESS TO THE MAIN CONTROL ROOM

1 Scope

This International Standard establishes requirements for the Supplementary Control Room provided to enable the operating staff of nuclear power plants to shut down the reactor, where previously operating, and maintain the plant in a safe shut-down state in the event that control of the safety functions can no longer be exercised from the Main Control Room, due to unavailability of the Main Control Room or its facilities. The design has to ensure that the Supplementary Control Room is protected against the hazards, including any localised extreme hazards, leading to the unavailability of the Main Control Room.

The standard also establishes requirements for the selection of functions, the design and organisation of the human-machine interface, and the procedures which shall be used systematically to verify and validate the functional design of the supplementary control room.

It is assumed that supplementary control room provided for shutdown operations from outside the main control room would be unattended during normal plant conditions other than for periodic testing. The requirements reflect the application of human engineering principles as they apply to the human-machine interface during such periodic testing and during abnormal plant conditions.

This standard does not cover special emergency response facilities (e.g. a technical support centre) or facilities provided for radioactive waste handling. Detailed equipment design is also outside the scope of the standard.

This standard follows the principles of IAEA Specific Safety Requirements SSR-2/1 and IAEA Safety Guide NS-G-1.3.

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control room of a nuclear power plant to meet safety requirements.

This standard is intended for application to a supplementary control room whose conceptual design is initiated after the publication of this standard. If it is desired to apply it to existing plants or designs, special care must be taken to ensure a consistent design basis. This relates, for example, to factors such as the consistency between the supplementary control room and the main control room, the ergonomic approach, the automation level and the information technology, and the extent of modifications to be implemented in I&C systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60709, *Nuclear power plants – Instrumentation and control systems important to safety – Separation*

IEC 60964:2009, *Nuclear power plants – Control rooms – Design*

IEC 61226, *Nuclear power plants – Instrumentation and control important to safety – Classification of instrumentation and control functions*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 61771, *Nuclear power plants – Main control-room – Verification and validation of design*

IEC 62646, *Nuclear power plants – Control rooms – Computer based procedures*

ISO 11064 (all parts), *Ergonomic design of control centres*

ISO 11064-1, *Ergonomic design of control centres – Part 1: Principles for the design of control centres*

ISO 11064-3, *Ergonomic design of control centres – Part 3: Control room layout*

ISO 11064-6, *Ergonomic design of control centres – Part 6: Environmental requirements for control centres*

IAEA SSR-2/1:2012, *Safety of nuclear power plants: Design*

IAEA NS-G-1.3:2002, *Instrumentation and Control Systems Important to Safety in Nuclear Power Plants (to be replaced by SSG-39)*

(standards.iteh.ai)

3 Terms and definitions

IEC 60965:2016

For the purposes of this document, the following terms and definitions apply. For other terms, refer to the general terminology defined in IEC 60964, IEC 61513 and in the IAEA NUSS programme, such as Safety Guide NS-G-1.3 or the safety glossary.

3.1

control room staff

group of plant personnel stationed in the control room, which is responsible for achieving the plant operational goals by controlling plant through the human-machine interface. Typically, the control room staff consists of supervisory operators, and operators who actually monitor plant and plant conditions and manipulate controls, but may also include those staff members and experts who are authorised to be present in the control room, e.g. during long lasting event sequences

[SOURCE: IEC 60964:2009, 3.4]

3.2

design extension conditions

postulated accident conditions that are not considered for design basis accidents, but that are considered in the design process of the facility in accordance with best estimate methodology, and for which releases of radioactive material are kept within acceptable limits. Design extension conditions include conditions in events without significant fuel degradation and conditions with core melting

[SOURCE: IAEA SSR-2/1:2012, definitions revised as DS462]

3.3

local control points

local control facilities

points (or facilities) located outside the control room where local operators perform control activities

[SOURCE: IEC 60964:2009, 3.17]

3.4

local operators

operating staff that perform tasks outside the control room

[SOURCE: IEC 60964:2009, 3.18]

3.5

operating staff

plant personnel working on shift to operate the plant. The operating staff includes the control room staff, maintenance engineers, etc.

[SOURCE: IEC 60964:2009, 3.20]

3.6

supplementary control room

location from which limited plant control and/or monitoring can be carried out to accomplish the safety functions identified by the safety analysis as required in the event of a loss of ability to perform those functions from the Main Control Room

Note 1 to entry: For existing plants, the Supplementary Control Room may be a special control room, but in many cases comprises sets of control panels and displays in switchgear rooms or similar areas. In the latter case, the term 'supplementary control point' is used in this standard

4 Abbreviations

CBP	Computer-Based Procedure
I&C	Instrumentation and Control
LCP	Local Control Point
MCR	Main Control Room
NPP	Nuclear Power Plant
PIE	Postulated Initiating Event
SCR	Supplementary Control Room
V&V	Verification and Validation

5 Design principles

5.1 General

Requirement 66 of IAEA SSR-2/1 states: "Instrumentation and control equipment shall be kept available, preferably at a single location (a supplementary control room) that is physically, electrically and functionally separate from the control room at the nuclear power plant. The supplementary control room shall be so equipped that the reactor can be placed and maintained in a shutdown state, residual heat can be removed, and essential plant variables can be monitored if there is a loss of ability to perform these essential safety functions in the control room."

NOTE 1 The reference to "control room" is interpreted in this standard as "main control room (MCR)".

NOTE 2 Functional separation means that the function of the SCR can be performed despite postulated malfunctions in the MCR.

NOTE 3 Complete functional separation of paths from human-machine interface control points out to end devices may be difficult to achieve for all I&C functions, especially for example when a shared actuator requires a common priority logic controller to select between MCR and SCR control. Any such common equipment is acceptable if adequate redundant, backup, or field equipment exists that can achieve the required actuation function and is sufficiently separated from common hazards to minimize the risk that the function may be completely disabled.

Subclauses 6.15 to 6.30 of IAEA NS-G-1.3 provide guidance on the requirements for supplementary control rooms, including requirements associated with the following:

- definition of the plant design bases that require use of the SCR (6.17, 6.19, 6.20);
- location and configuration of the SCR to promote prompt mobilisation (6.29);
- qualified access path to the SCR, with hazard indication and suitable countermeasures along this path (6.27, 6.28);
- prevention of unauthorised access to or use of the SCR (6.21);
- safety functions of the MCR and SCR not affected by the same PIE, and independence of the circuits associated with the SCR from those of the MCR (6.20, 6.23);
- priority of control between the MCR and SCR, and transfer of control from the MCR to the SCR (6.18, 6.20, 6.24);
- manual control in the SCR accomplished by simple actions (clause 6.22);
- displays and controls in the SCR similar to those in the MCR, to the extent possible (6.22);
- consideration of the difference of purpose between the MCR and the SCR (6.25);
- if long-term use is envisaged, suitable facilities for habitability and workspace for tasks (6.30).

5.2 Main objectives

IEC 60965:2016

<https://standards.iteh.ai/catalog/standards/sist/25adb9b3-416f-4432-9ee9-c0c46597ee-60965-2016>

The IAEA requirements for the design of the SCR given in 5.1, paragraph 1, shall be met as detailed in this standard.

The SCR shall be provided with the means to trip the reactor and bring the plant to a safe state and maintain it in that state without access to the MCR. However, the SCR is not required to perform all the other plant control and monitoring functions which are typically performed in the MCR. According to the type of NPP and the detailed safety arguments, provisions to cope with a predefined set of PIE could be integrated in the SCR.

The SCR is required when the ability to perform safety functions in the MCR is lost. Possible causes include a control room fire, the entry of excess smoke or a dangerous atmosphere to the MCR, severe damage to the MCR or its cables such that safety functions cannot be performed, major damage to the control room area, or major failure of control room facilities.

The design basis PIE and sequences of events for which use of the SCR is necessary shall be identified. This shall include identification and justification of the assumed conditions throughout the plant and the corresponding durations for which the SCR may be required.

Since events leading to the unavailability of the MCR are very infrequent, it is anticipated that the plant safety analysis will demonstrate that such events can only coincide with another independent event in the plant at an acceptably low frequency; in particular, it is anticipated that the primary coolant circuit will be intact. However, due account shall be taken of any plant fault that may occur as a consequence of reactor trip and of any plant faults at shutdown that are of sufficient frequency to coincide with use of the SCR. In particular, the design of the SCR shall take account of the possible long-term unavailability of the MCR due to fire or other reasons.

The criteria for use of the SCR shall be clearly stated in the plant operating procedures.

It shall be possible to determine the complete safety state of the plant from outside the MCR. This should preferably be from the SCR. The SCR should therefore enable the monitoring of the state of the relevant plant systems and key plant parameters. All information presented should comply with the ergonomic principles presented in the relevant parts of ISO 11064.

For the purpose of efficient monitoring and later analysis of the events, key plant parameters should be recorded to allow display of trends and later access for offline analysis. Automatic recording is recommended. If the MCR and SCR are assumed not to be staffed for an extended period of time, automatic recording shall be provided.

From an operational viewpoint (e.g. to simplify operation and avoid misunderstanding), it is preferable to have only one supplementary control room. Care shall be taken, however, to meet safety requirements, particularly requirements for redundancy and independence. If two or more supplementary control points are provided for an existing plant, each supplementary control point should display all information needed to perform the operator tasks.

Computer-based information displays in the SCR should provide the same functionality for the presentation of information important to safety as the corresponding displays in the MCR. The content of the displays for a given plant state and for given operator tasks should be the same as in the MCR.

There shall be adequate time to reach the SCR before necessary actions are required as well as sufficient equipment to provide necessary communication between all operating staff involved in these actions and with on-site and off-site locations. Communication requirements are given in 7.7.

The layout of the instrumentation and the mode of presentation at the SCR shall provide the operating staff with adequate information to assess the plant state and to supervise the shutdown (and subsequent hold down) of the reactor, the long-term cooling of the reactor core and confinement of all radioactive substances.

The plant systems that can be controlled from the SCR may be limited to those providing the safety functions.

The SCR shall provide sufficient control over the safety functions to reach and maintain a safe state, for the defined set of PIEs and conditions for which the MCR cannot be used. The supervision and control provided at the SCR shall include the state of the safety functions concerned and control of their initiation and termination, and the state of the related fundamental safety functions (see IAEA SSR-2/1:2012, Requirement 4).

Facilities for site security monitoring, plant access control and fire alarms which are normally provided in the MCR shall also be provided in an independent location. This independent location may be the SCR or may be a location that would not be affected by the same event that causes the SCR to be used. Where the latter applies, the facilities location shall have a hazard withstand capability equivalent to that of the SCR.

The design of SCR shall be consistent with the MCR design. The identification and design process for the relevant controls and indications needed for the SCR shall follow the requirements of IEC 60964, as summarised in Clause 6 of this standard.

5.3 Safety principles

5.3.1 Design basis and design extension conditions

The design basis of an NPP normally specifies the internal and external hazards to be taken into account. The design shall ensure that such events are not able to make those functions of the MCR and SCR (and local control points) required for safe shutdown, monitoring to ensure safe shutdown and critical functions control and monitoring, unusable or ineffective simultaneously.