

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Automatic electrical controls –  
Part 2-6: Particular requirements for automatic electrical pressure sensing  
controls including mechanical requirements**

**Dispositifs de commande électrique automatiques –  
Partie 2-6: Exigences particulières pour les dispositifs de commande électrique  
automatiques sensibles à la pression y compris les exigences mécaniques**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms, containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Catalogue IEC - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

#### Recherche de publications IEC - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 21 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Automatic electrical controls –**  
**Part 2-6: Particular requirements for automatic electrical pressure sensing**  
**controls including mechanical requirements**

**Dispositifs de commande électrique automatiques –**  
**Partie 2-6: Exigences particulières pour les dispositifs de commande électrique**  
**automatiques sensibles à la pression y compris les exigences mécaniques**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 97.120

ISBN 978-2-8322-5268-0

**Warning! Make sure that you obtained this publication from an authorized distributor.**  
**Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD .....	4
1 Scope and normative references .....	7
2 Terms and definitions .....	8
3 General requirements .....	9
4 General notes on tests .....	10
5 Rating.....	10
6 Classification .....	10
7 Information .....	11
8 Protection against electric shock .....	11
9 Provision for protective earthing .....	11
10 Terminals and terminations.....	11
11 Constructional requirements .....	12
12 Moisture and dust resistance .....	14
13 Electric strength and insulation resistance .....	14
14 Heating.....	14
15 Manufacturing deviation and drift.....	14
16 Environmental stress .....	15
17 Endurance .....	15
18 Mechanical strength .....	16
19 Threaded parts and connections .....	17
20 Creepage distances, clearances and distances through solid insulation.....	17
21 Resistance to heat, fire and tracking.....	17
22 Resistance to corrosion .....	18
23 Electromagnetic compatibility (EMC) requirements – Emission .....	18
24 Components .....	18
25 Normal operation .....	18
26 Electromagnetic compatibility (EMC) requirements – Immunity .....	18
27 Abnormal operation .....	18
28 Guidance on the use of electronic disconnection .....	18
Annexes .....	19
Annex H (normative) Requirements for electronic controls .....	20
Annex AA (normative) Number of cycles .....	27
AA.1 Number of cycles for independently mounted controls.....	27
AA.2 Cycling rate for independently mounted controls .....	27
Annex BB (informative) Stainless steel for bellows, bourdon tubes or similar elements .....	28
Annex CC (informative) Deviation and drift requirements for pressure operating controls.....	31
Bibliography.....	32

Table 1 (7.2 of edition 3) – Required information and methods of providing information .....	11
Table H.101 – Compliance criteria .....	22
Table BB.1 – Stainless steel for bellows, bourdon tubes or similar elements .....	28

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[IEC 60730-2-6:2015](https://standards.iteh.ai/catalog/standards/sist/1f97b374-cbd7-4b33-bcaa-b8bf3bb4215d/iec-60730-2-6-2015)

<https://standards.iteh.ai/catalog/standards/sist/1f97b374-cbd7-4b33-bcaa-b8bf3bb4215d/iec-60730-2-6-2015>

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## AUTOMATIC ELECTRICAL CONTROLS –

**Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.  
<https://standards.iteh.ai/catalog/standards/sist/197b374-cbd7-4b33-bcaa-3a0b42590e30/iec-60730-2-6-2015>
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-6 has been prepared IEC technical committee 72: Automatic electrical controls.

This bilingual version (2018-01) corresponds to the monolingual English version, published in 2015-04.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- a) aligns the text with IEC 60730-1, Edition 5;
- b) modifies requirements for Class B control function (H.27.1.2.2);
- c) modifies requirements for Class C control function (H.27.1.2.3);
- d) modifies requirements for faults during lock-out or safety- shut-down.

The text of this standard is based on the following documents:

FDIS	Report on voting
72/980/FDIS	72/992/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part 2 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition (2013) of that publication. Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements.

Where this part 2 states "addition", "modification", or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, this part 2 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practices are contained in the following subclauses:

10.1.4

15.1.101

18.101

Annex CC

In this publication:

- 1) The following print types are used:
  - Requirements proper: in roman type;
  - *Test specifications: in italic type;*
  - Notes; in small roman type;
  - Words defined in Clause 2: **bold**.
- 2) Subclauses, notes, tables and figures which are additional to those in part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

A list of all parts of the IEC 60730 series, published under the title *Automatic electrical controls* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## **iTeh STANDARD PREVIEW (standards.iteh.ai)**

[IEC 60730-2-6:2015](#)

<https://standards.iteh.ai/catalog/standards/sist/1f97b374-cbd7-4b33-bcaa-b8bf3bb4215d/iec-60730-2-6-2015>



## AUTOMATIC ELECTRICAL CONTROLS –

### Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements

#### 1 Scope and normative references

This clause of Part 1 is applicable except as follows:

##### 1.1 Scope

###### *Replacement:*

This part of IEC 60730 applies to automatic electrical pressure **sensing controls** with a minimum gauge pressure rating of –60 kPa and a maximum gauge pressure rating of 4,2 MPa, for use in, on or in association with, equipment. The equipment may use electricity, gas, oil, solid fuel, solar thermal energy, etc. or a combination thereof.

NOTE Throughout this standard, the word “equipment” includes “appliances” and “control system”.

This standard is also applicable to individual pressure **sensing controls** utilized as part of a **control system** or pressure **sensing controls** which are mechanically integral with multi-functional controls having non-electrical outputs.

Automatic electrical pressure **sensing controls** for equipment used by the public, such as equipment intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

This standard does not apply to pressure **sensing controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant equipment standard.

###### 1.1.1 *Replacement:*

This standard applies to inherent safety, **operating values**, **operating sequences** where such are associated with equipment protection, and to the testing of automatic electrical pressure **sensing controls** used in, on or in association with equipment.

This standard is also applicable to the functional safety of low complexity safety related pressure **sensing controls** and **systems**.

This standard is also applicable to pressure **sensing controls** for appliances within the scope of IEC 60335-1.

See also Annex J.

###### 1.1.2 *Addition:*

This standard applies to automatic **electrical controls**, mechanically or electrically operated, responsive to or controlling a pressure or vacuum.

###### 1.1.3 Not applicable.

#### 1.1.4 Replacement:

This standard applies to **manual controls** when such are electrically and/or mechanically integral with pressure **sensing controls**.

NOTE Requirements for manual switches not forming part of an **automatic control** are contained in IEC 61058-1.

#### 1.1.5

##### *Replacement:*

This standard applies to a.c. or d.c. powered pressure **sensing controls** with a rated voltage not exceeding 690 V a.c. or 600 V d.c.

#### 1.1.6

##### *Replacement:*

This standard does not take into account the **response value** of an **automatic action** of a pressure **sensing control**, if such a **response value** is dependent upon the method of mounting it in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer shall apply.

#### 1.1.7

##### *Replacement:*

This standard applies also to pressure **sensing controls** incorporating **electronic devices**, requirements for which are contained in Annex H.

This standard applies also to pressure **sensing controls** using NTC or PTC **thermistors**, requirements for which are contained in Annex J.

##### *Additional subclauses:*

**1.1.101** This standard contains requirements for electrical features of pressure **sensing controls** and requirements for mechanical features that affect their intended **operation**.

NOTE Subclause 18.101, as it pertains to gas and/or oil **controls**, is under consideration pending review or revision of ISO 22967, ISO 22968 and ISO 23550 series, if applicable.

**1.1.102** In general, these pressure **sensing controls** are integrated or incorporated with the equipment or are intended to be integrated in, or on the equipment. This standard also covers these **controls** when they are independently mounted. **In-line cord controls** are not covered by this standard.

## 2 Terms and definitions

This clause of Part 1 is applicable except as follows:

### 2.2 Definitions of types of control according to purpose

#### *Additional definitions:*

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

IEC 60730-2-6:2015  
<https://standards.iteh.ai/en/standards/sist/197b374-cbd7-4b33-bcaa-b8b3bb4215d/iec-60730-2-6-2015>

**2.2.101****pressure limiter**

pressure **sensing control** which is intended to keep a pressure below or above a predetermined value during normal operating conditions and which may have provision for **setting** by the user

Note 1 to entry: A pressure limiter may be of the automatic or of the manual reset type. It does not make the reverse **operation** during the normal **duty cycle** of the equipment.

**2.2.102****pressure operating control**

pressure **sensing control** set at a high or low pressure, or both, between which limits the equipment is normally intended to operate

**2.2.103****pressure cut-out**

pressure **sensing control** intended to keep a pressure below or above one particular value during abnormal operating conditions of the equipment and which has no provisions for **setting by the user**

Note 1 to entry: A pressure cut-out may be of the automatic or of the manual reset type.

A pressure cut-out will provide a Type 2 action.

A pressure cut-out may have an adjustable stop intended to be set by the **control manufacturer**, the **equipment manufacturer** or the **installer**.

**2.3 Definitions relating to the function of controls**

*Additional definitions:*

**2.3.101****pressure medium**

medium used to transmit the pressure to the pressure **sensing element**

Note 1 to entry: **Pressure medium** as used in this standard refers to either gases or liquids.

**2.3.102****differential pressure**

difference in a pressure between any two points in a **system**, between two **systems** or between a **system** and a reference pressure such as atmospheric pressure

Note 1 to entry: An example is the difference in static pressure between the upstream side of an orifice and the downstream side.

**2.8 Definitions relating to component parts of controls**

*Additional definition:*

**2.8.101****vent**

that opening from the atmospheric side of a diaphragm to the atmosphere through which air is discharged or drawn in when the **control** is functioning

**3 General requirements**

This clause of Part 1 is applicable.

## 4 General notes on tests

This clause of Part 1 is applicable except as follows:

### 4.1 Conditions of test

#### 4.1.7 Replacement:

*The rates of pressure change declared in Table 1 requirement 37, and used in Clause 17 (i.e.  $\alpha_1, \beta_1, \alpha_2, \beta_2$ ) shall have test tolerances as declared by the manufacturer.*

### 4.3 Instructions for test

#### 4.3.1 According to submission

*Additional subclause:*

**4.3.1.101** The values in Annex AA apply for the testing of independently mounted pressure **sensing controls** in Clause 17. Values for integrated and **incorporated controls** are specified in the appropriate equipment standard.

## 5 Rating

This clause of Part 1 is applicable.

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

## 6 Classification

[IEC 60730-2-6:2015](https://standards.iteh.ai/catalog/standards/sist/197b374-cbd7-4b33-bcaa-b8b3bb4215d/iec-60730-2-6-2015)

This clause of Part 1 is applicable except as follows:

### 6.3.9 – sensing control;

*Additional subclause:*

#### 6.3.9.101 – pressure sensing;

### 6.4.3

*Additional subclause:*

**6.4.3.101** – for sensing actions, no increase in the **operating value** as a result of any leakage from the **sensing element** or from parts connecting the **sensing element** to the **switch head** (Type 2.N).

#### 6.8.3 Replacement:

For an **independently mounted control** or a **control** integrated or incorporated in an assembly utilizing a non-electrical energy source:

## 7 Information

This clause of Part 1 is applicable except as follows:

### 7.2 Methods of providing information

**Table 1 (7.2 of edition 3) – Required information and methods of providing information**

Information	Clause or subclause	Method
<i>Modification:</i>		
<i>Replace the following requirements by:</i>		
6 Purpose of <b>control</b>	2.2.101 to 2.2.103 4.3.5 6.3	D
26 Number of cycles of <b>actuation</b> (M) for each <b>manual action</b>	6.10, Annex AA	X
27 Number of automatic cycles (A) for each <b>automatic action</b>	6.11, Annex AA	X
34 Not applicable		
44 Not applicable		
48 Operating pressure (or pressures)	2.3.11, 15, 18	D
<i>Additional requirements:</i>		
101 Pressure medium	2.3.101	X
102 <b>Operating differential</b>	2.3.26	D
103 <b>Maximum working pressure</b>	2.3.29	D
<i>Addition to Note i:</i>		
<p style="text-align: center;">IEC 60730-2-6:2015</p> <p>For pressure <b>sensing controls</b>, limits of activating quantity are specified either in the applicable appliance standard, by the appliance manufacturer or as declared by the pressure <b>sensing control manufacturer</b> (see 17.7 and 17.8).</p>		

## 8 Protection against electric shock

This clause of Part 1 is applicable.

## 9 Provision for protective earthing

This clause of Part 1 is applicable.

## 10 Terminals and terminations

This clause of Part 1 is applicable except as follows:

### 10.1 Terminals and terminations for external copper conductors

#### 10.1.4 Addition:

NOTE In the USA, **controls** for **operation** above 50 V shall be provided with suitable wiring terminals or leads for the connection of **fixed wiring** conductors having an ampere rating of no less than:

- 1,25 times the ampere rating of a fixed electric space-heating equipment load;
- 1,25 times the full-load motor current rating of a single motor;
- 1,25 times the combination load of a full-load motor current and 1,25 times a fixed electric space-heating equipment load;
- 1,25 times the full load current of the largest motor plus the full load amperes of the other loads;
- 1,0 times all other loads.

## 11 Constructional requirements

This clause of Part 1 is applicable except as follows:

### 11.4 Actions

*Additional subclause:*

#### 11.4.101 Type 2.N action

A Type 2.N action shall be so designed that in the event of a leak in the **sensing element**, or in any other part between the **sensing element** and the **switch head**, the declared disconnection or interruption is provided before the sum of the declared operating pressure and **drift** is exceeded.

*Compliance is checked by the following test:*

*The operating pressure of a Type 2.N control shall be measured under the conditions of Clause 15 of Part 1. If the control has means for setting, it shall be set to the highest value.*

*After this measurement, a hole is artificially produced in the sensing element and the measurement of the operating pressure is repeated.*

*No positive drift is allowed beyond the declared value.*

*A separate shroud or sleeve may be employed for protection of the sensing element to achieve conformance with Clause 18.*

NOTE The test can be replaced by theoretical computations of the physical mode of operation.

#### 11.11 Requirements during mounting, maintenance and servicing

*Additional subclauses:*

**11.11.101** Parts in contact with a diaphragm shall have no sharp burrs, projections or the like which might chafe or abrade the diaphragm.

*Compliance is checked by inspection before and after the tests of Clause 17.*

**11.11.102** An operating spring shall be retained and arranged to prevent abrasion, binding, buckling or interference with its free movement.

*Compliance is checked by inspection before and after the tests of Clause 17.*

**11.11.103** If **failure** of any part of the **control** would allow unsafe leakage of a hazardous fluid, that part shall be made of a material having a melting point (solidus temperature) of not less than 510 °C and a tensile strength of not less than 68 MPa at 204 °C.

Such parts shall not sag, distort, melt, oxidize or show leakage of fluid during any of the tests specified herein.

*Compliance is checked by inspection and the tests of Clause 17.*

**11.11.104** A part including a sheath, capillary tube, bellows or diaphragm shall be resistant to atmospheric corrosion and attack by the fluid it may normally contact in service, if **failure** of the part will permit external fluid leakage of a combustible fluid or cause the **control** to malfunction.

NOTE Brass alloys containing less than 81 % copper and more than 9 % zinc are not considered resistant to the corrosive effects of fuel oils.

**11.11.105** A **control** in which a flexible diaphragm, bellows or similar construction constitutes the only flammable gas or fluid seal shall have the atmospheric side of the diaphragm or bellows enclosed in a casing designed to limit external fluid leakage in the event of a diaphragm or bellows rupture or shall have provisions for connection of a vent pipe or tubing intended to be routed to the outdoors or other safe location.

**11.11.106** A **control** designed to supervise the pressure of fuel oil of 1,00 mm<sup>2</sup>/s to 600 mm<sup>2</sup>/s viscosity is not required to conform to 18.101 and 18.102, provided three samples of the **control**, when subjected to a 100 000 cycle endurance test, show no evidence of leakage during the test and when subjected to a hydrostatic test of four times the maximum working pressure, following the endurance test, and the **control** conforms to one of the following:

- a) the bellows, Bourdon tube, diaphragm or similar element is made of stainless steel or material of equivalent resistance to corrosion designated material Class A, if leakage from a ruptured element will be into the **control** enclosure, in which case such leakage is to be released to the exterior of the **control** before entering any opening provided for conduit connection, or
- b) the bellows, Bourdon tube, diaphragm or similar element is made of stainless steel or material of equivalent resistance to corrosion designated material Class B, if leakage from a ruptured element will be to the exterior of the **control** enclosure only.

NOTE 1 Suitable Class A and B materials are shown in Annex BB.  
NOTE 2 1 mm<sup>2</sup>/s = 1 centistoke.

*Additional subclauses:*

### **11.101 Construction requirements relating to operating mechanism**

**11.101.1** If screws and nuts serve to attach operating parts to movable members, they shall be swaged or otherwise locked.

**11.101.2** The operating mechanism of a manually operated switch shall not subject parts to damage.

**11.101.3** Operating parts shall be separated by barriers or by their physical location from conductors to be connected to the **control** to avoid interference with the movement of such parts by the conductors.

*Compliance with 11.101.1 to 11.101.3 inclusive is checked by inspection.*

**11.102** A pressure cut-out shall not reset, or be resettable manually or otherwise at a value above the maximum or below the minimum operating pressure, whichever is declared.

**11.103** A pressure cut-out with a manually operated reset device shall be **trip-free**.

*Compliance with 11.102 and 11.103 is checked by inspection.*