

INTERNATIONAL STANDARD

Automatic electrical controls –
Part 2-12: Particular requirements for electrically operated door locks
(standards.iteh.ai)

[IEC 60730-2-12:2015](https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8ebca3182d/iec-60730-2-12-2015)

<https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8ebca3182d/iec-60730-2-12-2015>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

IEC STANDARD PREVIEW
(standards.iec.ch)
IEC 60730-213:2015
0a8ebca3182d/iec-60730-2-12-2015



IEC 60730-2-12

Edition 3.0 2015-04

INTERNATIONAL STANDARD

Automatic electrical controls –
Part 2-12: Particular requirements for electrically operated door locks

STANDARD PREVIEW
(standards.iteh.ai)

IEC 60730-2-12:2015
<https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8ebca3182d/iec-60730-2-12-2015>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 97.120

ISBN 978-2-8322-2586-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
1 Scope and normative references	6
2 Terms and definitions	7
3 General requirements	8
4 General notes on tests	8
5 Rating	8
6 Classification	8
7 Information	9
8 Protection against electric shock	9
9 Provision for protective earthing	9
10 Terminals and terminations	10
11 Constructional requirements	10
12 Moisture and dust resistance	10
13 Electric strength and insulation resistance	10
14 Heating	10
15 Manufacturing deviation and drift	10
16 Environmental stress	10
17 Endurance	10
18 Mechanical strength	13
19 Threaded parts and connections	13
20 Creepage distances, clearances and distances through solid insulation	13
21 Resistance to heat, fire and tracking	13
22 Resistance to corrosion	13
23 Electromagnetic compatibility (EMC) requirements – Emission	13
24 Components	14
25 Normal operation	14
26 Electromagnetic compatibility (EMC) requirements – Immunity	14
27 Abnormal operation	14
28 Guidance on the use of electronic disconnection	16
Annexes	17
Annex H (normative) Requirements for electronic controls	17
Table 1 (7.2 of edition 3) – Required information and methods of providing information	9

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS –**Part 2-12: Particular requirements for
electrically operated door locks**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-12 has been prepared by technical committee 72: Automatic electrical controls.

This third edition cancels and replaces the second edition published in 2005. This edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- a) aligns the text with IEC 60730-1, Edition 5;
- b) modifies requirements for Class B control function (H.27.1.2.2);
- c) modifies requirements for Class C control function (H.27.1.2.3);
- d) modifies requirements for faults during safety shut-down.

The text of this standard is based on the following documents:

FDIS	Report on voting
72/981/FDIS	72/993/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part 2 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition (2013) of that publication. Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: Particular requirements for electrically operated door locks.

Where this part 2 states "addition", "modification", or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, this part 2 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practices are contained in the following subclauses:

17.1.3.1

17.7.1

17.7.7

17.10.4

27.2.3.1

In this publication:

- 1) The following print types are used:
 - Requirements proper: in roman type;
 - *Test specifications: in italic type;*
 - Notes; in small roman type;
 - Words defined in Clause 2: **bold**.
- 2) Subclauses, notes, tables and figures which are additional to those in part 1 are numbered starting from 101; additional annexes are lettered AA, BB, etc.

A list of all parts of the IEC 60730 series, published under the title *Automatic electrical controls* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 60730-2-12:2015](https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8ebca3182d/iec-60730-2-12-2015)

<https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8ebca3182d/iec-60730-2-12-2015>

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-12: Particular requirements for electrically operated door locks

1 Scope and normative references

This clause of Part 1 is applicable except as follows:

1.1 Scope

Replacement:

This part of IEC 60730 applies to **electrically operated door locks** for use in, on or in association with equipment, including equipment for heating, air-conditioning and similar applications. The equipment may use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this standard, the word "equipment" includes "appliance" and "control system".

This standard also applies to **electrically operated door locks** for equipment that may be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

This standard does not apply to **electrically operated door locks** intended exclusively for industrial process applications unless explicitly mentioned in the equipment standard.

This standard does not apply to **electrically operated door locks** intended for security access applications.

NOTE 2 Standards that cover these applications are under IEC Technical Committee 79.

1.1.1 *Replacement:*

This standard applies to the inherent safety, to the **operating values, operating sequences** where such are associated with equipment protection, and to the testing of door locks used in, or in association with equipment.

This standard is also applicable to door locks for appliances within the scope of IEC 60335-1.

NOTE Throughout this standard, the word "door" means "door, cover or lid". The words "door lock" mean "electrically operated door lock".

This standard is also applicable to individual door locks utilized as part of a **control system** or door locks which are mechanically integral with multi-functional **controls** having non-electrical outputs or employing motors.

Door locks for equipment not intended for normal household use, but which nevertheless may be used by the public, such as equipment intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

This standard is also applicable to the **functional safety of low complexity safety related systems** and **controls** employing door locks as the actuating element.

1.1.2 Replacement:

This standard applies to door locks with electrical circuits and **control** circuits which are, for example, operated by bimetals, magnet coils, memory metals, pressure elements, temperature-sensitive expansion elements or electronic elements.

1.1.3 Not applicable.

1.1.4 Replacement:

This standard applies to **manual controls** when such are electrically and/or mechanically integral with door locks.

NOTE Requirements for manual switches not forming part of a door lock are contained in IEC 61058-1.

1.1.5 Replacement:

This standard applies to a.c. or d.c. powered door locks with a rated voltage not exceeding 690 V a.c. or 600 V d.c.

1.1.6 Replacement:

This standard does not take into account the **response value** of an **automatic action** of a door lock, if such a **response value** is dependent upon the method of mounting the **control** in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer shall apply.

1.1.7 Replacement:

This standard applies also to door locks incorporating **electronic devices**, requirements for which are contained in Annex H and door locks using **thermistors**, requirements for which are contained in Annex J.

2 Terms and definitions

This clause of Part 1 is applicable except as follows:

2.2 Definitions of types of control according to purpose

Additional definition:

2.2.101

electrically operated door lock

incorporated or integrated **electrically operated mechanism** intended to control the door **locking** in equipment by means of a mechanical output mechanism which physically secures a door, **cover** or lid

2.3 Definitions relating to the function of controls

Additional definitions:

2.3.101

drop-out value

operating value at which the **locking** means is disengaged

2.3.102**locking**

mechanical action intended to block a door mechanism in such a way that opening of the door is prevented under defined conditions

2.3.103**locking delay**

period of time elapsing between the signal to lock and completion of the **locking** action

2.3.104**locking force**

minimum mechanical force intended for the door lock to prevent opening of the door

2.3.105**locking security**

condition in which the door lock either prevents an appliance door from being opened or prevents the appliance from being operated, even if the door lock is damaged

2.3.106**unlocking delay**

period of time elapsing between the signal to unlock and completion of the unlocking action

3 General requirements

This clause of Part 1 is applicable.

4 General notes on tests

[IEC 60730-2-12:2015](https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8b33182dfe/iec-60730-2-12-2015)

[https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-](https://standards.iteh.ai/catalog/standards/sist/9083064a-10b4-4fa3-8a25-0a8b33182dfe/iec-60730-2-12-2015)

This clause of Part 1 is applicable except as follows:

4.1 Conditions of test**4.1.1 Addition:**

NOTE 101 An actual door or a suitable device simulating the door may be used for the tests of this standard.

5 Rating

This clause of Part 1 is applicable.

6 Classification

This clause of Part 1 is applicable except as follows:

6.3 According to their purpose

Additional subclauses:

6.3.101 – door locks;

6.3.101.1 – voltage sensing;

NOTE The design may include a voltage-sensitive heating element, a magnet coil or an electronic element.

6.3.101.2 – current sensing;

NOTE The design may include a current-sensitive heating element, a magnet coil or an electronic element.

6.3.101.3 – thermally operated;

NOTE **Locking** may be controlled either directly or indirectly by a temperature-sensitive element.

6.3.101.4 – pressure operated.

NOTE Latching may either be directly or indirectly controlled by pressure-sensitive elements.

6.4 According to features of automatic action

Additional subclause:

6.4.101 – locking security (Type 1.AA or 2.AA).

7 Information

This clause of Part 1 is applicable except as follows:

7.2 Methods of providing information

Table 1 (7.2 of edition 3) – Required information and methods of providing information

Addition:

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Information		Clause or subclause	Method
101	Locking delay ¹⁰¹	2.3.103	X
102	Unlocking delay ¹⁰¹	2.3.106	X
103	Locking force (if declared) ¹⁰¹	2.3.104 18.101.1	X
104	Drop-out value	2.3.101	X
105	Effects on controlled outputs (if declared) ¹⁰²	6.4.101 18.101.2	X
106	Method of operation for the test of Clause 17	17	X

Addition to Note i:

For door locks, limits of **activating quantity** are specified either in the applicable appliance standard, by the appliance manufacturer or as declared by the door lock manufacturer (see 17.7 and 17.8).

Additional notes:

¹⁰¹ These are specified either in the applicable appliance standard, by the appliance manufacturer or by the door lock manufacturer.

¹⁰² This provides for manufacturer declaration of the outputs which will result after **failure** of the door lock.

8 Protection against electric shock

This clause of Part 1 is applicable.

9 Provision for protective earthing

This clause of Part 1 is applicable.