



SLOVENSKI STANDARD SIST EN 60255-151:2010

01-januar-2010

BUXca Yý U
SIST EN 60255-3:2001

A Yf]b]fY Yq]b`nUý]hbUcdfYa U!`%`%`XY. : i b_W]cbUbj`ghUbXUfX`nUdcX!`]b
bUXhc_cj bc`nUý]hc`f97`*`\$&`)!%`%&\$-\$-Ł

Measuring relays and protection equipment -- Part 151: Functional standard for over/under current protection

Messrelais und Schutzrichtungen - Teil 151: Funktionsanforderungen für Über-/Unterstromschutz

Relais de mesure et dispositifs de protection -- Partie 151: Norme fonctionnelle pour protection à maximum/minimum de courant

ITEH STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 60255-151:2009

ICS:

29.120.70 Releji Relays

SIST EN 60255-151:2010 en,fr

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 60255-151:2010](https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010)

<https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60255-151

October 2009

ICS 29.120.70

Supersedes EN 60255-3:1998 + corr. Jan.1998

English version

**Measuring relays and protection equipment -
Part 151: Functional requirements
for over/under current protection
(IEC 60255-151:2009)**

Relais de mesure
et dispositifs de protection -
Partie 151: Exigences fonctionnelles
pour les protections à maximum
et minimum de courant
(CEI 60255-151:2009)

Messrelais und Schutzeinrichtungen -
Teil 151: Funktionsanforderungen
für Über-/Unterstromschutz
(IEC 60255-151:2009)

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

This European Standard was approved by CENELEC on 2009-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 95/255/FDIS, future edition 1 of IEC 60255-151, prepared by IEC TC 95, Measuring relays and protection equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60255-151 on 2009-09-01.

This European Standard supersedes EN 60255-3:1998 + corrigendum January 1998.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2010-06-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2012-09-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60255-151:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60044	NOTE	Harmonized in EN 60044 series (partially modified).
IEC 60255-8	NOTE	Harmonized as EN 60255-8:1998 (modified).
IEC 61850	NOTE	Harmonized in EN 61850 series (not modified).
IEC 61850-7-4	NOTE	Harmonized as EN 61850-7-4:2003 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-447	200X ¹⁾	International Electrotechnical Vocabulary - Part 447: Measuring relays	-	-
IEC 60255-1	- ²⁾	Measuring relays and protection equipment - Part 1: Common requirements	EN 60255-1	200X ³⁾

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60255-151:2010](https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010)

<https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010>

¹⁾ To be published.

²⁾ Undated reference.

³⁾ To be ratified.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 60255-151:2010](#)

<https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010>



IEC 60255-151

Edition 1.0 2009-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Measuring relays and protection equipment –
Part 151: Functional requirements for over/under current protection**

**Relais de mesure et dispositifs de protection –
Partie 151: Exigences fonctionnelles pour les protections à minimum et
maximum de courant**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 29.120.70

ISBN 2-8318-1060-0

CONTENTS

FOREWORD.....	4
1 Scope and object.....	6
2 Normative references	6
3 Terms and definitions	6
4 Specification of the function.....	8
4.1 General.....	8
4.2 Input Energizing quantities / energizing quantities.....	8
4.3 Binary input signals.....	9
4.4 Functional logic.....	9
4.4.1 Operating characteristics.....	9
4.4.2 Reset characteristics	12
4.5 Binary output signals.....	16
4.5.1 Start (pick-up) signal	16
4.5.2 Operate (trip) signal.....	16
4.5.3 Other binary output signals.....	16
4.6 Additional influencing functions/conditions	16
4.7 Specific characteristics.....	16
5 Performance specification.....	17
5.1 Accuracy related to the characteristic quantity.....	17
5.2 Accuracy related to the operate time.....	18
5.3 Accuracy related to the reset time	18
5.4 Transient performance	19
5.4.1 Transient overreach.....	19
5.4.2 Overshoot time.....	19
5.4.3 Response to time varying value of the characteristic quantity	19
5.5 Current transformer requirements.....	19
6 Functional test methodology.....	20
6.1 General.....	20
6.2 Determination of steady state errors related to the characteristic quantity	20
6.2.1 Accuracy of setting (start) value	20
6.2.2 Reset ratio determination.....	22
6.3 Determination of steady state errors related to the start and operate time	23
6.4 Determination of steady state errors related to the reset time.....	23
6.5 Determination of transient performance.....	24
6.5.1 General	24
6.5.2 Transient overreach.....	24
6.5.3 Overshoot time	25
6.5.4 Response to time varying value of the characteristic quantity for dependent time relays	26
7 Documentation requirements	27
7.1 Type test report.....	27
7.2 Other user documentation	27
Annex A (normative) Constants for dependent time operating and reset characteristics	29
Annex B (informative) Reset time determination for relays with trip output only.....	30
Bibliography.....	31

Figure 1 – Simplified protection function block diagram.....	8
Figure 2 – Overcurrent independent time characteristic	10
Figure 3 – Undercurrent independent time characteristic	10
Figure 4 – Dependent time characteristic	11
Figure 5 – Definite time reset characteristic	13
Figure 6 – Definite time reset characteristic (alternative solution with instantaneous reset after relay operation).....	14
Figure 7 – Dependent time reset characteristic	15
Figure 8 – Dependent time reset characteristic (alternative solution with instantaneous reset after relay operation).....	16
Figure 9 – Voltage restrained characteristics	17
Figure 10 – Voltage controlled characteristics.....	17
Figure 11 – Typical test waveform for transient overreach	25
Figure 12 – Test waveform	26
Figure B.1 – Dependent reset time determination	30
Table 1 – Multiplier factor on operated time assigned error.....	18
Table 2 – Multiplier factor on reset time assigned error.....	19
Table 3 – Test points for overcurrent elements	23
Table 4 – Test points for undercurrent elements	23
Table 5 – Test points for overcurrent elements	24
Table 6 – Test points for undercurrent elements	24
Table 7 – Recommended values for the test	26
Table A.1 – Constants for dependent time operating and reset characteristics.....	29

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MEASURING RELAYS AND PROTECTION EQUIPMENT –

Part 151: Functional requirements for over/under current protection

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60255-151 has been prepared by IEC technical committee 95: Measuring relays and protection equipment.

This first edition cancels and replaces IEC 60255-3, published in 1989.

The text of this standard is based on the following documents:

FDIS	Report on voting
95/255/FDIS	95/258/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60255 series, published under the general title *Measuring relays and protection equipment*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60255-151:2010](#)

<https://standards.iteh.ai/catalog/standards/sist/17e99c5d-ef28-4551-b313-dd8361850aef/sist-en-60255-151-2010>

MEASURING RELAYS AND PROTECTION EQUIPMENT –

Part 151: Functional requirements for over/under current protection

1 Scope and object

This part of IEC 60255 specifies minimum requirements for over/under current relays. This standard includes a specification of the protection function, measurement characteristics and time delay characteristics.

This part of IEC 60255 defines the influencing factors that affect the accuracy under steady state conditions and performance characteristics during dynamic conditions. The test methodologies for verifying performance characteristics and accuracy are also included in this standard.

The over/under current functions covered by this standard are the following:

	IEEE/ANSI C37.2 Function Numbers	IEC 61850-7-4 Logical nodes
Instantaneous phase overcurrent protection	50	PIOC
Time delayed phase overcurrent protection	51	PTOC
Instantaneous earth fault protection	50N/50G	PIOC
Time delayed earth fault protection	51N/51G	PTOC
Negative sequence overcurrent or current unbalance protection	46	PTOC
Phase undercurrent protection	37	PTUC
Voltage-dependent overcurrent protection	51V	PVOC

This standard excludes thermal electrical relays as specified in IEC 60255-8. General requirements for measuring relays and protection equipment are specified in IEC 60255-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-447, *International Electrotechnical Vocabulary – Part 447: Measuring relays*

IEC 60255-1, *Measuring relays and protection equipment – Part 1: Common requirements*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

theoretical curve of time versus characteristic quantity

curve which represents the relationship between the theoretical specified operate time and the characteristic quantity