



Designation: C 965 – 96 (Reapproved 2002)

## Standard Practice for Measuring Viscosity of Glass Above the Softening Point<sup>1</sup>

This standard is issued under the fixed designation C 965; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This practice covers the determination of the viscosity of glass above the softening point through the use of a platinum alloy spindle immersed in a crucible of molten glass. Spindle torque, developed by differential angular velocity between crucible and spindle, is measured and used to calculate viscosity. Generally, data are taken as a function of temperature to describe the viscosity curve for the glass, usually in the range from 1 to  $10^6$  Pa·s.

1.2 Two procedures with comparable precision and accuracy are described and differ in the manner for developing spindle torque. Procedure A employs a stationary crucible and a rotated spindle. Procedure B uses a rotating crucible in combination with a fixed spindle.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

#### 2.1 ASTM Standards:

C 162 Terminology of Glass and Glass Products<sup>2</sup>

E 220 Method for Calibration of Thermocouples by Comparison Techniques<sup>3</sup>

### 3. Significance and Use

3.1 This practice is useful in determining the viscosity-temperature relationships for glasses and corresponding useful working ranges.

### 4. Apparatus

4.1 The apparatus shall consist of an electrically heated furnace equipped with a temperature controller, temperature

measuring equipment, a platinum alloy spindle,<sup>4</sup> a crucible,<sup>4</sup> a device to rotate spindle or crucible, and equipment to measure torque.

4.1.1 Procedure A employs an electrically heated tube-type furnace with a fixed support for the crucible as shown in Fig. 1. A platinum alloy resistance-heated crucible also may be used.

4.1.2 Procedure B employs a similar furnace but with a removable, rotatable crucible support as shown in Fig. 2.

4.1.3 Furnaces other than resistance-wound muffle types may be used provided they give uniform and stable temperature conditions. Temperature differences greater than 3°C within the crucible (in glass) are excessive for high precision measurements.

4.1.4 A temperature controller shall be provided for maintaining the glass temperature within  $\pm 2^\circ\text{C}$  of a specified temperature.

4.1.5 Temperatures shall be measured with Type R or S thermocouples calibrated in accordance with Method E 220 in conjunction with a calibrated potentiometer or solid state instrumentation capable of 0.5°C accuracy. An immersion thermocouple is recommended but a thermocouple in air may be used provided measurements show equivalency.

4.1.6 A crucible to contain the glass similar to those shown in Fig. 3 preferably shall be fabricated from a platinum alloy, but a refractory material may be used provided it does not contaminate the glass.

4.1.7 A platinum alloy spindle with the geometry shown in Fig. 4 is recommended. An alternative design has a hollow shaft to house the thermocouple (junction at the center of the large diameter portion) which has the advantage of proximity, but the disadvantage of possible electrical disconnection during torque measurement.


<sup>1</sup> This practice is under the jurisdiction of ASTM Committee C14 on Glass and Glass Products and is the direct responsibility of Subcommittee C14.04 on Physical and Mechanical Properties.

Current edition approved Oct. 10, 1996. Published December 1996. Originally published as C 965 – 81. Last previous edition C 965 – 81 (1996)  $\epsilon^2$ .

<sup>2</sup> Annual Book of ASTM Standards, Vol 15.02.


<sup>3</sup> Annual Book of ASTM Standards, Vol 14.03.

<sup>4</sup> Spindles and crucibles manufactured from 90% Pt–10% Rh or 80% Pt–20% Rh alloys have been found satisfactory for this purpose.



- 1—Furnace Winding
- 2—Crucible
- 3—Spindle
- 4—Shaft
- 5—Viscometer (providing both rotation and torque measurement)
- 6—Thermocouple

**FIG. 1 General Arrangement for Rotating Spindle, Fixed Crucible Scheme (Procedure A)**



NOTE 1—Details are the same as in Fig. 1 except that the viscometer is replaced by a torque measuring device, and the crucible is mounted on a removable rotatable stand.

**FIG. 2 General Apparatus Arrangement for Rotating Crucible Scheme (Procedure B)**

4.1.8 A measurement system<sup>5</sup> is necessary for measurement of spindle torque to an accuracy of 1 %.

## 5. Preparation of Test Glass

5.1 Select a mass of glass that is free of foreign material. Break or cut glass into pieces, each weighing about 10 to 50 g, and place the correct quantity into the crucible that will make the molten charge reach a level at some fixed distance (several millimetres) above the point where the spindle narrows down. The weight of glass required can be approximated satisfactorily with the following expression for a cylindrical crucible:

$$W_T = [\pi d^2(L + h)/4 - V_s]\rho (1 - 0.0007\alpha) \quad (1)$$

where:

- $h$  = distance between crucible floor and spindle tip, mm (generally greater than 10 mm to avoid end effects)
- $W_T$  = glass charge weight at room temperature, g,
- $d$  = inside diameter of crucible, mm,
- $L$  = immersed portion of spindle, mm,
- $V_s$  = volume of immersed portion of spindle, mm<sup>3</sup>,
- $\rho$  = density of glass at room temperature, g/cm<sup>3</sup>, and
- $\alpha$  = 0 to 300°C thermal expansion coefficient, cm/cm·°C ( $\times 10^7$ ).

<sup>5</sup> Equipment such as the Brookfield RVT or HBT manufactured by Brookfield Engineering Laboratories, Inc., 240 Cushing St., Stoughton, MA 02072, or equivalent has been found satisfactory for this purpose.

Avoid very small pieces of glass in the charge as they tend to make the molten glass seedy.

5.2 Place the filled crucible in proper position in the furnace and heat to a temperature that lowers the viscosity of glass sufficiently to allow trapped air bubbles to be released. This temperature should be below the original melting temperature to avoid reboil. If reboil occurs, allow additional time for the glass to clear. Hold at this temperature at least 20 min before starting measurements.

## 6. Calibration and Viscosity Determination

6.1 The use of several standard reference glasses (see Appendix X1),<sup>6</sup> available from the National Institute of Standards and Technology, is recommended. These provide a wide range of temperatures and viscosities for calibration.

6.2 For constant angular velocity rotation:

$$\eta \propto \Omega/\omega \quad (2)$$

<sup>6</sup> See NIST Special Publication 260, NIST Standard Reference Materials, National Institute of Standards and Technology, Gaithersburg, MD.