

# INTERNATIONAL STANDARD



**Concentrator photovoltaic (CPV) modules and assemblies – Design qualification and type approval**

(<https://standards.iteh.ai>)  
Document Preview

IEC 62108:2016

<https://standards.iteh.ai/document/standards/iec/2110963-1c11-41d8-940e-c25ef646c058/iec-62108-2016>

WITHDRAWN



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2016 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

**IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)**

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

**IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

**IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)**

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

**IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

IEC 6108:2016

<https://standards.iteh.ai/en/standards/iec/2110963-1c11-41d8-940c-c25ef646c058/iec-62108-2016>

# INTERNATIONAL STANDARD



**Concentrator photovoltaic (CPV) modules and assemblies – Design qualification and type approval**

<https://standards.iteh.ai>  
Document Preview

IEC 62108:2016

<https://standards.iteh.ai/document/standards/iec/2110963-1c11-41d8-940e-c25ef646c058/iec-62108-2016>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 27.160

ISBN 978-2-8322-3668-0

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	5
1 Scope and object.....	7
2 Normative references.....	7
3 Terms and definitions .....	8
4 Sampling .....	9
5 Marking .....	10
6 Testing .....	10
7 Pass criteria .....	11
8 Report.....	19
9 Modifications .....	20
10 Test procedures .....	20
10.1 Visual inspection.....	20
10.1.1 General .....	20
10.1.2 Procedure.....	20
10.1.3 Major visual defects .....	21
10.1.4 Requirements .....	21
10.2 Electrical performance measurement.....	21
10.2.1 Purpose.....	21
10.2.2 Outdoor side-by-side I-V measurement.....	21
10.2.3 Solar simulator I-V measurement.....	23
10.2.4 Dark I-V measurement .....	23
10.3 Ground path continuity test.....	24
10.3.1 General.....	24
10.3.2 Purpose.....	24
10.3.3 Procedure.....	24
10.3.4 Requirements .....	24
10.4 Electrical insulation test .....	25
10.4.1 Purpose.....	25
10.4.2 Procedure.....	25
10.4.3 Requirements .....	25
10.5 Wet insulation test.....	26
10.5.1 Purpose.....	26
10.5.2 Procedure.....	26
10.5.3 Requirements .....	26
10.6 Thermal cycling test .....	27
10.6.1 Purpose.....	27
10.6.2 Test sample .....	27
10.6.3 Procedure.....	27
10.6.4 Requirements .....	29
10.7 Damp heat test.....	29
10.7.1 Purpose.....	29
10.7.2 Test sample .....	29
10.7.3 Procedure.....	30
10.7.4 Requirements .....	30
10.8 Humidity freeze test .....	30

10.8.1	Purpose .....	30
10.8.2	Test sample .....	30
10.8.3	Procedure .....	31
10.8.4	Requirements .....	31
10.9	Hail impact test .....	32
10.9.1	Purpose .....	32
10.9.2	Apparatus .....	32
10.9.3	Procedure .....	33
10.9.4	Requirements .....	33
10.10	Water spray test.....	33
10.10.1	General .....	33
10.10.2	Purpose .....	33
10.10.3	Procedure .....	34
10.10.4	Requirements .....	34
10.11	Bypass/blocking diode thermal test.....	34
10.11.1	Purpose .....	34
10.11.2	Test sample .....	35
10.11.3	Apparatus .....	35
10.11.4	Procedure .....	35
10.11.5	Requirements .....	36
10.11.6	Procedure 2 – Alternate method.....	36
10.12	Robustness of terminations test.....	37
10.12.1	Purpose .....	37
10.12.2	Types of terminations.....	37
10.12.3	Procedure .....	38
10.12.4	Requirements .....	38
10.13	Mechanical load test.....	39
10.13.1	Purpose .....	39
10.13.2	Procedure.....	40
10.13.3	Requirements .....	40
10.14	Off-axis beam damage test.....	40
10.14.1	General .....	40
10.14.2	Purpose .....	40
10.14.3	Special case .....	40
10.14.4	Procedure .....	40
10.14.5	Requirements .....	41
<del>10.15</del>	<del>Ultraviolet conditioning test .....</del>	<del>41</del>
<del>10.15.1</del>	<del>Purpose .....</del>	<del>41</del>
<del>10.15.2</del>	<del>Procedure .....</del>	<del>41</del>
10.15	Outdoor exposure test.....	41
10.15.1	Purpose .....	41
10.15.2	Procedure .....	42
10.15.3	Requirements .....	42
10.16	Hot-spot endurance test .....	42
10.17	Dust ingress protection test .....	42
10.17.1	Purpose .....	42
10.17.2	Procedure .....	43
10.17.3	Requirements .....	43
Annex A (informative) Summary of test conditions and requirements.....		44

Annex B (normative) Retesting guideline .....	47
B.1 Product or process modifications requiring limited retesting to maintain certification .....	47
B.2 Modifications of CPV cell technology .....	47
B.3 Modifications in optical encapsulation on the cell (Includes optical coupling between the cell and a glass secondary optical element bonded to the cell) .....	48
B.4 Modification in cell encapsulation outside of intended light path .....	48
B.5 Modification of cell package substrate used for heat transfer .....	48
B.6 Accessible optics (primary or secondary) .....	49
B.7 Inaccessible optics (secondary) .....	49
B.8 Frame and/or mounting structure .....	49
B.9 Enclosure .....	50
B.10 Wiring compartment/junction box .....	50
B.11 Interconnection terminals .....	50
B.12 Interconnection materials or technique (to cells and between receivers) .....	51
B.13 Change in electrical circuit design in an identical package .....	51
B.14 Output power .....	51
B.15 Thermal energy transfer means .....	52
B.16 Adhesives .....	52
<b>Bibliography</b> .....	
Figure 1 – Schematic of point-focus dish PV concentrator .....	13
Figure 2 – Schematic of linear-focus trough PV concentrator .....	14
Figure 3 – Schematic of point-focus fresnel lens PV concentrator .....	15
Figure 4 – Schematic of linear-focus fresnel lens PV concentrator .....	16
Figure 5 – Schematic of a heliostat CPV .....	17
Figure 6 – Qualification test sequence for CPV modules .....	18
Figure 7 – Qualification test sequence for CPV assemblies .....	19
Figure 8 – Temperature and current profile of thermal cycle test (not to scale) .....	29
Figure 9 – Profile of humidity-freeze test conditions .....	32
Figure 10 – Bypass diode thermal test .....	37
Table 1 – Terms used for CPVs .....	9
Table 2 – Allocation of test samples to typical test sequences .....	11
Table 3 – Thermal cycle test options for sequence A .....	29
<del>Table 4 – Pre thermal cycle test options for sequence B .....</del>	<del>.....</del>
Table 4 – Humidity freeze test options for sequence B .....	31
Table 5 – Minimum wind loads .....	39
Table A.1 – Summary of test conditions and requirements .....	44

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**CONCENTRATOR PHOTOVOLTAIC (CPV) MODULES AND ASSEMBLIES –  
DESIGN QUALIFICATION AND TYPE APPROVAL**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.**

International Standard IEC 62108 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

This second edition cancels and replaces the first edition, issued in 2007. It constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

- a) Changes in outdoor exposure from 1000 h to 500 h.
- b) Changes in current cycling during thermal cycling test.
- c) Added dust ingress test.
- d) Eliminated thermal cycling associated with damp heat test.
- e) Eliminated UV exposure test.

The text of this standard is based on the following documents:

FDIS	Report on voting
82/1142/FDIS	82/1161/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.**



# CONCENTRATOR PHOTOVOLTAIC (CPV) MODULES AND ASSEMBLIES – DESIGN QUALIFICATION AND TYPE APPROVAL

## 1 Scope and object

This International Standard specifies the minimum requirements for the design qualification and type approval of concentrator photovoltaic (CPV) modules and assemblies suitable for long-term operation in general open-air climates as defined in IEC 60721-2-1. The test sequence is partially based on that specified in IEC 61215-1 for the design qualification and type approval of flat-plate terrestrial crystalline silicon PV modules. However, some changes have been made to account for the special features of CPV receivers and modules, particularly with regard to the separation of on-site and in-lab tests, effects of tracking alignment, high current density, and rapid temperature changes, which have resulted in the formulation of some new test procedures or new requirements.

The object of this test standard is to determine the electrical, mechanical, and thermal characteristics of the CPV modules and assemblies and to show, as far as possible within reasonable constraints of cost and time, that the CPV modules and assemblies are capable of withstanding prolonged exposure in climates described in the scope. The actual life of CPV modules and assemblies so qualified will depend on their design, production, environment, and the conditions under which they are operated.

This standard shall be used in conjunction with the retest guidelines described in Annex B.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-21:2006, *Environmental testing – Part 2-21: Tests – Test U: Robustness of terminations and integral mounting devices*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

~~IEC 61215:2005, Crystalline silicon Terrestrial photovoltaic (PV) modules – Design qualification and type approval~~

IEC 61215-2:2016, *Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures*

IEC 62670-1, *Photovoltaic concentrators (CPV) – Performance testing – Part 1: Standard conditions*

~~ISO/IEC 17025:2005, General requirements for the competence of testing and calibration laboratories~~

ANSI/UL 1703:2002 ~~ed.3 March 15~~, *Standard for Safety: Flat-Plate Photovoltaic Modules and Panels*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply. See also Table 1.

#### 3.1

##### **concentrator**

term associated with photovoltaic devices that use concentrated sunlight

#### 3.2

##### **concentrator cell**

basic photovoltaic device that is used under the illumination of concentrated sunlight

#### 3.3

##### **concentrator optics**

optical device that performs one or more of the following functions from its input to output: increasing the light intensity, filtering the spectrum, modifying light intensity distribution, or changing light direction. Typically, it is a lens or a mirror

**Note 1 to entry:** A primary optics receives unconcentrated sunlight directly from the sun. A secondary optics receives concentrated or modified sunlight from another optical device, such as primary optics or another secondary optics.

#### 3.4

##### **concentrator receiver**

group of one or more concentrator cells and secondary optics (if present) that accepts concentrated sunlight and incorporates the means for thermal and electric energy transfer. A receiver could be made of several sub-receivers. The sub-receiver is a physically stand-alone, smaller portion of the full-size receiver

#### 3.5

##### **concentrator module**

group of receivers, optics, and other related components, such as interconnection and mounting, that accepts unconcentrated sunlight. All above components are usually prefabricated as one unit, and the focus point is not field adjustable

**Note 1 to entry:** A module could be made of several sub-modules. The sub-module is a physically stand-alone, smaller portion of the full-size module.

#### 3.6

##### **concentrator assembly**

group of receivers, optics, and other related components, such as interconnection and mounting, that accepts unconcentrated sunlight. All above components would usually be shipped separately and need some field installation, and the focus point is field adjustable

**Note 1 to entry:** An assembly could be made of several sub-assemblies. The sub-assembly is a physically stand-alone, smaller portion of the full-size assembly.


#### 3.7

~~representative samples for CPV~~  
see details in Clause 4

#### 3.7

##### **control unit**

hardware that is not stressed, but is included in each measurement to enable greater confidence in consistent measurements

**Table 1 – Terms used for CPV**

#### 4 Sampling

Figures 1 to 5 are schematics of cells, receivers, modules, and assemblies.

For non-field-adjustable focus-point CPV systems or modules, 7 modules and 2 receivers are required to complete all the specified tests, plus one receiver for the bypass/blocking diode thermal test (intrusive or non-intrusive). For details, see Figure 6. For field-adjustable focus-point CPV systems or assemblies, 9 receivers (including secondary optics sections, if applicable) and 7 primary optics sections are required to complete all the specified tests, plus one receiver for the bypass/blocking diode thermal test (intrusive or non-intrusive). For details, see Figure 7.

In the case that a full-size module or assembly is too large to fit into available testing equipment, such as environmental chambers, or a full-size module or assembly is too expensive (e.g., for a 20 kW reflective dish concentrator system, 9 receiver samples account for 180 kW of PV cells), a smaller representative sample ~~may~~ **can** be used. However, even if representative samples are used for the other test, a full-size module or assembly ~~should~~ **shall** be installed and tested for outdoor exposure. This can be conducted either in the testing lab, or through on-site witness.

Representative samples ~~should~~ **shall** include all components, except some repeated parts. If possible, the representative samples ~~should~~ **shall** use sub-receivers, sub-modules, or sub-assemblies. During the design and manufacturing of the representative samples, much attention ~~should~~ **shall** be paid to reach the maximum similarity to the full-size component in all electrical, mechanical, and thermal characteristics related to quality and reliability.

Specifically, the cell string in representative samples ~~should~~ **shall** be long enough to include at least two bypass diodes, but in no case less than ten cells. The encapsulations, interconnects, terminations, and the clearance distances around all edges ~~should~~ **shall** be the same as on the actual full-size products. Other representative components, including lens/housing joints, receiver/housing joints, and end plate/lens ~~should~~ **shall** also be included and tested.

Test samples should be taken at random from a production batch or batches. When the samples to be tested are prototypes of a new design and not from production, or representative samples are used, these facts should be noted in the test report (see Clause 8).

The test samples ~~should~~ shall have been manufactured from specified materials and components in accordance with the relevant drawings and process instructions and should have been subjected to the manufacturer's normal inspection, quality control, and production acceptance procedures. They ~~should~~ shall be complete in every detail and should be accompanied by the manufacturer's handling, mounting, connection, and operation manuals. Samples ~~should~~ shall not be subjected to other special procedures that are not a part of standard production.

If the intrusive bypass/blocking diode thermal test is to be performed, an additional specially manufactured receiver is required with extra electrical and thermal detector leads so that each individual diode can be accessed separately.

## 5 Marking

Each receiver or module section ~~should~~ shall carry the following clear and indelible markings:

- Name, monogram, or symbol of manufacturer.
- Type or model number.
- Serial number.
- Polarity of terminals or leads (color coding is permissible).
- Maximum system voltage for which the module or assembly is suitable.
- Nominal maximum output power and its tolerance at specified condition.
- The date, place of manufacture, and cell materials ~~should~~ shall be marked, or be traceable from the serial number.

If representative samples are used, the same markings as on full-size products ~~should~~ shall be included for all tests, and the marking should be capable of surviving all test sequences.

## 6 Testing

If recommended by the manufacturer, before beginning the testing, all testing samples, including the control module and control receiver, ~~should~~ shall be exposed to the direct normal irradiation (DNI) of sunlight (either natural or simulated) for a total of 5 kWh/m<sup>2</sup> to 5,5 kWh/m<sup>2</sup> while open circuited. This procedure is designed to reduce the initial photon degradation effects.

In this standard all references to short-circuit current  $I_{sc}$ , open-circuit voltage  $V_{oc}$ , maximum output power  $P_m$ , ~~and other measures are all based on DNI 900 W/m<sup>2</sup>, cell temperature 25 °C, spectrum at Air Mass 1,5D (under consideration), and wind speed 3 m/s Concentrator Standard Test Condition (CSTC), which is defined in IEC 62670-1. A formal Concentrator Standard Test Condition (CSTC) definition will be given in a future IEC CPV standard, which is under consideration.~~ Alternatively, Concentrator Standard Operating Conditions (CSOC), as defined in IEC 62670-1, may be used consistently.

The test samples ~~should~~ shall be randomly divided into groups and subjected to the qualification test sequences in Figure 6 or Figure 7. Test procedures and requirements are detailed in Clause 10, and summarized in Annex A. The allocation of test samples to typical test sequences is given in Table 2.

After initial tests and inspections, one module or one receiver/mirror section ~~should~~ shall be removed from the test sequence as a control unit. Preferably, the control unit should be

stored in the dark at room temperature to reduce the electrical performance degradation, but it may be kept outdoors with a dark cover. As shown in Figure 6 for modules or in Figure 7 for assemblies, the test sequence is performed both in-lab and on-site. **If the CPV receiver uses crystalline silicon, a 1-sun measurement (flash or outdoor) can be used as a diagnostic tool throughout the program.** If the distance between these two locations is considerable or public shipping companies are involved, a dark current-voltage (I-V) curve measurement before and after the shipping should be performed to evaluate any possible changes on testing samples.

If a particular manufacturer produces only specific components, such as receivers, lenses, or mirrors, the design qualification and type approval testing ~~may~~ **can** be conducted only on applicable test sequences, and a partial certification can be issued independently.

If some test procedures in this standard are not applicable to a specific design configuration, the manufacturer should discuss this with the certifying body and testing agency to develop a comparable test program, based on the principles described in this standard. Any changes and deviations shall be recorded and reported in details, as required in Clause 8 j).

**Table 2 – Allocation of test samples to typical test sequences**

Test sequence	Module		Assembly	
	receiver	module	receiver	mirror
Control		1	1	1
A	2		2	
B		2	2	2
C		2	2	2
D		1	1	1
E		1 (full-size)	1 (full-size)	1 (full-size)
F	1		1	
Total	3	7	10	7

## 7 Pass criteria

A concentrator photovoltaic module or assembly design ~~should~~ **shall** be judged to have passed the qualification tests, and therefore to be IEC 62108 type approved, if each test sample meets all the following criteria:

- The relative power degradation in sequence A to D does not exceed 13 % if the I-V measurement is under outdoor natural sunlight, or 8 % if the I-V measurement is under solar simulator.
- The relative power degradation in sequence E does not exceed 7 % for natural sunlight I-V measurement, or 5 % for solar simulator I-V measurement, because the 1 000 kWh/m<sup>2</sup> DNI outdoor exposure ~~and 50 kWh/m<sup>2</sup> ultraviolet (UV) tests are~~ **is** not an accelerated stress test.
- No sample has exhibited any open circuit during the tests.
- There is no visual evidence of a major defect, as defined in 10.1.2.
- The insulation test requirements are met at the beginning and the end of each sequence.
- The wet leakage current test requirements are met at the beginning and the end of each sequence.
- Specific requirements of the individual tests are met.

If there are some failures observed during the test, the following judgment and re-test procedure ~~should~~ **shall** apply:

- h) If two or more test samples do not meet pass criteria, the design shall be deemed not to have met the qualification requirements.
- i) Should one sample fail any test, another two samples meeting the requirements of Clause 4 could be subjected to the whole of the relevant test sequence from the beginning.
- | j) In case i), if both samples pass the test sequence, the design ~~should~~ shall be judged to have met the qualification requirements.
- k) In case i), if one or both of these samples also fail, the design shall be deemed not to have met the qualification requirements.
- | l) In case h) or k), the entire test program illustrated in Figure 6 or Figure 7 ~~should~~ shall be re-performed, usually after some design or processing improvement.

Witholdam

iTech Standards  
(<https://standards.itih.ai>)  
Document Preview

IEC 62108:2016  
<https://standards.itih.ai/standards/iec/2110963-1c11-41d8-940e-c25ef646c058/iec-62108-2016>