

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-12: Application layer service definition – Type 12 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-12: Définition des services de la couche application – Éléments
de type 12**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-12: Application layer service definition – Type 12 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-12: Définition des services de la couche application – Éléments
de type 12**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XF

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-1737-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope	8
1.1 General.....	8
1.2 Specifications.....	9
1.3 Conformance.....	9
2 Normative references	9
3 Terms, definitions, symbols, abbreviations and conventions	10
3.1 Reference model terms and definitions.....	10
3.2 Service convention terms and definitions.....	11
3.3 Application layer and data-link service terms and definitions.....	11
3.4 Common symbols and abbreviations	15
3.5 Conventions	16
4 Concepts.....	17
4.1 Common concepts.....	17
4.2 Type specific concepts	17
5 Data type ASE.....	26
5.1 General.....	26
5.2 Formal definition of data type objects.....	26
5.3 FAL defined data types.....	26
5.4 Data type ASE service specification.....	35
6 Communication model specification	35
6.1 ASEs.....	35
6.2 AR	116
Bibliography	129
Figure 1 – Producer consumer model.....	19
Figure 2 – Client server model	19
Figure 3 – Server triggered invocation.....	19
Figure 4 – Slave reference model.....	21
Figure 5 – Simple slave device.....	22
Figure 6 – Complex slave device.....	23
Figure 7 – Master functional overview	24
Figure 8 – Process output data sequence.....	36
Figure 9 – Process input data sequence.....	37
Figure 10 – CoE server model.....	55
Figure 11 – Successful single SDO-Download sequence.....	60
Figure 12 – Unsuccessful single SDO-Download sequence.....	61
Figure 13 – Successful segmented SDO-Download sequence.....	62
Figure 14 – Successful single SDO-Upload sequence.....	63
Figure 15 – Unsuccessful single SDO-Upload sequence.....	64
Figure 16 – Successful segmented SDO-Upload sequence	65


Figure 17 – SDO information sequence	66
Figure 18 – Emergency service	67
Figure 19 – Command sequence	68
Figure 20 – PDO mapping	70
Figure 21 – Sync manager PDO assignment	71
Figure 22 – RxPDO service	73
Figure 23 – TxPDO service	74
Figure 24 – RxPDO remote transmission sequence	75
Figure 25 – TxPDO remote transmission sequence	76
Figure 26 – EoE sequence	96
Figure 27 – FoE read sequence with success	104
Figure 28 – FoE read sequence with error	105
Figure 29 – FoE write sequence with success	106
Figure 30 – FoE write sequence with error	107
Figure 31 – FoE write sequence with busy	108
Figure 32 – Successful AL control sequence	118
Figure 33 – Unsuccessful AL control sequence	119
Figure 34 – AL state changed sequence	120
Table 1 – Process output data	39
Table 2 – Process input data	40
Table 3 – Update process input data	41
Table 4 – SII read	49
Table 5 – SII write	50
Table 6 – SII reload	51
Table 7 – Allocation of SDO areas	55
Table 8 – SDO download expedited	80
Table 9 – SDO download normal	81
Table 10 – Download SDO segment	82
Table 11 – SDO upload expedited	83
Table 12 – SDO upload normal	84
Table 13 – Upload SDO segment	85
Table 14 – Abort SDO transfer	85
Table 15 – Get OD list	86
Table 16 – OD list segment	87
Table 17 – Get object description	88
Table 18 – Get entry description	89
Table 19 – Object entry segment	91
Table 20 – Emergency	92
Table 21 – RxPDO	93
Table 22 – TxPDO	93
Table 23 – RxPDO remote transmission	94
Table 24 – TxPDO remote transmission	94

Table 25 – Initiate EoE.....	99
Table 26 – EoE fragment	100
Table 27 – Set IP parameter	101
Table 28 – Set address filter	102
Table 29 – FoE read	109
Table 30 – FoE write.....	110
Table 31 – FoE data	110
Table 32 – FoE ack.....	111
Table 33 – FoE busy.....	111
Table 34 – FoE error.....	112
Table 35 – MBX read	113
Table 36 – MBX write.....	114
Table 37 – MBX read upd	115
Table 38 – AL management and ESM service primitives	117
Table 39 – AL control.....	127
Table 40 – AL state change	128

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 61158-5-12:2014

<https://standards.iteh.ai/catalog/standards/sist/7984564-9291-4475-8b88-902c09bf5035/iec-61158-5-12-2014>



INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 5-12: Application layer service definition –
Type 12 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-5-12 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision. The main changes with respect to the previous edition are listed below:

- bug fixes;
- editorial improvements;
- support of Explicit Device Identification added in ESM (see 6.2.2)

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/763/FDIS	65C/773/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IEC 61158-5-12:2014
<https://standards.iteh.ai/catalog/standards/sist/7984564-9291-4475-8b88-902c09bf5035/iec-61158-5-12-2014>

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 61158-5-12:2014

<https://standards.iteh.ai/catalog/standards/sist/7984564-9291-4475-8b88-902c09bf5035/iec-61158-5-12-2014>

Withstand

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-12: Application layer service definition – Type 12 elements

1 Scope

1.1 General

The fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 12 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the different Types of the fieldbus Application Layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- a) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model, and
- b) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This standard specifies the structure and services of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal Application Programming Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill any given Type of application layer services as defined in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-1:2014, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-3-12, *Industrial communication networks – Fieldbus specifications – Part 3-12: Data-link layer service definition – Type 12 elements*

ISO/IEC 646:1991, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

IEEE 802.1D, *IEEE standard for local and metropolitan area networks – Media access control (MAC) Bridges*; available at <<http://www.ieee.org>>

IETF RFC 791, *Internet Protocol darpa internet program protocol specification*; available at <<http://www.ietf.org>>

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply

3.1 Reference model terms and definitions

This standard is based in part on the concepts developed in ISO/IEC 7498-1 and ISO/IEC 7498-3, and makes use of the following terms defined therein:

3.1.1 correspondent (N)-entities	[ISO/IEC 7498-1]
correspondent AL-entities (N=7)	
3.1.2 (N)-entity	[ISO/IEC 7498-1]
AL-entity (N=7)	
3.1.3 (N)-layer	[ISO/IEC 7498-1]
AL-layer (N=7)	
3.1.4 layer-management	[ISO/IEC 7498-1]
3.1.5 peer-entities	[ISO/IEC 7498-1]
3.1.6 primitive name	[ISO/IEC 7498-3]
3.1.7 AL-protocol	[ISO/IEC 7498-1]
3.1.8 AL-protocol-data-unit	[ISO/IEC 7498-1]
3.1.9 reset	[ISO/IEC 7498-1]
3.1.10 routing	[ISO/IEC 7498-1]
3.1.11 segmenting	[ISO/IEC 7498-1]

3.1.12 (N)-service AL-service (N=7)	[ISO/IEC 7498-1]
3.1.13 AL-service-data-unit	[ISO/IEC 7498-1]
3.1.14 AL-simplex-transmission	[ISO/IEC 7498-1]
3.1.15 AL-subsystem	[ISO/IEC 7498-1]
3.1.16 systems-management	[ISO/IEC 7498-1]
3.1.17 AL-user-data	[ISO/IEC 7498-1]

3.2 Service convention terms and definitions

This standard also makes use of the following terms defined in ISO/IEC 10731 as they apply to the data-link layer:

3.2.1 acceptor	
3.2.2 asymmetrical service	
3.2.3 confirm (primitive); requestor.deliver (primitive)	
3.2.4 deliver (primitive)	
3.2.5 AL-service-primitive; primitive	
3.2.6 AL-service-provider	
3.2.7 AL-service-user	
3.2.8 indication (primitive); acceptor.deliver (primitive)	
3.2.9 request (primitive); requestor.submit (primitive)	
3.2.10 requestor	
3.2.11 response (primitive); acceptor.submit (primitive)	
3.2.12 submit (primitive)	
3.2.13 symmetrical service	
3.3 Application layer and data-link service terms and definitions	

For the purposes of this document, the following terms and definitions apply.

3.3.1

application

function or data structure for which data is consumed or produced

3.3.2

application objects

multiple object classes that manage and provide a run time exchange of messages across the network and within the network device]

3.3.3

basic slave

slave device that supports only physical addressing of data

3.3.4

bit

unit of information consisting of a 1 or a 0

Note 1 to entry: This is the smallest data unit that can be transmitted.

3.3.5

client

1) object which uses the services of another (server) object to perform a task

2) initiator of a message to which a server reacts

3.3.6

communication object

component that manage and provide a run time exchange of messages across the network

3.3.7

connection

logical binding between two application objects within the same or different devices

3.3.8

cyclic

events which repeat in a regular and repetitive manner

3.3.9

data

generic term used to refer to any information carried over a fieldbus

3.3.10

data consistency

means for coherent transmission and access of the input- or output-data object between and within client and server

3.3.11

data type

relation between values and encoding for data of that type

Note 1 to entry: The data type definitions of IEC 61131-3 apply.

3.3.12

data type object

entry in the object dictionary indicating a data type

3.3.13

default gateway

device with at least two interfaces in two different IP subnets acting as router for a subnet.

3.3.14

device

physical entity connected to the fieldbus composed of at least one communication element (the network element) and which may have a control element and/or a final element (transducer, actuator, etc.)

3.3.15

device profile

collection of device dependent information and functionality providing consistency between similar devices of the same device

3.3.16**diagnosis information**

all data available at the server for maintenance purposes

3.3.17**distributed clocks**

method to synchronize slaves and maintain a global time base

3.3.18**error**

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

3.3.19**error class**

general grouping for related error definitions and corresponding error codes

3.3.20**error code**

identification of a specific type of error within an error class

3.3.21**event**

instance of a change of conditions

3.3.22**fieldbus memory management unit**

function that establishes one or several correspondences between logical addresses and physical memory

3.3.23**fieldbus memory management unit entity**

single element of the fieldbus memory management unit: one correspondence between a coherent logical address space and a coherent physical memory location

3.3.24**frame**

denigrated synonym for DLPDU

3.3.25**full slave**

slave device that supports both physical and logical addressing of data

3.3.26**index**

address of an object within an application process

3.3.27**interface**

shared boundary between two functional units, defined by functional characteristics, signal characteristics, or other characteristics as appropriate

3.3.28**little endian**

method for data representation of numbers greater 8 bit where the least significant octet is transmitted first