
Delo pod napetostjo - Izolacijske palice in priklopne naprave - 2. del: Priklopne naprave (IEC 60832-2:2010)

Live working - Insulating sticks and attachable devices - Part 2: Attachable devices (IEC 60832-2:2010)

Arbeiten unter Spannung - Isolierende Arbeitsstangen und auswechselbare Adapter/Arbeitsköpfe - Teil 2: Auswechselbare Adapter/Arbeitsköpfe (IEC 60832-2:2010)

Travaux sous tension - Perches isolantes et outils adaptables - Partie 2: Outils adaptables (CEI 60832-2:2010)

[SIST EN 60832-2:2010](https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010)

[https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-](https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010)

[db25b361d2b2/sist-en-60832-2-2010](https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010)

Ta slovenski standard je istoveten z: EN 60832-2:2010

ICS:

13.260	Varstvo pred električnim udarom. Delo pod napetostjo	Protection against electric shock. Live working
29.260.01	Električna oprema za delo v posebnih razmerah na splošno	Electrical equipment for working in special conditions in general

SIST EN 60832-2:2010

en,fr

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60832-2:2010

<https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60832-2

March 2010

ICS 13.260; 29.240.20.

Supersedes EN 60832:1996 (partially)

English version

**Live working -
Insulating sticks and attachable devices -
Part 2: Attachable devices
(IEC 60832-2:2010)**

Travaux sous tension -
Perches isolantes et outils adaptables -
Partie 2: Outils adaptables
(CEI 60832-2:2010)

Arbeiten unter Spannung -
Isolierende Stangen und auswechselbare
Adapter/Arbeitsköpfe -
Teil 2: Auswechselbare
Adapter/Arbeitsköpfe
(IEC 60832-2:2010)

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 78/839/FDIS, future edition 1 of IEC 60832-2, prepared by IEC TC 78, Live working, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60832-2 on 2010-03-01.

This EN 60832-2, together with EN 60832-1, supersedes EN 60832:1996. The two parts have been created to clearly separate the requirements and testing of insulating sticks from those of attachable universal devices.

Compared to EN 60832, the major changes included in EN 60832-2 are:

- updating of the list of devices;
- clarifying the applicability of the document to other attachment system than splined end-fitting;
- application of conformity assessment for products having completed the production phase, according to IEC 61318:2007 (Edition 3), focusing on the classification of defects and the introduction of alternative testing in case of production follow-up.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2010-12-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2013-03-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60832-2:2010 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60060-1	-	High-voltage test techniques - Part 1: General definitions and test requirements	HD 588.1 S1	-
IEC 60212	1971	Standard conditions for use prior to and during the testing of solid electrical insulating materials	HD 437 S1	1984
IEC 60417	-	Graphical symbols for use on equipment	-	-
IEC 61318	2007	Live working - Conformity assessment applicable to tools, devices and equipment	EN 61318	2008
IEC 61477	-	Live working - Minimum requirements for the utilization of tools, devices and equipment	EN 61477	-

SIST EN 60832-2:2010

<https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60832-2:2010

<https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010>



IEC 60832-2

Edition 1.0 2010-02

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Live working – Insulating sticks and attachable devices –
Part 2: Attachable devices
(standards.iteh.ai)

Travaux sous tension – Perches isolantes et outils adaptables –
Partie 2: Outils adaptables
<https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX **XB**

ICS 13.260; 29.240.20; 29.260.99

ISBN 2-8318-1077-7

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references.....	8
3 Terms, definitions and symbols.....	8
3.1 Terms and definitions.....	8
3.2 Symbols.....	9
4 Requirements.....	9
4.1 General.....	9
4.2 Dimensional and mechanical requirements.....	9
4.2.1 Dimensional requirements.....	9
4.2.2 Mechanical requirements.....	10
4.3 Mechanical protection.....	12
4.4 Protection against corrosion.....	12
4.5 Marking.....	12
4.6 Instructions for use.....	12
5 Tests.....	13
5.1 General.....	13
5.2 Visual inspection.....	13
5.3 Dimensional check.....	13
5.4 Compatibility check.....	13
5.5 Durability of marking.....	13
5.6 Mechanical tests and specific tests.....	14
5.6.1 Universal adaptor and hook stick adaptor.....	14
5.6.2 Formed-wire ring – Tension of the spigot.....	15
5.6.3 Locating drift – Bending test.....	16
5.6.4 Conductor cleaning brush – Semi-tubular type.....	17
5.6.5 Conductor cleaning brush – V-shaped type – Fatigue test.....	19
5.6.6 Oilcan – Functioning of the operating lever.....	19
5.6.7 Ratchet spanner (ratchet wrench) – Friction.....	19
5.6.8 Spanner (wrench) – Torsion test.....	20
5.6.9 Retaining pin remover.....	20
5.6.10 Holding fork – Bending test.....	24
5.6.11 Retaining device installer/remover – Bending test.....	24
5.6.12 Binding wire cutter blade (tie wire cutter) – Bending test.....	25
5.6.13 Rotary blade – Tension test.....	27
5.6.14 Rotary prong – Tension test.....	27
5.6.15 Adjustable pliers.....	28
5.6.16 Vice-grip pliers.....	29
5.6.17 Adjustable insulator fork.....	31
5.6.18 All-angle pliers.....	33
5.6.19 Pin holder.....	34
5.6.20 Flexible spanner head (flexible wrench head) – Torsion test.....	36
5.6.21 Ammeter holder.....	36
5.6.22 Anti-interference braid applicator.....	39
5.6.23 Hack saw – Bending test.....	40

5.6.24	Mirror	41
5.6.25	Conductor gauge	42
5.6.26	Gap gauge.....	44
5.6.27	Clevis and tongue stick devices – Tension test.....	45
5.7	Instructions for use.....	46
5.7.1	Type test	46
5.7.2	Alternative test in case of attachable devices having completed the production phase.....	46
6	Conformity assessment of devices having completed the production phase.....	46
7	Modifications	46
Annex A (informative)	Attachment system of sticks – Examples	47
Annex B (normative)	Suitable for live working ; double triangle (IEC 60417–5216 (2002-10)).....	49
Annex C (normative)	Chronology of type tests	50
Annex D (normative)	Classification of defects and tests to be allocated	55
Annex E (informative)	In-service recommendations.....	60
Bibliography	61
Figure 1	– Test set-up for a hook stick adaptor – Torsion and tension of the adaptor	14
Figure 2	– Universal adaptor and hook stick adaptor – Torsion of the wing screw	15
Figure 3	– Formed-wire ring – Tension of the spigot	16
Figure 4	– Locating drift – Bending test.....	17
Figure 5	– Conductor cleaning brush – Fatigue test on semi-tubular type.....	17
Figure 6	– Conductor cleaning brush – Semi-tubular type – Crushing test.....	18
Figure 7	– Conductor cleaning brush – V-shaped type – Fatigue test.....	19
Figure 8	– Spanner (wrench) – Torsion test	20
Figure 9	– Spiral type retaining pin remover – Torsion test	21
Figure 10	– Fine-point type retaining pin remover – Torsion test.....	22
Figure 11	– Cam type (pry type) retaining pin remover – Bending test	23
Figure 12	– Holding fork – Bending test	24
Figure 13	– Retaining device installer/remover – Bending test	25
Figure 14	– Binding wire cutter blade (tie wire cutter) – Bending test	26
Figure 15	– Rotary blade – Tension test	27
Figure 16	– Rotary prong – Tension test	28
Figure 17	– Adjustable pliers – Tightening capability.....	28
Figure 18	– Adjustable pliers – Bending test	29
Figure 19	– Vice-grip pliers – Tightening capability – Blocking and unblocking of the handle	30
Figure 20	– Adjustable insulator fork – Torsion of the attachment system	31
Figure 21	– Adjustable insulator fork – Bending test	32
Figure 22	– Adjustable insulator fork – Articulation test.....	32
Figure 23	– All-angle pliers – Tightening capability	33
Figure 24	– All-angle pliers – Bending test.....	34
Figure 25	– Pin holder – Resistance of the spring	35
Figure 26	– Pin holder – Bending test	35

Figure 27 – Ammeter holder – Torsion test	36
Figure 28 – Ammeter holder – Shock test	38
Figure 29 – Anti-interference braid applicator – Controlling the sliding rod	39
Figure 30 – Anti-interference braid applicator – Bending test	40
Figure 31 – Hack saw – Bending test mounting	41
Figure 32 – Mirror – Friction test	42
Figure 33 – Conductor gauge – Testing the slide	43
Figure 34 – Conductor gauge – Distortion of the gauge body	43
Figure 35 – Gap gauge – Tension test	44
Figure 36 – Gap gauge – Electrical test	45
Figure A.1 – First example	47
Figure A.2 – Second example	48
Table 1 – Mechanical characteristics of splined end devices (to be supplied by the manufacturer)	11
Table 2 – Mechanical characteristics of clevis and tongue stick devices (to be supplied by the manufacturer)	12
Table C.1 – Type tests for splined end devices	50
Table C.2 – Type tests for clevis and tongue stick devices	54
Table D.1 – Classification of defects and associated requirements and tests for splined end devices	55
Table D.2 – Classification of defects and associated requirements and tests for clevis and tongue stick devices	59

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LIVE WORKING – INSULATING STICKS AND ATTACHABLE DEVICES –

Part 2: Attachable devices

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60832-2 has been prepared by IEC technical committee 78: Live working.

The first edition of IEC 60832-1 and that of IEC 60832-2 cancel and replace the first edition of IEC 60832 published in 1988. The two parts have been created to clearly separate the requirements and testing of insulating sticks from those of attachable universal devices.

Compared to IEC 60832, the major changes included in IEC 60832-2 are:

- updating of the list of devices;
- clarifying the applicability of the document to other attachment system than splined end-fitting;
- application of conformity assessment for products having completed the production phase, according to IEC 61318:2007 (Edition 3), focusing on the classification of defects and the introduction of alternative testing in case of production follow-up.

The text of this standard is based on the following document:

FDIS	Voting report
78/839/FDIS	78/845/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60832 series, published under the general title *Live working – Insulating sticks and attachable devices*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

The purpose of this standard is to provide essential requirements. Each user of this standard may supplement it with their own requirements. For example, the user may add requirements regarding the use of attachable devices on d.c. electrical installations or the mechanical performance or compatibility and interchangeability with tools already in service. In such cases, caution should be taken to maintain or improve the performance of the products.

This publication has been prepared in accordance with the requirements of IEC 61477.

The products designed and manufactured according to this standard contribute to the safety of the users provided they are used by skilled persons, in accordance with safe methods of work and the instructions for use.

The product covered by this standard may have an impact on the environment during some or all stages of its life cycle. These impacts can range from slight to significant, be of short-term or long-term, and occur at the global, regional or local level.

Except for a disposal statement in the instructions for use, this standard does not include requirements and test provisions for the manufacturers of the product, or recommendations to the users of the product for environmental improvement. However, all parties intervening in its design, manufacture, packaging, distribution, use, maintenance, repair, reuse, recovery and disposal are invited to take account of environmental considerations.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60832-2:2010

<https://standards.iteh.ai/catalog/standards/sist/29a61f7d-db37-4ef0-8582-db25b361d2b2/sist-en-60832-2-2010>

LIVE WORKING – INSULATING STICKS AND ATTACHABLE DEVICES –

Part 2: Attachable devices

1 Scope

This part of IEC 60832 gives the essential requirements for devices that can be attached onto and removed from the fitting of the insulating sticks for live working, for use on a.c. electrical installations.

Part 1 of IEC 60832 covers insulating sticks.

In this part of the standard, the term “device” is used for “attachable device”, unless otherwise specified.

Products designed and manufactured according to this standard contribute to the safety of the users provided they are used by skilled persons, in accordance with safe methods of work and the instructions for use.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this international standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60212:1971, *Standard conditions for use prior to and during the testing of solid electrical insulating materials*

IEC 60417, *Graphical symbols for use on equipment*

IEC 61318:2007, *Live working – Conformity assessment applicable to tools, devices and equipment*

IEC 61477, *Live working – Minimum requirements for the utilization of tools, devices and equipment*

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61318 and the following apply.

3.1.1**rated value**

value of a quantity used for specification purposes, established for a specified set of operating conditions of a component, device, equipment or system

[IEV 151-16-08]

3.1.2**type of device**

family of devices which are of the same design and application and are of similar dimensions

3.2 Symbols

T_N	rated torque given by the manufacturer for a given device and for testing purposes
F_{TN}	rated tensile force given by the manufacturer for a given device and for testing purposes
F_{CN}	rated compression force given by the manufacturer for a given device and for testing purposes
F_{BN}	rated bending force given by the manufacturer for a given device and for testing purposes

4 Requirements

iTeh STANDARD PREVIEW
(standards.iteh.ai)

4.1 General

The following requirements have been prepared in order that the products covered by this standard are designed and manufactured to contribute to the safety of the users, provided they are used by persons skilled for live working, in accordance with safe methods of work and the instructions for use.

All bolts used to join two parts together shall be of suitable and sufficient mechanical strength both in tension and shear for that purpose.

Devices subjected to tensile or compressive forces when in use shall be designed in such a way that the force shall be exerted along the axis of the stick.

The method for fixing the device shall ensure that it cannot become accidentally detached when in use.

The method for fixing the device shall be designed and constructed to allow the angle formed by the axis of the stick and the device fitted to it to be adjusted in steps of 30°. Two examples of such a system are shown in Annex A.

4.2 Dimensional and mechanical requirements**4.2.1 Dimensional requirements**

For each type of device complying with this part of the standard, the manufacturer shall provide in writing the rated dimensions and parameters relating directly to its specific functions.

NOTE Conducting devices should be designed to be as small as possible consistent with their proper functioning to reduce the risk of short-circuits.