

## SLOVENSKI STANDARD SIST EN 60891:2011

01-marec-2011

Nadomešča: SIST EN 60891:2001

# Postopki za temperaturno in sevalno korekcijo izmerjenih karakteristik I-U fotonapetostnih naprav (IEC 60891:2009 (EQV))

Procedures for temperature and irradiance corrections to measured I-V characteristics of photovoltaic devices

Verfahren zur Umrechung von gemessenen Strom-Spannungs-Kennlinien von photovoltaischen Bauelementen auf andere Temperaturen und Bestrahlungsstärken (IEC 60891:2009)

### SIST EN 60891:2011

Procédures pour les corrections en fonction de la température et de l'éclairement à appliquer aux caractéristiques I-V mesurées des dispositifs photovoltaïques

Ta slovenski standard je istoveten z: EN 60891:2010

ICS:

27.160 Sončna energija

Solar energy engineering

SIST EN 60891:2011

en



## iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 60891:2011 https://standards.iteh.ai/catalog/standards/sist/646a3ed3-ff0a-48f3-bfb2b411f1d6f3d1/sist-en-60891-2011

### SIST EN 60891:2011

## EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

## EN 60891

March 2010

ICS 27.160

Supersedes EN 60891:1994

English version

### Photovoltaic devices -Procedures for temperature and irradiance corrections to measured I-V characteristics

(IEC 60891:2009)

Dispositifs photovoltaïques -Procédures pour les corrections en fonction de la température et de l'éclairement à appliquer aux caractéristiques I-V mesurées (CEI 60891:2009) Verfahren zur Umrechung von gemessenen Strom-Spannungs-Kennlinien von photovoltaischen Bauelementen auf andere Temperaturen und Bestrahlungsstärken (IEC 60891:2009)

## iTeh STANDARD PREVIEW (standards.iteh.ai)

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alterations/sist/646a3ed3-fl0a-48f3-bfb2-

b411f1d6f3d1/sist-en-60891-2011

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

## CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

© 2010 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

### Foreword

The text of document 82/581/FDIS, future edition 2 of IEC 60891, prepared by IEC TC 82, Solar photovoltaic energy systems, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60891 on 2010-03-01.

This European Standard supersedes EN 60891:1994.

The main technical changes with regard to the EN 60891:1994 are as follows:

- extends existing translation procedure to irradiance change during I-V measurement;
- adds 2 new translation procedures;
- revises procedure for determination of temperature coefficients to include PV modules;
- defines new procedure for determination of internal series resistance;
- defines new procedure for determination of curve correction factor.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented D PREVIEW at national level by publication of an identical national standard or by endorsement and ards.iteh.ai) (dop) 2010-12-01
- latest date by which the national standards conflicting o be withdrawn <u>5151 EN 60891:2011</u> (dow) https://standards.iteh.ai/catalog/standards/sist/646a3ed3-ff0a-48f3-bfb2with the EN have to be withdrawn 2013-03-01 Annex ZA has been added by CENELEC.

### Endorsement notice

The text of the International Standard IEC 60891:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 60904-5 NOTE Harmonized as EN 60904-5. - 3 -

### Annex ZA

(normative)

# Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Publication	Year	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60904-1	-	Photovoltaic devices - Part 1: Measurement of photovoltaic current-voltage characteristics	EN 60904-1	-
IEC 60904-2	-	Photovoltaic devices - Part 2: Requirements for reference solar devices	EN 60904-2	-
IEC 60904-7	- <b>iT</b> (	Photovoltaic devices - RD PREVIE Part 7: Computation of the spectral mismatch correction for measurements of photovoltaic devices	<b>E</b> N 60904-7	-
IEC 60904-9	- https://st	Photovoltaic <u>devices<sub>60891</sub>.2011</u> an <mark>Part 9: Solar simulator performance</mark> 13-ff0a-48f requirements 6f3d1/sist-en-60891-2011	EN 60904-9 3-bfb2-	-
IEC 60904-10	-	Photovoltaic devices - Part 10: Methods of linearity measurement	EN 60904-10	-



## iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 60891:2011 https://standards.iteh.ai/catalog/standards/sist/646a3ed3-ff0a-48f3-bfb2b411f1d6f3d1/sist-en-60891-2011



**IEC 60891** 

Edition 2.0 2009-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

Photovoltaic devices of Procedures for temperature and irradiance corrections to measured I-V characteristics tandards.iteh.ai)

Dispositifs photovoltaïques – Procédures pour les corrections en fonction de la température et de l'éclairement à appliquer aux caractéristiques I-V mesurées b411fld6f3d1/sist-en-60891-2011

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE CODE PRIX



ICS 27.160

ISBN 978-2-88910-316-4

### CONTENTS

- 2 -

FO	REWC	PRD			
1	Scop	e5			
2	Normative references				
3	Correction procedures				
	3.1	General			
	3.2	Correction procedure 1			
	3.3	Correction procedure 27			
	3.4	Correction procedure 3			
4	Deter	mination of temperature coefficients13			
	4.1	General			
	4.2	Apparatus13			
	4.3	Procedure in natural sunlight14			
	4.4	Procedure with a solar simulator			
	4.5	Calculation of temperature coefficients			
5	Deter	mination of internal series resistance $R_{S}$ and $R'_{S}$			
	5.1	General15			
	5.2	Correction procedure 116			
	5.3	Correction procedure 2TANDARD PREVIEW 17			
6	Deter	mination of the curve correction factor k and k. 18   General 18			
	6.1	General			
	6.2	Procedure			
7		rtinghttps://standards.iteh.ai/catalog/standards/sist/646a3ed3~ff0a-48f3-bfb219			
Bib	liograp	b411fld6f3d1/sist-en-60891-2011 21			
Fig	ure 2 -	- Example of the correction of the I-V characteristics by Equations (6) and (7) 10 - Schematic diagram of the relation of $G_3$ and $T_3$ which can be chosen in the ous correction for irradiance and temperature, for a fixed set of $T_1$ , $G_1$ , $T_2$ ,			
and	$G_2$ by	/ Equations (8) and (9)11			
vari	ious ra	- Schematic diagram of the processes for correcting the I-V characteristics to anges of irradiance and temperature based on three measured istics			
		- Schematic diagram of the processes for correcting the I-V characteristics to angles of irradiance and temperature based on four measured characteristics			
Fig	ure 5 -	- Positions for measuring the temperature of the test module behind the cells 14			
Fig	ure 6 -	- Determination of internal series resistance16			
Fig	ure 7 -	- Determination of <i>V</i> <sub>OC</sub> irradiance correction factor and internal series			
		- Determination of curve correction factor			

### INTERNATIONAL ELECTROTECHNICAL COMMISSION

## PHOTOVOLTAIC DEVICES – PROCEDURES FOR TEMPERATURE AND IRRADIANCE CORRECTIONS TO MEASURED I-V CHARACTERISTICS

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC/National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, <u>access to IEC marks</u> of conformity. IEC is not responsible for any services carried out by independent certification bodies rds/sist/646a3ed3-ff0a-48f3-bfb2-
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60891 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

This second edition cancels and replaces the first edition issued in 1987 and its Amendment 1 (1992) and constitutes a technical revision.

The main technical changes with regard the previous edition are as follows:

- extends edition 1 translation procedure to irradiance change during I-V measurement;
- adds 2 new translation procedures;
- revises procedure for determination of temperature coefficients to include PV modules;
- defines new procedure for determination of internal series resistance;
- defines new procedure for determination of curve correction factor.

### - 4 -

The text of this standard is based on the following documents:

FDIS	Report on voting
82/581/FDIS	82/588/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 60891:2011</u> https://standards.iteh.ai/catalog/standards/sist/646a3ed3-ff0a-48f3-bfb2b411f1d6f3d1/sist-en-60891-2011

# PHOTOVOLTAIC DEVICES – PROCEDURES FOR TEMPERATURE AND IRRADIANCE CORRECTIONS TO MEASURED I-V CHARACTERISTICS

### 1 Scope

This standard defines procedures to be followed for temperature and irradiance corrections to the measured I-V (current-voltage) characteristics of photovoltaic devices. It also defines the procedures used to determine factors relevant for these corrections. Requirements for I-V measurement of photovoltaic devices are laid down in IEC 60904-1.

NOTE 1 The photovoltaic devices include a single solar cell with or without a protective cover, a sub-assembly of solar cells, or a module. A different set of relevant parameters for I-V correction applies for each type of device. Although the determination of temperature coefficients for a module (or sub-assembly of cells) may be calculated from single cell measurements, it should be noted that the internal series resistance and curve correction factor should be separately measured for a module or subassembly of cells.

NOTE 2 The term "test specimen" is used to denote any of these devices.

NOTE 3 Care should be taken regarding the use of I-V correction parameters. The parameters are valid for the PV device for which they have been measured. Variations may occur within a production lot or the type class.

### 2 Normative references iTeh STANDARD PREVIEW

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

#### SIST EN 60891:2011

IEC 60904-1, *Photovoltaicndevicesai*-caPartstIndMeasurements-fof-photovoltaic current-voltage characteristics b411fld6Bd1/sist-en-60891-2011

IEC 60904-2, Photovoltaic devices – Part 2: Requirements for reference solar devices

IEC 60904-7, Photovoltaic devices – Part 7: Computation of the spectral mismatch correction for measurements of photovoltaic devices

IEC 60904-9, Photovoltaic devices – Part 9: Solar simulator performance requirements

IEC 60904-10, Photovoltaic devices – Part 10: Methods of linearity measurement

### **3** Correction procedures

#### 3.1 General

Three procedures for correcting measured current-voltage characteristics to other conditions of temperature and irradiance (such as STC) can be applied. The first is identical to the procedure given in Edition 1 of this standard, but the equation has been rewritten for easier understanding. The second procedure is an alternative algebraic correction method which yields better results for large irradiance corrections (>20 %). Both procedures require that correction parameters of the PV device are known. If not known they need to be determined prior to performing the correction. The third procedure is an interpolation method which does not require correction parameters as input: It can be applied when a minimum of three current-voltage curves have been measured for the test device. These three current-voltage curves span the temperature and irradiance range for which the correction method is applicable.