



SLOVENSKI STANDARD
oSIST IEC 60079-0:2018
01-april-2018

Eksplozivne atmosfere - 0. del: Oprema - Splošne zahteve

Explosive atmospheres - Part 0: Equipment - General requirements

Explosionsgefährdete Bereiche - Teil 0: Betriebsmittel - Allgemeine Anforderungen

Atmosphères explosives - Partie 0: Matériel - Exigences générales

Ta slovenski standard je istoveten z: IEC 60079-0 Ed. 7.0

[oSIST IEC 60079-0:2018](https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-f4bf-4890-ba24-bdd3f1780312/osist-iec-60079-0-2018)

<https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-f4bf-4890-ba24-bdd3f1780312/osist-iec-60079-0-2018>

ICS:

29.260.20	Električni aparati za eksplozivna ozračja	Electrical apparatus for explosive atmospheres
-----------	---	--

oSIST IEC 60079-0:2018

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST IEC 60079-0:2018](#)

<https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-f4bf-4890-ba24-bdd3f1780312/osist-iec-60079-0-2018>



IEC 60079-0

Edition 7.0 2017-12

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 0: Equipment – General requirements

Atmosphères explosives –
Partie 0: Matériel – Exigences générales

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.260.20

ISBN 978-2-8322-5065-5

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD	8
1 Scope	15
2 Normative references	16
3 Terms and definitions	18
4 Equipment grouping	36
4.1 General	36
4.2 Group I	36
4.3 Group II	36
4.4 Group III	36
4.5 Equipment for a particular explosive gas atmosphere	37
5 Temperatures	37
5.1 Environmental influences	37
5.1.1 Ambient temperature	37
5.1.2 External source of heating or cooling	37
5.2 Service temperature	37
5.3 Maximum surface temperature	38
5.3.1 Determination of maximum surface temperature	38
5.3.2 Limitation of maximum surface temperature	38
5.3.3 Small component temperature for Group I or Group II electrical equipment	39
5.3.4 Component temperature of smooth surfaces for Group I or Group II electrical equipment	40
6 Requirements for all equipment	41
6.1 General	41
6.2 Mechanical strength of equipment	41
6.3 Opening times	41
6.4 Circulating currents in enclosures (e.g. of large electric machines)	42
6.5 Gasket retention	42
6.6 Electromagnetic and ultrasonic energy radiating equipment	42
6.6.1 General	42
6.6.2 Radio frequency sources	42
6.6.3 Ultrasonic sources	43
6.6.4 Lasers, luminaires, and other non-divergent continuous wave optical sources	44
7 Non-metallic enclosures and non-metallic parts of enclosures	44
7.1 General	44
7.1.1 Applicability	44
7.1.2 Specification of materials	44
7.2 Thermal endurance	45
7.2.1 Tests for thermal endurance	45
7.2.2 Material selection	46
7.2.3 Alternative qualification of elastomeric sealing O-rings	46
7.3 Resistance to ultraviolet light	46
7.4 Electrostatic charges on external non-metallic materials	47
7.4.1 Applicability	47
7.4.2 Avoidance of a build-up of electrostatic charge for Group I or Group II	47

7.4.3	Avoidance of a build-up of electrostatic charge for Group III	49
7.5	Attached external conductive parts	50
8	Metallic enclosures and metallic parts of enclosures	51
8.1	Material composition	51
8.2	Group I	51
8.3	Group II	51
8.4	Group III	52
8.5	Copper Alloys	52
9	Fasteners	52
9.1	General.....	52
9.2	Special fasteners	53
9.3	Holes for special fasteners.....	53
9.3.1	Thread engagement.....	53
9.3.2	Tolerance and clearance	53
9.4	Hexagon socket set screws.....	54
10	Interlocking devices	54
11	Bushings	54
12	(Reserved for future use).....	54
13	Ex Components	54
13.1	General.....	54
13.2	Mounting.....	55
13.3	Internal mounting	55
13.4	External mounting	55
13.5	Ex Component certificate	55
14	Connection facilities	55
14.1	General.....	55
14.2	Type of protection.....	56
14.3	Creepage and clearance	56
15	Connection facilities for earthing or bonding conductors	56
15.1	Equipment requiring earthing or bonding.....	56
15.1.1	Internal earthing	56
15.1.2	External bonding.....	56
15.2	Equipment not requiring earthing	56
15.3	Size of protective earthing conductor connection	56
15.4	Size of equipotential bonding conductor connection	57
15.5	Protection against corrosion.....	57
15.6	Secureness of electrical connections	57
15.7	Internal earth continuity plate.....	57
16	Entries into enclosures	57
16.1	General.....	57
16.2	Identification of entries.....	57
16.3	Cable glands.....	58
16.4	Blanking elements.....	58
16.5	Thread adapters	58
16.6	Temperature at branching point and entry point	59
16.7	Electrostatic charges of cable sheaths	59
17	Supplementary requirements for electric machines	60
17.1	General.....	60

iTech STANDARD PREVIEW

(standards.iteh.ai)

oSIST IEC 60079-0:2018

<https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-4bf-4890-ba24->[bdd3ff780312/osist-iec-60079-0-2018](https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-4bf-4890-ba24-bdd3ff780312/osist-iec-60079-0-2018)

17.2	Ventilation.....	60
17.2.1	Ventilation openings	60
17.2.2	Materials for external fans	60
17.2.3	Cooling fans of rotating electric machines.....	60
17.2.4	Auxiliary motor cooling fans.....	61
17.2.5	Room ventilating fans	61
17.3	Bearings	62
18	Supplementary requirements for switchgear	62
18.1	Flammable dielectric	62
18.2	Disconnectors	62
18.3	Group I – Provisions for locking	63
18.4	Doors and covers.....	63
19	Reserved for future use	63
20	Supplementary requirements for external plugs, socket outlets and connectors for field wiring connection	63
20.1	General.....	63
20.2	Explosive gas atmospheres	64
20.3	Explosive dust atmospheres	64
20.4	Energized plugs	64
21	Supplementary requirements for luminaires.....	64
21.1	General.....	64
21.2	Covers for luminaires of EPL Mb, EPL Gb, or EPL Db	64
21.3	Covers for luminaires of EPL Gc or EPL Dc	65
21.4	Sodium lamps	65
22	Supplementary requirements for caplights and handlights	65
22.1	Group I caplights	65
22.2	Group II and Group III caplights and handlights	65
23	Equipment incorporating cells and batteries.....	66
23.1	General.....	66
23.2	Interconnection of cells to form batteries	66
23.3	Cell types.....	66
23.4	Cells in a battery.....	69
23.5	Ratings of batteries.....	69
23.6	Interchangeability	69
23.7	Charging of primary batteries	69
23.8	Leakage.....	69
23.9	Connections.....	69
23.10	Orientation.....	69
23.11	Replacement of cells or batteries	69
23.12	Replaceable battery pack.....	70
24	Documentation	70
25	Compliance of prototype or sample with documents.....	70
26	Type tests	70
26.1	General.....	70
26.2	Test configuration	70
26.3	Tests in explosive test mixtures	70
26.4	Tests of enclosures.....	71
26.4.1	Order of tests	71

26.4.2	Resistance to impact	73
26.4.3	Drop test	74
26.4.4	Acceptance criteria	75
26.4.5	Degree of protection (IP) by enclosures	75
26.5	Thermal tests	76
26.5.1	Temperature measurement	76
26.5.2	Thermal shock test	78
26.5.3	Small component ignition test (Group I and Group II)	78
26.6	Torque test for bushings	79
26.6.1	Test procedure	79
26.6.2	Acceptance criteria	80
26.7	Non-metallic enclosures or non-metallic parts of enclosures	80
26.7.1	General	80
26.7.2	Test temperatures	80
26.8	Thermal endurance to heat	80
26.9	Thermal endurance to cold	81
26.10	Resistance to UV light	81
26.10.1	General	81
26.10.2	Light exposure	82
26.10.3	Acceptance criteria	82
26.11	Resistance to chemical agents for Group I equipment	82
26.12	Earth continuity	83
26.13	Surface resistance test of parts of enclosures of non-metallic materials	84
26.14	Measurement of capacitance	85
26.14.1	General	85
26.14.2	Test procedure	85
26.15	Verification of ratings of ventilating fans	86
26.16	Alternative qualification of elastomeric sealing O-rings	86
26.17	Transferred charge test	86
26.17.1	Test equipment	86
26.17.2	Test sample	87
26.17.3	Test procedure	87
27	Routine tests	88
28	Manufacturer's responsibility	88
28.1	Conformity with the documentation	88
28.2	Certificate	89
28.3	Responsibility for marking	89
29	Marking	89
29.1	Applicability	89
29.2	Location	89
29.3	General	89
29.4	Ex marking for explosive gas atmospheres	90
29.5	Ex marking for explosive dust atmospheres	92
29.6	Combined types (or levels) of protection	95
29.7	Multiple types of protection	95
29.8	Ga equipment using two independent Gb types (or levels) of protection	95
29.9	Boundary wall	95
29.10	Ex Components	95
29.11	Small Ex Equipment and small Ex Components	96

29.12	Extremely small Ex Equipment and extremely small Ex Components	96
29.13	Warning markings	96
29.14	Cells and batteries	97
29.15	Electric machines operated with a converter	97
29.16	Examples of marking	98
30	Instructions	101
30.1	General	101
30.2	Cells and batteries	102
30.3	Electric machines	103
30.4	Ventilating fans	103
30.5	Cable glands	104
Annex A	(normative) Supplementary requirements for cable glands	105
A.1	General	105
A.2	Constructional requirements	105
A.2.1	Cable sealing	105
A.2.2	Filling compounds	106
A.2.3	Clamping	106
A.2.4	Lead-in of cable	106
A.2.5	Release by a tool	107
A.2.6	Fixing	107
A.2.7	Degree of protection	107
A.3	Type tests	107
A.3.1	Tests of clamping of non-armoured and braided cables	107
A.3.2	Tests of clamping of armoured cables	110
A.3.3	Type test for resistance to impact	111
A.3.4	Test for degree of protection (IP) of cable glands	112
A.4	Marking	113
A.4.1	Marking of cable glands	113
A.4.2	Identification of cable-sealing rings	113
A.5	Instructions	113
Annex B	(normative) Requirements for Ex Components	115
Annex C	(informative) Example of rig for resistance to impact test	118
Annex D	(informative) Electric machines connected to converters	119
Annex E	(informative) Temperature evaluation of electric machines	120
Annex F	(informative) Guidance flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	123
Annex G	(informative) Guidance flowchart for tests of cable glands	124
Annex H	(informative) Shaft voltages resulting in motor bearing or shaft brush sparking Discharge energy calculation	125
H.1	General	125
H.2	Assessment of the risk of ignition using ignition energy calculation	125
H.3	Shaft voltage determination for a rotating machine	126
H.4	Capacitance “C” calculation for a rotating machine	126
H.5	Energy “E” calculation for a rotating machine	129
H.6	Assessment using reference curves	129
Bibliography	131
Figure 1	– Typical battery examples	20

Figure 2 – Typical battery compartment	21
Figure 3 – Typical replaceable battery pack	22
Figure 4 – Tolerances and clearance for threaded fasteners	53
Figure 5 – Contact surface under head of fastener with a reduced shank	54
Figure 6 – Cable gland	59
Figure 7 – Conduit entry	59
Figure 8 – Assembly of test sample for earth-continuity test	84
Figure 9 – Test piece with painted electrodes	85
Figure 10 – Compression set of an O-ring	86
Figure A.1 – Illustration of the terms used for cable glands	106
Figure A.2 – Rounded edge of the point of entry of the flexible cable	107
Figure A.3 – Example of rig for resistance to impact test	112
Figure C.1 – Example of rig for resistance to impact test	118
Figure F.1 – Non-metallic enclosures or non-metallic parts of enclosures	123
Figure H.1 – Capacitance stored in bearing clearance of sleeve bearing Between journal and outer bearing housing	128
Figure H.2 – Air-gap between stator and rotor	128
Figure H.3 – Typical surfaces that form capacitors from the motor shaft to ground	129
Figure H.4 – Capacitive ignition curves	130
(standards.iteh.ai)	
Table 1 – Ambient temperatures in service and additional marking	37
Table 2 – Classification of maximum surface temperature for Group II electrical equipment	38
Table 3 – Assessment of temperature classification according to component size	40
Table 4 – Assessment of temperature classification Component surface area $\geq 20 \text{ mm}^2$	40
Table 5 – Threshold power	43
Table 6 – Threshold energy	43
Table 7 – Limitation of surface areas	48
Table 8 – Maximum diameter or width	49
Table 9 – Limitation of thickness of non-metallic layer	49
Table 10 – Maximum acceptable transferred charge	49
Table 11 – Maximum capacitance of unearthed conductive parts	51
Table 12 – Minimum cross-sectional area of PE conductors	57
Table 13 – Primary cells	66
Table 14 – Secondary cells	68
Table 15 – Tests for resistance to impact	74
Table 16 – Torque to be applied to the stem of bushing used for connection facilities	79
Table 17 – Thermal endurance test	80
Table 18 – Text of warning markings	97
Table 19 – Example of type-test converter parameters	103
Table B.1 – Applicability of clauses to Ex Components	115
Table H.1 – Maximum permitted energy	126

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 0: Equipment – General requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
<https://standards.iteh.ai/catalog/standards/sist/4a75e9e8-f1bf-4890-ba24-1e7a6504c02c/iec-60079-0-2017>
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This seventh edition cancels and replaces the sixth edition, published in 2011. This edition constitutes a technical revision.

The significance of the changes between IEC Standard, IEC 60079-0, Edition 6 (2011) and IEC 60079-0, Edition 7 (2017) are as listed below:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Throughout document, "electrical equipment" replaced by "equipment" where appropriate.	Multiple	X		
Scope List of "Type of "Protection" and "Product" standards combined into one list.	1	X		
Definitions used in multiple sub-parts added. Definitions harmonized across sub-parts and added to 60079-0 where appropriate. Battery definitions updated	3	X		
Clarification of the way that information on process temperature influences can be expressed.	5.1.2	X		
Clarification regarding the determination of service temperatures when dust layers are present	5.2	X		
Clarification on the need to provide service temperature information for Ex Components in the Schedule of Limitations	5.2	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	5.3.2.3.1	A1		
Clarified that for EPL Db, a maximum specified dust layer of greater than 200 mm is not permitted as thicker layers have no additional effect on maximum surface temperature.	b)	X		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	c)		X	
Clarified that for EPL Dc, no dust layer tests are required.	5.3.2.3.3	X		
Clarified that the "temperature" is the temperature of the air surrounding the component	5.3.3	X		
Subdivided section dealing with higher permitted surface temperatures for "smooth" surfaces. Corrected area from 1 000 mm ² to 10 000 mm ² .	5.3.4	X		
Clarified that the "Ex" requirements of IEC 60079 supplement those of the relevant industrial standards.	6.1	X		
Added requirement that where an adhesive is used to secure a gasket, it shall be used within its COT and shall comply with the requirements for cements.	6.5			C1
Requirements relocated to IEC 60079-28	former 6.6.2	A2		
Ultrasonic requirements updated based on latest research work	6.6.3		X	
Added reference to IEC 60079-28	6.6.4	A2		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.2	X		
"RTI-mechanical" has been clarified to include "RTI-mechanical strength" and "RTI-mechanical impact"	7.1.2.2	X		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.3	X		
Relocated information on "cements" from Clause 12.	7.1.2.4	X		
"RTI-mechanical" has been clarified to include "RTI-mechanical strength" and "RTI-mechanical impact". Requirements for cements aligned with the requirements for elastomers.	7.2.2	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Relocation of 10 K margin for EPL Gc or Dc from IEC 60079-15, IEC 60079-18 & IEC 60079-31	7.2.2	A3		
Added clarification with respect to gaskets and seals where only the outer edge is potentially exposed to light.	7.3	X		
Clarification added that one or more of the described techniques may be used	7.4.2	X		
Added additional relaxation for the case where a surface is in contact with an earthed surface on only two of four sides.	7.4.2 b)		X	
Added reference to IEC 60243-1 and IEC 60243-2 for test method to require a 4 kV DC test..	7.4.2.c)			C2
Additional guidance added with respect to the possible Specific Conditions of Use	7.4.2 e)	X		
New option added for portable, mains-powered equipment with earth-connected guard	7.4.2 f)		X	
Added option for determination of maximum transferred charge.	7.4.2 g) Table 10		X	
Added missing limits (same as 7.4.2)	7.4.3 a)	X		
Clarified that it is a dc test that is conducted	7.4.3 b)	X		
Clarified that this requirement is not applied to personal or portable equipment	7.5	X		
Clarified Group I limits	8.2	X		
Clarified Group II, EPL Ga limits	8.3	X		
Added limitation for external surfaces of >65% copper	8.5			C3
Added clarification as to what is considered a tool	9.1	X		
Clarified that the tolerance class of the set screw is not critical, only that it not protrude from the threaded hole after tightening.	9.4	X		
Information on cements transferred to Clause 7	12	X		
Required that Ex Component Certificates require a Schedule of Limitations in all cases	13.5		X	
Revised to clarified that all connection facilities may not be a "Compartment".	14	X		
Sub-clause split to separate the requirements for protective earthing and equipotential bonding into separate sections	15.3 15.4	X		
Section split to separate secureness of electrical connections from the internal earth continuity plate.	15.6 15.7	X		
Non-threaded Group I cable glands are no longer required to be Ex Components.	16.3		X	
Non-threaded Group I blanking elements are no longer required to be Ex Components.	16.4		X	
Scope of Clause 17 clarified to define applicability	17	X		
Additional guidance notes added to address bearings	17.3	X		
Clarified applicability to disconnectors, interlocks, and maintenance switches.	18.2	X		
Fuse requirements deleted as they are addressed in the individual sub-parts	19	X		
Added requirements for EPL Gc and Dc	20.1			C4

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
The test circuit requirements for a flameproof connection have been removed as they are more completely specified in IEC 60079-1.	20.2	X		
The impact test requirements for luminaires are relocated to Table 15	21.1 Table 15	X		
Clarified interlock switch operation for flameproof luminaires	21.2	X		
Clarified that some Types of Protection permit connection of cells in parallel	23.2	X		
New cell types and data added based on latest available data	Table 13		X	
New cell types and data added based on latest available data	Table 14			C5
Clarification of what documentation is to be prepared regarding the explosion safety aspects of the equipment	24	X		
Clarification that the type tests are to take into consideration the installation instructions	26.2	X		
Clarification that the "glass" requirements also apply to "ceramic" parts	26.4.1.1	X		
Added a permission to interchange the order of tests at the "lower test temperature" and the "upper test temperature".	26.4.1.2.2 26.4.1.2.3	X		
Clarified the construction of the impact test fixture	26.4.2	X		
Clarified the impact tests for glass parts	26.4.2	X		
Added clarification to deal with the new IPX9 ratings	26.4.5.1		X	
Clarified the test voltage for maximum surface temperature	26.5.1.3	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	26.5.1.3	A1		
Relocation of EPL Db specified dust layer requirements from IEC 60079-31	26.5.1.3	A4		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	26.5.1.3		B1	
Clarified that for EPL Dc, the testing is conducted without a dust layer.	26.5.1.3	X		
Relocation of thermal endurance to heat 10K relaxation for Gc equipment from IEC 60079-15, IEC 60079-18, & IEC 60079-31	Table 17	X		
Clarification of a consistent way to address elastomeric materials exposed to ultraviolet light	26.10	X		
Replacement of "oil No. 2" with the revised designation of "oil IRM 902".	26.11	X		
Option added for testing at lower voltages when low resistance materials are encountered	26.13		X	
Transferred charge test added based on IEC TS 60079-32-2	26.17		X	
The reference to a specific instruction document instead of an "X" condition relocated to e) instead of a note giving a permission	29.3 e)	X		
Updated to reflect the additional levels of protection already shown in the sub-parts: "da", "dc", "eb", "ec", "oc", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "qb", "sa", "sb", and "sc".	29.4 b)	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Text added to address marking of "Ex associated equipment"	29.4		X	
Updated to reflect the additional levels of protection already shown in the sub-parts: "ic", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "sa", "sb", and "sc".	29.5 b)	X		
Clarified marking of EPL Da, EPL Db with no dust layer, EPL Db with a specified dust layer, and EPL Dc.	29.5 d)	X		
Introduced marking for EPL Db with a dust layer in a specified orientation	29.5 d)		X	
Text added to address marking of "Ex associated equipment"	29.5		X	
Text added to address marking of equipment intended to be installed in a boundary wall.	29.9		X	
The marking of Ex Component enclosure was aligned with the marking requirements of IEC 60079-1 and IEC 60079-7	29.10	X		
The alternate marking of EPL has been deleted.	former 29.13			C6
Marking for electric machines operated with a converter clarified	29.15	X		
Instruction material guidance clarified	30.1	X		
Additional instruction material for electric machines added	30.3			C7
Additional instruction material for cable glands added	30.5			C8
Allow ISO 10807 hose assemblies to be used with cable glands.	A.1		X	
Clarify testing with stainless steel mandrels	A.3	X		
Reduction of the time / slippage permitted	A.3.1.1		X	
Clarify impact testing of cable glands	A.3.3 Figure A.3	X		
Clarified the order of tests	A.3.4	X		
Clarified remarks	Annex B	X		
Aligned Figure with text	Figure C.1	X		
Clarified operation of electric machines from converters	Annex D (informative)	X		
Clarified temperature testing of electric machines	Annex E (informative)	X		
Flowchart for Cable Gland testing	Annex G (informative)	X		
Guidance of electric machine shaft voltages	Annex H (informative)	X		

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

Explanations:**A) Definitions**

Minor and editorial changes	clarification decrease of technical requirements minor technical change editorial corrections
------------------------------------	--

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension	addition of technical options
------------------	-------------------------------

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

Major technical changes	addition of technical requirements increase of technical requirements
--------------------------------	--

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

<https://standards.iteh.ai/catalog/standards/sist/4a75a9e8-f4bf-4890-ba24-948879488794/iec-60079-0-2018>

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of changes

- A1 The dust layer requirements for EPL Da are unchanged from what previously existed in IEC 60079-18, Ed 4 and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A2 IEC 60079-28 now includes all requirements for optical radiation for all EPLs.
- A3 The COT requirements for EPL Gc or Dc are unchanged from what previously existed in IEC 60079-15, Ed 4, IEC 60079-18, Ed 4, and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A4 The dust layer requirements for EPL Db with a specified dust layer depth are unchanged from what previously existed in IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- B1 Dust layer requirements for EPL Db with a dust layer in a specified orientation have been added.
- C1 It is recognized that the new requirements were, in many cases, already applied. The change is to ensure that they are uniformly and consistently applied.
- C2 Require that the test be conducted at 4 kV DC.
- C3 The limitation applies to external surfaces of other than cable glands, blanking elements, thread adapters and bushings.
- C4 The added requirements for tool securing and marking are consistent with the approach in IEC 60079-15
- C5 Voltage values were changed following additional research due to the complicated assessment and sometimes unspecified construction of Li/Ion-cells. It was found that some voltage values previously stated were too low.