

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Cable trunking systems and cable ducting systems for electrical installations –
Part 2-3: Particular requirements – Slotted cable trunking systems intended for
installation in cabinets**

**Systèmes de goulottes et systèmes de conduits-profilés pour installations
électriques –**

**Partie 2-3 : Exigences particulières – Systèmes de goulottes de câblage pour
installation dans les armoires**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 61084-2-3

Edition 1.1 2024-02
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Cable trunking systems and cable ducting systems for electrical installations –
Part 2-3: Particular requirements – Slotted cable trunking systems intended for
installation in cabinets**

**Systèmes de goulottes et systèmes de conduits-profilés pour installations
électriques –**

**Partie 2-3 : Exigences particulières – Systèmes de goulottes de câblage pour
installation dans les armoires**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.060.01, 29.120.10

ISBN 978-2-8322-8375-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



Cable trunking systems and cable ducting systems for electrical installations – Part 2-3: Particular requirements – Slotted cable trunking systems intended for installation in cabinets

Systèmes de goulottes et systèmes de conduits-profilés pour installations électriques –

Partie 2-3 : Exigences particulières – Systèmes de goulottes de câblage pour installation dans les armoires



CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	5
4 General requirements	6
5 General conditions for tests	6
6 Classification	7
7 Marking and documentation	7
8 Dimensions.....	7
9 Construction	8
10 Mechanical properties.....	8
11 Electrical properties.....	10
12 Thermal properties	10
13 Fire hazard	10
14 External influences	11
15 Electromagnetic compatibility	11
Annex A (informative) Types of cable trunking systems (CTS) and cable ducting systems (CDS).....	17
Annex B (normative) CTS/CDS IK code	18
Bibliography.....	19
Figure 101 – Examples of pattern of fixing holes in the base of the slotted trunking length	12
Figure 102 – Examples of sizes for the fixing holes.....	13
Figure 103 – Fixing distances for cable support test	14
Figure 104 – Arrangements for cable support test.....	15
Figure 105 – Arrangement for flame test	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

CABLE TRUNKING SYSTEMS AND CABLE DUCTING SYSTEMS FOR ELECTRICAL INSTALLATIONS –

Part 2-3: Particular requirements – Slotted cable trunking systems intended for installation in cabinets

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61084-2-3 edition 1.1 contains the first edition (2017-03) [documents 23A/829/FDIS and 23A/835/RVD] and its amendment 1 (2024-02) [documents 23A/1063/FDIS and 23A/1071/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61084-2-3 has been prepared by subcommittee 23A: Cable management systems, of IEC technical committee 23: Electrical accessories.

This International standard is to be used in conjunction with IEC 61084-1:2017.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part of the IEC 61084 series supplements or modifies the corresponding clauses of IEC 61084-1:2017 as follows:

- where no particular clause or subclause of IEC 61084-1 is mentioned, the corresponding clause or subclause applies as far as it is reasonable;
- where "addition", "modification" or "replacement" is stated, the relevant text of IEC 61084-11 is to be adapted accordingly;
- subclauses, figures and tables which are additional to those in IEC 61084-1 are numbered starting from 101.

In this standard, the following print types are used:

- requirements and definitions: roman type;
- *compliance statements: italic type.*

A list of all parts in the IEC 61084 series, published under the general title *Cable trunking and cable ducting systems for electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

[IEC 61084-2-3:2017](https://standards.ch.ai/catalog/standards/iec/94d6ab18-cb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017)

<https://standards.ch.ai/catalog/standards/iec/94d6ab18-cb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017>

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

CABLE TRUNKING SYSTEMS AND CABLE DUCTING SYSTEMS FOR ELECTRICAL INSTALLATIONS –

Part 2-3: Particular requirements – Slotted cable trunking systems intended for installation in cabinets

1 Scope

This part of the IEC 61084 series specifies requirements and tests for cable trunking systems (CTS) and cable ducting systems (CDS) intended for the accommodation, and where necessary for the electrically protective separation, of insulated conductors, cables and possibly other electrical equipment in electrical and/or communication systems installations. The maximum voltage of these installations is 1 000 V AC and 1 500 V DC.

Slotted cable trunking systems are intended for mounting inside cabinets in electrical and/or communication system installations.

This document does not apply to conduit systems, cable tray systems, cable ladder systems, power track systems or equipment covered by other standards.

NOTE Wherever reference is made in this document to IEC 61084-1:2017, this does not apply to cable ducting systems.

2 Normative references

This clause of Part 1 is applicable, except as follows:

Addition:

[IEC 61084-2-3:2017](https://standards.iteh.ai/catalog/standards/iec/94d6ab18-eb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017)

<https://standards.iteh.ai/catalog/standards/iec/94d6ab18-eb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017>

IEC 60228:2004, *Conductors of insulated cables*

IEC 60695-11-5:2004/2016, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*¹

IEC 61084-1:2017, *Cable trunking systems and cable ducting systems for electrical installations – Part 1: General requirements*

3 Terms and definitions

This clause of Part 1 is applicable, except as follows:

Addition:

3.101

slotted cable trunking system

system comprising a slotted trunking length and possibly other slotted cable trunking system components for the accommodation and laying in of insulated conductors or cables intended for use in a cabinet or similar

¹ ~~This publication was withdrawn.~~

3.102**slotted cable trunking system component**

part of the system which includes

- a) slotted trunking length;
- b) trunking fitting;
- c) fixing device;
- d) system accessory

Note 1 to entry: The above mentioned system components are not necessarily included all together in a system. Different combinations of system components can be used.

3.103**slotted trunking length**

trunking length with slotted walls and with cover(s) which may be integral part of the base and/or may be slotted

3.104**slotted wall**

wall with openings allowing cables to pass through

Note 1 to entry: The openings can be with open or closed boundary and may have different shapes, normally designed to maintain wiring in position.

3.105**wall finger**

part of a slotted wall between two consecutive slots with open boundary

3.106**break-out line**

line which may be available on the walls of a trunking length to facilitate the breaking of walls or parts thereof, such as a wall finger

4 General requirements

This clause of Part 1 is applicable, except as follows:

Replacement:

Slotted cable trunking systems shall be so designed and constructed that where required they ensure reliable support, accommodation and segregation of the insulated conductors and/or cables contained therein.

Equipment associated with or incorporated in a system component but which is not a system component, shall and need only comply with the relevant standard of this equipment, if any. However it may be necessary to include such equipment in a test arrangement for the purpose of testing its interface with the slotted cable trunking system.

Compliance is checked by carrying out all the tests specified.

5 General conditions for tests

This clause of Part 1 is applicable.

6 Classification

This clause of Part 1 is applicable, except as follows.

6.2 According to resistance to impact for installation and application

Not applicable.

6.1 According to temperatures

Table 2 of Part 1 is not applicable.

6.5 According to electrical continuity characteristic

Not applicable.

6.6 According to electrical insulating characteristic

Not applicable.

6.7 According to degrees of protection provided by enclosure according to IEC 60529:1989

Not applicable.

6.9 According to the system access cover retention

Not applicable.

Additional subclauses:

6.101 According to the intended installation positions

6.101.1 Mounted on vertical or horizontal surface

6.101.2 Mounted on vertical or horizontal surface except in a cover down position

7 Marking and documentation

This clause of Part 1 is applicable.

8 Dimensions

This clause of Part 1 is applicable, except as follows.

Additional subclause:

8.101 The preferred solution for fixing holes, if any, in the base of the slotted trunking lengths according to the different trunking widths as shown in Figure 101 is as follows:

- trunking lengths with a nominal width less or equal to 12,5 mm should preferably have one row of small holes only, as shown in Figure 102 b);
- trunking lengths with a nominal width greater than 12,5 mm and less or equal to 62,5 mm, should preferably have one row of holes only, alternately as shown in Figure 102 a) and in Figure 102 b);
- trunking lengths with a nominal width greater than 62,5 mm should preferably have two or more rows of holes alternately as shown in Figure 102 a) and in Figure 102 b), positioned

at a distance of 25 mm or 50 mm apart, symmetrically located from the trunking centre line.

9 Construction

This clause of Part 1 is applicable, except as follows.

9.2 Apparatus mounting

Not applicable.

9.5 Accessible conductive parts

Not applicable.

9.6 Equipotential bonding

Not applicable.

9.7 Access to live parts

Not applicable.

9.8 Inlet openings

Not applicable.

9.9 Membranes

Not applicable.

9.10 Cable restrainer

Not applicable.

9.11 Cable anchorage

Not applicable.

10 Mechanical properties

This clause of Part 1 is applicable, except as follows.

10.2 Cable support test

Replacement by the following additional subclauses:

10.2.101 General test conditions

Each test is made on one new sample of slotted trunking length having a length of (250 ± 5) mm.

Before the test non-metallic and composite slotted trunking lengths are aged at the temperature declared according to Table 3 of Part 1 with a tolerance of $\pm 2^\circ\text{C}$ for (168 ± 4) h continuously.

The sample is securely fixed, using 10 mm external diameter flat metallic washers and appropriate metallic screws to a rigid smooth support such as a plywood board 16 mm thick. When 10 mm external diameter is too large, suitable smaller washer and appropriate screw are used. Fixing(s) are positioned as shown in Figure 103 at (200 ± 5) mm centres along the length of the sample.

Within the width of the sample:

- for trunking with a width less than ~~50~~ 62,5 mm, one fixing is used as shown in Figure 103 a);
- for trunking with a width equal or greater than ~~50~~ 62,5 mm, two fixings are used as shown in Figure 103 b).

If the manufacturer's instructions require the use of cable retainers or dividers, these are fitted according to the manufacturer's instructions. Cable retainers, if any, are symmetrically fixed along the length.

The sample is subjected to an evenly distributed load of 0,8 g/mm² of the declared usable area for cables, per metre length. The load is distributed between the compartments proportionally to the declared usable area. The load consists of copper insulated conductors or cables complying with ~~class 5~~, Table 3 – class 5 of IEC 60228:2004, or flexible insulated conductors or cables of similar mass per meter.

To allow for settlement of the sample, a pre-load of 10 % of the load is applied and removed after (300 ± 30) s. The measurement apparatus is then calibrated to zero.

Insulated conductors or cables of 25 mm² nominal cross section are placed in the sample so that approximately 50 % of the load is achieved. Insulated conductors or cables of 2,5 mm² nominal cross section are placed on top of the larger cables to achieve the total load within a tolerance of ± 5 g. If the dimensions of the compartment do not permit the accommodation of 25 mm² insulated conductor or cable, 2,5 mm² nominal cross section insulated conductors or cables are used.

<https://standards.iteh.ai/catalog/standards/iec/94d6ab18-cb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017>

<https://standards.iteh.ai/catalog/standards/iec/94d6ab18-cb6b-44e4-a4dc-9d81a6eac574/iec-61084-2-3-2017>

Non-metallic and composite slotted trunking lengths are tested at the maximum application temperature declared by the manufacturer according to Table 3 of Part 1 with a tolerance of ± 2 °C.

10.2.102 Mounting arrangements for slotted trunking lengths

Slotted trunking lengths are mounted according to Figure 104 a).

After $(120 + 5/0)$ min with the load still applied the vertical deflection F is measured at approximately the middle of the length.

F shall not exceed 10 % of the height H with a maximum of 10 mm (see Figure 104 a)).

10.2.103 Mounting arrangements for slotted trunking lengths classified according to 6.101.1

Slotted trunking lengths classified according to 6.101.1 are mounted according to Figure 104 b).

After $(120 + 5/0)$ min with the load still applied the vertical deflection F is measured at approximately the middle of the length.

F shall not exceed 10 % of the width W with a maximum of 10 mm (see Figure 104 b)).

10.3 Impact test

This clause of Part 1 is applicable except as follows.

10.3.1.3 *Replacement of the last paragraph by:*

This test is not applied to wall fingers, knockouts, membranes and the like, and within 50 mm of each end.

Break-out line, if any, is considered as knockout.

10.3.1.4 *Addition of the following sentence at the end of the first paragraph:*

Any cracks in or breaking of wall finger are ignored.

10.3.2 Impact test for installation and application

Not applicable.

10.4 Linear deflection test

Not applicable.

10.5 External load test

Not applicable.

10.6 System access cover retention

Not applicable.

11 Electrical properties

This clause of Part 1 is not applicable.

12 Thermal properties

This clause of Part 1 is applicable.

13 Fire hazard

This clause of Part 1 is applicable, except as follows.

13.1.3 Spread of fire

Replacement:

Slotted cable trunking systems shall either not ignite or if ignited, shall not continue to burn when the source of ignition is removed.

Non-metallic system component or metallic system component coated in paint or any other substance which is likely to affect its resistance to flame propagation is to be considered as a composite system component and tested accordingly.

Compliance is checked as follows:

- *for slotted trunking lengths of non-metallic or composite material by the following flame test;*