

Edition 2.0 2017-05 REDLINE VERSION

INTERNATIONAL STANDARD



Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – Industrial applications with specified electromagnetic environment

<u>IEC 61326-3-2:2017</u>

https://standards.iteh.ai/catalog/standards/iec/4874f1a7-d690-4c08-9d23-0f11633bdad7/iec-61326-3-2-2017





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from sitter UC as UC as the committee in the country of the requester.

either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office	Tel.: +41 22 919 02 11
3, rue de Varembé	Fax: +41 22 919 03 00
CH-1211 Geneva 20	info@iec.ch
Switzerland	www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

EC 61326-3-2:2017

https://standards.iteh.ai/catalog/standards/iec/4874f1a7-d690-4c08-9d23-0f11633bdad7/iec-61326-3-2-2017





Edition 2.0 2017-05 REDLINE VERSION

INTERNATIONAL STANDARD



Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – Industrial applications with specified electromagnetic environment

EC 61326-3-2:2017

https://standards.iteh.ai/catalog/standards/iec/4874f1a7-d690-4c08-9d23-0f11633bdad7/iec-61326-3-2-2017

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 25.040.40; 33.100.20

ISBN 978-2-8322-4367-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

F	OREWO)RD	4
11	NTRODI	JCTION	6
1	Scop)e	8
2	Norn	native references	9
3	5 Term	ns, definitions and abbreviations	10
	3.1	Terms and definitions	10
	3.2	Abbreviations	14
4	Gen	eral	14
5	EMC	test plan	15
-	5 1	General	15
	5.2	Instruction for testing	15
I	5.3	Configuration of EUT during testing	15
	5.3.1	General	15
	5.3.2	2 Composition of EUT	16
	5.3.3	Assembly of EUT	16
	5.3.4	I/O ports	16
	5.3.5	6 Auxiliary equipment (AE)	16
I	5.3.6	Cabling and earthing (grounding)	16
	5.4	Operation conditions of EUT during testing	16
	5.4.1	Operation modes	16
	5.4.2	2 Environmental conditions	16
	5.4.3	B EUT software during test	16
	5.5	Specification of performance criteria	17
	5.6	Test descriptionIEC.61326-3-2:2017	17
ps:6	stanPerf	ormance criterialandards/iec/4874f1a7.d690-4c08-9d23-0f11633bdad7/iec-6132/	63.17-20
	6.1	General	17
1	6.2	Performance criteria A, B and C	17
	6.3	Performance criterion- FS DS	17
	6.3.1	Definition of performance criterion DS	17
	6.3.2	2 Application of the performance criterion FS DS	18
	6.3.3	Aspects to be considered during application of performance criterion DS.	18
7	′ Imm	unity requirements	19
8	Test appl	set-up and test philosophy for EUT with functions intended for safety cations	24
	8.1	Testing of safety-related systems and equipment intended to be used in safety-related systems	24
	8.2	Test philosophy for equipment intended for use in safety-related systems	24
	8.3	Test philosophy for safety-related systems	24
	8.4	Test configuration and test performance	25
	8.5	Monitoring	26
9	Test	results and test report	26
A	nnex A	(informative) Approaches on how to apply IEC 61326-3 series	32
A	nnex B	(informative) Evaluation of electromagnetic phenomena	34
A	Annex C	(informative normative) Details of the Specified electromagnetic environment	36
I	C.1	General	36

C.2	Industrial area with limited access	36
C.3	Limited use of mobile transmitters	36
C.4	Dedicated cables for power supply and control, signal or communication	37
C.5	Separation between power supply and control, signal or communication	
	cables	37
C.6	Factory building mostly consisting of metal construction	38
C.7	Overvoltage/lightning protection by appropriate measures	38
C.8	Pipe heating systems driven by AC mains may be present	39
C.9	No high-voltage substations close to sensitive areas	39
C.10	Presence of low-power devices using ISM frequencies according to CISPR 11	39
C.11	Competent staff	
C.12	Periodic maintenance of equipment and systems	39
C 13	Installation guidelines for equipment and systems	39
Anney D	(informative) Example of immunity levels in the process industry	ور ۱
Figure 1 - tested as	- Typical test set-up for equipment intended for use in safety-related system, stand-alone equipment or entire system	2
Figure 2 - integrated	- Typical test set-up fo <mark>r equipment intended for use</mark> in a safety-related system I into a representative safety-related system during test	2
Figure 3 - tested sta	- Typical test set-up for equipment intended for use in a safety-related system and-alone	
Figure 4 -	- Test set-up for a safety-related system	
Figure A.	1 – Correlation between the standards IEC 61326-1, IEC 61326-2-x, 6-3-1 and IEC 61326-3-2	34
Figure C	1 - Recommended cable layouts for different categories	0. 39
/standards	s. iteh.a/catalog/standards/iec/487411a7-d690-4c08-9d23-0f11633bdad7/iec-61326	-3-2
Table 1 –	Reaction of EUT during test	19
Table 2 – locations	Immunity test requirements for equipment intended for use in industrial with specified electromagnetic environment – Enclosure port	19
Table 3 – locations	Immunity test requirements -for equipment intended for use in industrial with specified electromagnetic environment – Input and output AC rts	2
		∠
I able 4 – locations	with specified electromagnetic environment – Input and output DC	~
hower bo		Z
Table 5 – locations	Immunity test requirements-for equipment intended for use in industrial with specified electromagnetic environment – I/O signal/control ports	22
Table 6 – locations connecte	Immunity test requirements-for equipment intended for use in industrial with specified electromagnetic environment – I/O signal/control ports d directly to power supply networks	2
Table 7 –	Immunity test requirements for equipment intended for use in industrial	
locations	with specified electromagnetic environment – Functional earth port	2
Table B.1	- General considerations for the application of electromagnetic phenomena	
for function	onal safety in industrial applications with specified electromagnetic	0
environm	ent (examples)	3
Table D.1 locations	 Immunity test requirements for equipment intended for use in industrial with a specified electromagnetic environment according to NE 21 	4

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE – EMC REQUIREMENTS –

Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – Industrial applications with specified electromagnetic environment

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications
- transparently to the maximum extent possible in their national and regional publications. Any divergence to between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in 2017 the latter.
 - 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
 - 6) All users should ensure that they have the latest edition of this publication.
 - 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
 - 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
 - 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 61326-3-2 has been prepared by subcommittee 65A: System aspects, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2008. This edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- extension of the frequency range up to 6 GHz for the radio-frequency electromagnetic field test according to IEC 61000-4-3,
- replacement of the performance criterion FS with DS according to the generic standard IEC 61000-6-7,
- adding Table 1 Aspects to be considered during application of performance criterion DS,
- including immunity tests for devices with current consumption > 16 A according to IEC 61000-4-34,
- updating Figure A.1 and Figure 1 for better readability,
- adding tests according to IEC 61000-4-16 to replace the tests according to IEC 61000-4-6 in the frequency range between 10 kHz and 150 kHz.

IEC 61326-3-2 is to be read in conjunction with IEC 61326-1.

The text of this standard is based on the following documents:

FDIS	Report on voting	•
65A/820/FDIS	65A/826/RVD	J

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

EC 61326-3-2:2017

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 61326 series, under the general title *Electrical equipment for measurement, control and laboratory use – EMC requirements*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Functional safety is that part of the overall safety relating to the equipment under control (EUC) and the EUC control system which depends on the correct functioning of the electrical safety-related systems. To achieve this, all items of equipment of the safety-related system which are involved in the performance of the safety functions must behave in a specified manner under all relevant conditions.

The IEC basic safety publication for functional safety of electrical/electronic/programmable electronic safety-related systems is IEC 61508. It sets the overall requirements to achieve functional safety. Sufficient immunity to electromagnetic disturbances is one of those requirements.

The concept of IEC 61508 distinguishes between the consideration of the application and the design of safety-related electrical and electronic systems. The interface between both is The overall safety requirements specification (SRS). It specifies all relevant requirements of the intended application, as follows.

- a) definition of the safety functions, based on a risk assessment of the intended application (which functions are intended to reduce risk);
- b) appropriate safety integrated integrity level (SIL) for each safety function based on a risk assessment of the intended application;
 - c) definition of the environment in which the system is intended to work including the electromagnetic environment as required by IEC 61508-2.

The requirements for each safety function are then specified in one or more system safety requirements specifications (SSRS). Hence, with regard to immunity against electromagnetic phenomena, the essential starting point is that the electromagnetic environment and its phenomena are considered in the SSRS, as required by IEC 61508. The safety-related system intended to implement the specified safety function has to fulfil the SSRS, and, from it, corresponding immunity requirements have to be derived for the items of equipment, which results in an equipment requirement specification. With respect to the electromagnetic environment, the SSRS and the equipment requirement specification should be based on a competent assessment of the foreseeable electromagnetic threats in the real environment over the whole operational life of the equipment. Hence, immunity requirements for the equipment depend on the characteristics of the electromagnetic environment in which the equipment is intended to be used.

The equipment manufacturer, therefore, has to prove that the equipment fulfils the equipment requirement specification and the system integrator must prove that the system fulfils the SSRS. Evidence has to be produced by application of appropriate methods. They do not need to consider any other aspects of the application, for example, risk of the application associated to any failure of the safety-related system. The objective is for all equipment in the system to comply with particular performance criteria taking into account functional safety aspects (for example, the performance criterion—FS DS) up to levels specified in the SSRS independent of the required safety integrity level (SIL).

For approaches on how to apply IEC 61326-3 series, see Annex A.

There exists meanwhile the generic EMC standard IEC 61000-6-7 dealing with functional safety aspects in industrial environments. Generic EMC standards are designed to apply for a defined electromagnetic environment, to products for which no dedicated product family EMC/product EMC standards exist. However, for the equipment in the scope of this document, the information given in the generic EMC standard was considered not to be sufficient. More detailed information and specifications were needed, for example specific test set-ups, consideration of the functional earth port or the deliberate differentiation between types of electromagnetic environments relevant for the equipment in the scope of this document.

IEC 61326-3-2:2017 RLV © IEC 2017 - 7 -

Though historically this product standard was developed several years before the generic EMC standard, this 2nd edition considers the information given in the generic EMC standard and applies it where appropriate.

iTeh Standards (https://standards.iteh.ai) Document Preview

IEC 61326-3-2:2017

https://standards.iteh.ai/catalog/standards/iec/4874f1a7-d690-4c08-9d23-0f11633bdad7/iec-61326-3-2-2017

ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE – EMC REQUIREMENTS –

Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – Industrial applications with specified electromagnetic environment

1 Scope

This part of IEC 61326 covers all equipment within the scope of IEC 61326-1-applies to this part of IEC 61326, but is limited to systems and equipment for industrial applications within a specified electromagnetic environment and intended to perform safety functions as defined in IEC 61508 with SIL 1-3.

The electromagnetic environments encompassed by this product family standard are industrial, both indoor and outdoor, as they can be found in industrial applications with an electromagnetic environment having specified characteristics (for example, process industry), and based on the requirements of the process industry, specifically chemical/petrochemical/pharmaceutical manufacturing plants using the mitigation measures given in Annex C. The difference between the electromagnetic environment covered by this document compared to the general industrial environment (see IEC 61326-3-1) is due to the mitigation measures employed against electromagnetic phenomena leading to a specified electromagnetic environment with test values that have been proven in practice.

The environment of industrial application with a specified electromagnetic environment typically includes the following characteristics: <u>6-3-2:2017</u>

industrial area with limited access;

- limited use of mobile transmitters;
- dedicated cables for power supply and control, signal or communication lines;
- separation between power supply and control, signal or communication cables;
- factory building mostly consisting of metal construction;
- overvoltage/lightning protection by appropriate measures (for example, metal construction of the building or use of protection devices);
- pipe heating systems driven by AC main power-may be present;
- no high-voltage substation close to sensitive areas;
- presence of CISPR 11 Group 2 ISM equipment using ISM frequencies only with low power;
- competent staff;
- periodical maintenance of equipment and systems;
- mounting and installation guidelines for equipment and systems.

A more detailed description of the above-mentioned typical characteristics is given in Annex B.

Equipment and systems considered as "proven-in-use" according to IEC 61508 or "prior use" according to IEC 61511 are excluded from the scope of this document.

IEC 61326-3-2:2017 RLV © IEC 2017 - 9 -

Fire alarm systems and security alarm systems intended for protection of buildings are excluded from the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-161, International Electrotechnical Vocabulary – Part 161: Electromagnetic compatibility (available at http://www.electropedia.org/)

IEC 61000-4-2:2001 2008, Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test* IEC 61000-4-3:2006/AMD1:2007 IEC 61000-4-3:2006/AMD2:2010

IEC 61000-4-4:2004 2012, Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test

IEC 61000-4-5:2005 2014, Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test

IEC 61000-4-6:2004 2013, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

<u>EC 61326-3-2:2017</u>

https:/IEC.61000-4-8:1993 2009, Electromagnetic compatibility (EMC) - Part 4-8: Testing and 201 measurement techniques - Power frequency magnetic field immunity test¹ Amendment 1 (2000)

IEC 61000-4-11:2004, Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests

IEC 61000-4-16:2015, Electromagnetic compatibility (EMC) – Part 4-16: Testing and measurement techniques – Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz

IEC 61000-4-29:2000, Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests

IEC 61000-4-34:2005, Electromagnetic compatibility (EMC) – Part 4-34: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase IEC 61000-4-34:2005/AMD1:2009

IEC 61000-6-2:2005, Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity for industrial environments

¹ There exists a consolidated edition 1.1 (2001) that includes edition 1.0 and its amendment.

IEC 61326-1:2005 2012, Electrical equipment for measurement, control and laboratory use – *EMC* requirements – *Part 1:* General requirements

IEC 61326-2-1:2005, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-1: Particular requirements – Test configurations, operational conditions and performance criteria for sensitive test and measurement equipment for EMC unprotected applications

IEC 61326-2-2:2005, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-2: Particular requirements – Test configurations, operational conditions and performance criteria for portable test, measuring and monitoring equipment used in low-voltage distribution systems

IEC 61326-2-3:2006, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-3: Particular requirements – Test configurations, operational conditions and performance criteria for transducers with integrated or remote signal conditioning

IEC 61326-2-4:2006, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-4: Particular requirements – Test configurations, operational conditions and performance criteria for insulation monitoring devices according to IEC 61557-8 and for equipment for insulation fault location according to IEC 61557-9

IEC 61326-2-5:2006, Electrical equipment for measurement, control and laboratory use EMC requirements — Part 2-5: Particular requirements — Test configurations, operational conditions and performance criteria for field devices with interfaces according to IEC 61784-1, CP 3/2

IEC 61326-3-1:2008 2, Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 3-1: Immunity requirements for safety-related systems and for equipment intended to perform safety functions (functional safety) – General industrial applications

IEC 61508-2:2000 2010, Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 2: Requirements for electrical/electronic/programmable electronic safety-related systems

IEC 61508-4:1998, Functional safety of electrical/electronic/programmable electronic safetyrelated systems – Part 4: Definitions and abbreviations

IEC 61511-1:2003, Functional safety – Safety instrumented systems for the process industry sector – Part 1: Framework, definitions, system, hardware and software requirements

ISO/IEC Guide 51:1999, Safety aspects – Guidelines for their inclusion in standards

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions of IEC 61326-1 and IEC 60050-161 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

² Under preparation. Stage at the time of publication: IEC/DIS 61326-3-1:2016.

- IEC Electropedia: available at http://www.electropedia.org
- ISO Online browing platform: available at http://www.iso.org/obp

NOTE Other definitions not included in IEC 60050-161 and in this standard, but nevertheless necessary for the application of the different tests, are given in the EMC basic publications of IEC 61000 series.

3.1.1

dangerous failure

failure which has the potential to put the safety-related system in a hazardous or fail-tofunction state of an element and/or subsystem and/or system that plays a part in implementing the safety function that:

- a) prevents a safety function from operating when required (demand mode) or causes a safety function to fail (continuous mode) such that the EUC is put into a hazardous or potentially hazardous state; or
- b) decreases the probability that the safety function operates correctly when required

NOTE Whether or not the potential is realised may depend on the channel architecture of the system; in systems with multiple channels to improve safety, a dangerous hardware failure is less likely to lead to the overall dangerous or fail-to-function state.

[SOURCE: IEC 61508-4:2010, 3.6.7]

3.1.2

equipment

the term equipment as used in this document is extremely general and is applied to a wide variety of possible subsystems, apparatus, appliances and other assemblies of products

3.1.3

equipment under control EUC

equipment, machinery, apparatus or plant used for manufacturing, process, transportation, medical or other activities

<u>IEC 61326-3-2:2017</u>

Note 1 to entry: The EUC control system is separate and distinct from the EUC. 1633bdad7/jec-61326-3-2-2017

[SOURCE: IEC 61508-4:2010, 3.2.1]

3.1.4

functional safety

part of the overall safety relating to the EUC and the EUC control system that depends on the correct functioning of the E/E/PE safety-related systems, other technology safety-related systems and external risk reduction facilities and other risk reduction measures

[SOURCE: IEC 61508-4:2010, 3.1.12]

3.1.5

harm

physical injury or damage to the health of people, or damage to property or the environment

[SOURCE: ISO/IEC Guide 51:2014, 3.1, modifed – "physical" has been added]

3.1.6 hazard potential source of harm

Note 1 to entry: The term includes short-term or immediate danger to persons arising within a short time scale (such as from fire or explosion) and also those that have a long-term effects on a person's health(such as from release of a toxic substance).

[SOURCE: ISO/IEC Guide 51:2014, 3.2, modified – the note to entry has been added]

3.1.7

safe failure

failure which does not have the potential to put the safety-related system in a hazardous or fail to-function state of an element and/or subsystem and/or system that plays a part in implementing the safety function that:

- a) results in the spurious operation of the safety function to put the EUC (or part thereof) into a safe state or maintain a safe state; or
- b) increases the probability of the spurious operation of the safety function to put the EUC (or part thereof) into a safe state or maintain a safe state

NOTE Whether or not the potential is realised may depend on the channel architecture of the system; in systems with multiple channels to improve safety, a safe hardware failure is less likely to result in an erroneous shut-down.

[SOURCE: IEC 61508-4:2010, 3.6.8]

3.1.8

safety function

function to be implemented by an E/E/PE safety-related system, other technology safetyrelated system or external risk reduction facilities or other risk reduction measures, that is intended to achieve or maintain a safe state for the EUC, in respect of a specific hazardous event (see 3.4.1)

EXAMPLE Examples of safety functions include:

- functions that are required to be carried out as positive actions to avoid hazardous situations (for example switching off a motor); and
- functions that prevent actions being taken (for example preventing a motor starting).

[SOURCE: IEC 61508-4:2010, 3.5.1]

3.1.9 programmable electronic PE

based on computer technology which may be comprised of hardware, software and of input and/or output units

EXAMPLE The following are all programmable electronic devices:

- microprocessors;
- micro-controllers;
- programmable controllers;
- application specific integrated circuits (ASICs);
- programmable logic controllers (PLCs);
- other computer-based devices (for example smart sensors, transmitters, actuators).

Note 1 to entry: This term covers microelectronic devices based on one or more central processing units (CPUs) together with associated memories, etc.

[SOURCE: IEC 61508-4:2010, 3.2.12]

3.1.10 electrical/electronic/programmable electronic E/E/PE

based on electrical (E) and/or electronic (E) and/or programmable electronic (PE) technology

EXAMPLE Electrical/electronic/programmable electronic devices include

- electro-mechanical devices (electrical);
- solid-state non-programmable electronic devices (electronic);
- electronic devices based on computer technology (programmable electronic); see 3.2.5 (of IEC 61326-1:2012).