

SLOVENSKI STANDARD

SIST EN 60076-2:2011

01-junij-2011

Nadomešča:
SIST EN 60076-2:1997

Močnostni transformatorji - 2. del: Segretek transformatorjev, potopljenih v tekočino (IEC 60076-2:2011)

Power transformers - Part 2: Temperature rise for liquid-immersed transformers (IEC 60076-2:2011)

Leistungstransformatoren - Teil 2: Übertemperaturen für flüssigkeitsgefüllte Transformatoren (IEC 60076-2:2011)

Transformateurs de puissance - Partie 2: Échauffement des transformateurs immergés dans le liquide (CEI 60076-2:2011)

Ta slovenski standard je istoveten z: EN 60076-2:2011

ICS:

29.180

Transformatorji. Dušilke

Transformers. Reactors

SIST EN 60076-2:2011

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60076-2:2011

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60076-2

April 2011

ICS 29.180

Supersedes EN 60076-2:1997

English version

**Power transformers -
Part 2: Temperature rise for liquid-immersed transformers
(IEC 60076-2:2011)**

Transformateurs de puissance -
Partie 2: Echauffement des
transformateurs immergés dans le liquide
(CEI 60076-2:2011)

Leistungstransformatoren -
Teil 2: Übertemperaturen für
flüssigkeitsgefüllte Transformatoren
(IEC 60076-2:2011)

This European Standard was approved by CENELEC on 2011-03-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 14/669/FDIS, future edition 3 of IEC 60076-2, prepared by IEC TC 14, Power transformers, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60076-2 on 2011-03-30.

This European Standard supersedes EN 60076-2:1997.

EN 60076-2:2011 includes the following significant technical changes with respect to EN 60076-2:1997:

- the standard is applicable only to liquid immersed transformers;
- the winding hot-spot temperature rise limit was introduced among the prescriptions;
- the modalities for the temperature rise test were improved in relation to the new thermal requirements;
- five informative annexes were added in order to facilitate the standard application.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2011-12-30
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2014-03-30

Annex ZA has been added by CENELEC

Endorsement notice

The text of the International Standard IEC 60076-2:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | | | |
|-----|----------------|------|---|
| [2] | IEC 60296:2003 | NOTE | Harmonized as EN 60296:2004 (not modified). |
| [3] | IEC 60567:2005 | NOTE | Harmonized as EN 60567:2005 (not modified). |
| [4] | IEC 60599:1999 | NOTE | Harmonized as EN 60599:1999 (not modified). |
| [5] | IEC 60836:2005 | NOTE | Harmonized as EN 60836:2005 (not modified). |
| [6] | IEC 61099:2010 | NOTE | Harmonized as EN 61099:2010 (not modified). |

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60076-1 (mod)	-	Power transformers - Part 1: General	EN 60076-1	-
IEC 60076-8	1997	Power transformers - Part 8: Application guide	-	-
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 61181	2007	Mineral oil-filled electrical equipment - Application of dissolved gas analysis (DGA) to factory tests on electrical equipment	EN 61181	2007
IEC Guide 115	2007	Application of uncertainty of measurement to conformity assessment activities in the electrotechnical sector	-	-

SIST EN 60076-2:2011

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60076-2:2011

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>



IEC 60076-2

Edition 3.0 2011-02

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Power transformers –
Part 2: Temperature rise for liquid-immersed transformers

Transformateurs de puissance –
Partie 2: Echauffement des transformateurs immergés dans le liquide

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 29.180

ISBN 978-2-88912-346-9

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 Cooling methods	8
4.1 Identification symbols.....	8
4.2 Transformers with alternative cooling methods	9
5 Normal cooling conditions.....	9
5.1 Air-cooled transformers	9
5.2 Water-cooled transformers	10
6 Temperature rise limits	10
6.1 General	10
6.2 Temperature rise limits at rated power	10
6.3 Modified requirements for special cooling conditions	12
6.3.1 General	12
6.3.2 Air-cooled transformers	12
6.3.3 Water-cooled transformers	13
6.4 Temperature rise during a specified load cycle	13
7 Temperature rise tests.....	13
7.1 General	13
7.2 Temperature of the cooling media	13
7.2.1 Ambient temperature	13
7.2.2 Water temperature	14
7.3 Test methods for temperature rise determination.....	14
7.3.1 General	14
7.3.2 Test by short-circuit method for two winding transformers.....	14
7.3.3 Test modification for particular transformers	15
7.4 Determination of liquid temperatures	16
7.4.1 Top-liquid temperature	16
7.4.2 Bottom and average liquid temperatures.....	17
7.5 Determination of top, average and bottom liquid temperature rises.....	18
7.6 Determination of average winding temperature	18
7.7 Determination of winding resistance at the instant of shutdown	19
7.8 Determination of average winding temperature rise at the instant of shutdown.....	19
7.9 Determination of the average winding to liquid temperature gradient	19
7.10 Determination of the hot-spot winding temperature rise	20
7.10.1 General	20
7.10.2 Determination by calculation.....	20
7.10.3 Direct measurement during the temperature rise test.....	20
7.11 Uncertainties affecting the results of the temperature rise test.....	21
7.12 Dissolved gas-in-oil analysis	21
7.13 Corrections.....	21
Annex A (informative) Hot-spot winding temperature rise determination for OFAF and OFWF cooled transformers based on the top-liquid temperature in tank.....	23
Annex B (informative) Methods to estimate the hot-spot winding temperature rises.....	25

Annex C (informative) Techniques used in temperature rise testing of liquid-immersed transformers	30
Annex D (informative) Dissolved gases analysis for the detection of local overheating	39
Annex E (informative) Application of optical fibre sensors for winding hot-spot measurements	43
Bibliography	47
Figure B.1 – Temperature rise distribution model for ON cooling methods	26
Figure B.2 – Value of factor Q as a function of rated power and strand height (W)	27
Figure B.3 – Typical liquid flow paths in a disk winding with diverting washers	28
Figure C.1 – Recommended circuit for transformers with a low resistance winding using two separate direct current sources, one for each winding	32
Figure C.2 – Alternative recommended circuit using only one direct current source for both windings	32
Figure C.3 – Average winding temperature variation after shutdown	33
Figure C.4 – Extrapolation of the cooling down curve, using the fitting curve $\theta_w(t) = A_0 - kt + Be^{-t/T_w}$	38
Figure E.1 – Optical fibre sensor application for a disk winding of core type transformer	45
Figure E.2 – Optical fibre sensor application for a transposed cable of core type transformer	45
Figure E.3 – Modality of optical fibre sensor application in the winding spacer of core type transformer	46
Figure E.4 – Optical fibre sensor application for high voltage winding of shell type transformer	46
Table 1 – Temperature rise limits	11
Table 2 – Recommended values of temperature rise corrections in case of special service conditions	12
Table 3 – Exponents for the corrections of temperature rise test results	22
Table A.1 – Hot-spot winding temperature rises for some specific transformers determined from conventional heat run test data combined with calculated hot-spot winding temperature rise, and from direct fibre-optic measurements	24
Table C.1 – Example of cooling down curve calculation spreadsheet	37
Table D.1 – Minimum detectable value S_D of gases in oil	40
Table D.2 – Admissible limits for gas rate increases	41
Table E.1 – Minimum recommended number of sensors for three-phase transformers	43
Table E.2 – Minimum recommended number of sensors for single-phase transformers	43

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER TRANSFORMERS –**Part 2: Temperature rise for liquid-immersed transformers****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60076-2 has been prepared by IEC technical committee 14: Power transformers.

This third edition cancels and replaces the second edition published in 1993. It is a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the standard is applicable only to liquid immersed transformers;
- b) the winding hot-spot temperature rise limit was introduced among the prescriptions;
- c) the modalities for the temperature rise test were improved in relation to the new thermal requirements;
- d) five informative annexes were added in order to facilitate the standard application.

The text of this standard is based on the following documents:

FDIS	Report on voting
14/669/FDIS	14/676/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60076 series can be found, under the general title *Power transformers*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>

SIST EN 60076-2:2011

POWER TRANSFORMERS –

Part 2: Temperature rise for liquid-immersed transformers

1 Scope

This part of IEC 60076 applies to liquid-immersed transformers, identifies power transformers according to their cooling methods, defines temperature rise limits and gives the methods for temperature rise tests.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-1, *Power transformers – Part 1: General*

IEC 60076-8:1997, *Power transformers – Part 8: Application guide*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 61181:2007, *Mineral oil-filled electrical equipment – Application of dissolved gas analysis (DGA) to factory tests on electrical equipment*

IEC Guide 115:2007, *Application of uncertainty of measurement to conformity assessment activities in the electrotechnical sector*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60076-1 and the following apply.

3.1

external cooling medium

the medium external to the transformer cooling system (air or water) into which the heat produced by the transformer losses is transferred

3.2

internal cooling medium

the liquid in contact with the windings and other transformer parts by means of which the heat produced by the losses is transferred to the external cooling medium

NOTE The liquid can be mineral oil or other natural and synthetic liquid.

3.3

temperature rise

the difference between the temperature of the part under consideration (for example, the average winding temperature) and the temperature of the external cooling medium

3.4**top-liquid temperature** θ_o

the temperature of the insulating liquid at the top of the tank, representative of top-liquid in the cooling flow stream

3.5**top-liquid temperature rise** $\Delta\theta_o$

the temperature difference between the top-liquid temperature and the external cooling medium temperature

3.6**bottom-liquid temperature** θ_b

the temperature of the insulating liquid as measured at the height of the bottom of the windings or to the liquid flowing from the liquid cooling equipment

3.7**bottom-liquid temperature rise** $\Delta\theta_b$

the difference between the bottom-liquid temperature and the external cooling medium temperature

iTeh STANDARD PREVIEW

3.8**average liquid temperature** (standards.iteh.ai) θ_{om}

the average temperature of the top-liquid and bottom liquid temperatures

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>

3.9**average liquid temperature rise** $\Delta\theta_{om}$

the difference between the average liquid temperature and the external cooling medium temperature

3.10**average winding temperature** θ_w

the winding temperature determined at the end of temperature rise test from the measurement of winding d.c. resistance

3.11**average winding temperature rise** $\Delta\theta_w$

the difference between the average winding temperature and the external cooling medium temperature

3.12**average winding gradient** g

the difference between the average winding temperature and the average insulating liquid temperature

3.13**hot-spot winding temperature** θ_h

the hottest temperature of winding conductors in contact with solid insulation or insulating liquid

3.14**hot-spot winding temperature rise** $\Delta\theta_h$

the difference between hot-spot winding temperature and the external cooling medium temperature

3.15**hot-spot factor** H

a dimensionless factor to estimate the local increase of the winding gradient due to the increase of additional loss and variation in the liquid flow stream

NOTE H factor is obtained by the product of the Q and S factors (see 3.16 and 3.17).

3.16 **Q factor**

a dimensionless factor to estimate the increase of the average winding gradient due to the local increase of the additional loss

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.17 **S factor**

a dimensionless factor to estimate the local increase of the average winding gradient due to the variation in the liquid flow stream [SIST EN 60076-2:2011](https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011)

<https://standards.iteh.ai/catalog/standards/sist/7ea30ff4-de11-4273-9d64-3552fa836032/sist-en-60076-2-2011>

3.18**thermally upgraded paper**

cellulose-based paper which has been chemically modified to reduce the rate at which the paper decomposes

A paper is considered as thermally upgraded if it meets the life criteria of the 50 % retention in tensile strength after 65 000 h in a sealed tube at 110 °C or any other time/temperature combination given by the equation:

$$\text{Time (h)} = 65\,000 e^{\left(\frac{15\,000}{\theta_h + 273} - \frac{15\,000}{110 + 273} \right)} \quad (1)$$

NOTE 1 Ageing effects are reduced either by partial elimination of water forming agents or by inhibiting the formation of water through the use of stabilizing agents.

NOTE 2 See IEC 60076-7, for an alternative test method based on the nitrogen content.

4 Cooling methods**4.1 Identification symbols**

Transformers shall be identified according to the cooling method employed. For liquid-immersed transformers, this identification is expressed by a four-letter code as described below.

First letter: Internal cooling medium:

- O: mineral oil or synthetic insulating liquid with fire point ≤ 300 °C;

- K: insulating liquid with fire point > 300 °C;
- L: insulating liquid with no measurable fire point.

Second letter: Circulation mechanism for internal cooling medium:

- N: natural thermosiphon flow through cooling equipment and in windings;
- F: forced circulation through cooling equipment, thermosiphon flow in windings;
- D: forced circulation through cooling equipment, directed from the cooling equipment into at least the main windings.

Third letter: External cooling medium:

- A: air;
- W: water.

Fourth letter: Circulation mechanism for external cooling medium:

- N: natural convection;
- F: forced circulation (fans, pumps).

NOTE 1 In this standard, the use of insulating liquids K and L is considered only for safety and environmental reasons.

NOTE 2 In a transformer designated as having forced directed insulating liquid circulation (second code letter D), the rate of liquid flow through the main windings is determined by the pumps and is not, in principle, determined by the loading. A minor fraction of the flow of liquid through the cooling equipment may be directed as a controlled bypass to provide cooling for core and other parts outside the main windings. Regulating windings and/or other windings having relatively low power may also have non-directed circulation of bypass liquid.

In a transformer with forced, non-directed cooling (second code letter F), the rates of flow of liquid through all the windings are variable with the loading, and not directly related to the pumped flow through the cooling equipment.

4.2 Transformers with alternative cooling methods

A transformer may be specified with alternative cooling methods. In this case, the specification and the rating plate shall then carry information about the power values at which the transformer fulfils the temperature rise limits when these alternatives apply, see IEC 60076-1.

The power value for the alternative cooling methods with the highest cooling capacity is the rated power of the transformer (or of an individual winding of a multi-winding transformer, see IEC 60076-1). The alternatives cooling methods are conventionally listed in rising order of cooling capacity.

Examples:

- ONAN/ONAF. The transformer has a set of fans which may be put into service as desired at high loading. The insulating liquid circulation is by thermosiphon effect only, in both cases.
- ONAN/OFAF. The transformer has cooling equipment with pumps and fans but is also specified with a reduced rated power under natural cooling (for example, in case of failure or reduction of auxiliary power).

5 Normal cooling conditions

5.1 Air-cooled transformers

Normal ambient temperature limits for power transformers are given in IEC 60076-1.