

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical insulation systems – Procedures for thermal evaluation –
Part 31: Applications with a designed life of 5 000 h or less**

**Systèmes d'isolation électrique – Procédures d'évaluation thermique –
Partie 31: Applications avec une durée de vie de conception maximale de 5 000 h**

ITAH STANDARD PREVIEW
(standards.iteh.ai)
IEC 61857-31:2017
<https://standards.iteh.ai/catalog/standards/sist/5960dc42-acc0-47ac-b082-8b7c4d91c291/iec-61857-31-2017>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms, containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 21 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical insulation systems – Procedures for thermal evaluation –
Part 31: Applications with a designed life of 5 000 h or less**

**Systèmes d'isolation électrique – Procédures d'évaluation thermique –
Partie 31: Applications avec une durée de vie de conception maximale de 5 000 h**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.30

ISBN 978-2-8322-5287-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 EIS evaluation	7
5 Test objects.....	7
6 Test procedures	7
6.1 Procedure A: Establishing a TE for applications with a designed life of 1 500 h or less: one-temperature ageing.....	7
6.2 Procedure B: Establishing a TE rating for applications with a designed life of 5 000 h or less: one-temperature ageing.....	8
6.3 Procedure C: Establishing a TE rating for applications with a designed life of 5 000 h or less: two-temperature ageing	8
7 Data analysis.....	8
7.1 Analysis – Test Procedures A and B (See 6.1 and 6.2)	8
7.2 Analysis – Test Procedure C (See 6.3)	9
8 Test report.....	9
Bibliography.....	10

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61857-31:2017](https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82-8b7c4d91c291/iec-61857-31-2017)

<https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82-8b7c4d91c291/iec-61857-31-2017>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL INSULATION SYSTEMS – PROCEDURES FOR THERMAL EVALUATION –

Part 31: Applications with a designed life of 5 000 h or less

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
<https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82->
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61857-31 has been prepared by IEC technical committee 112: Evaluation and qualification of electrical insulating materials and systems.

This bilingual version (2018-01) corresponds to the monolingual English version, published in 2017-01.

The text of this International Standard is based on the following documents:

CDV	Report on voting
112/356/CDV	112/375/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61857 series, published under the general title *Electrical insulation systems – Procedures for thermal evaluation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61857-31:2017](#)

<https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82-8b7c4d91c291/iec-61857-31-2017>

INTRODUCTION

IEC 61857-1 provides the general structure to be followed for an electrical insulation system (EIS) evaluation and classification.

IEC TR 61857-2 provides guidelines to identify the application and to select the preferred test method based on the application.

This part of IEC 61857 provides a test method for EIS applications, such as the automotive industry, when the designed life is 5 000 h or less.

The selection of this test method can be decided by the end product application.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61857-31:2017](https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82-8b7c4d91c291/iec-61857-31-2017)

<https://standards.iteh.ai/catalog/standards/sist/39d6de42-accd-41ac-bb82-8b7c4d91c291/iec-61857-31-2017>

ELECTRICAL INSULATION SYSTEMS – PROCEDURES FOR THERMAL EVALUATION –

Part 31: Applications with a designed life of 5 000 h or less

1 Scope

This part of IEC 61857 establishes an EIS evaluation for applications with a designed life of 5 000 h or less. This test method follows the procedures of IEC 60505 and is modified based on the range of designed life.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60505, *Evaluation and qualification of electrical insulation systems*

IEC 61857-1, *Electrical insulation systems – Procedures for thermal evaluation – Part 1: General requirements – Low-voltage*

IEC TR 61857-2, *Electrical insulation systems – Procedures for thermal evaluation – Part 2: Selection of the appropriate test method for evaluation and classification of electrical insulation systems*

IEC 61857-21, *Electrical insulation systems – Procedures for thermal evaluation – Part 21: Specific requirements for general-purpose models – Wire-wound applications*

IEC 61857-22, *Electrical insulation systems – Procedures for thermal evaluation – Part 22: Specific requirements for encapsulated-coil model – Wire-wound electrical insulation system (EIS)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61857-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

designed life

expected application time which is proposed or decided by an end user, an industrial manufacturer, etc., regardless of the duty cycle, continual or intermittent

3.2

thermal endurance

TE

maximum designed temperature for the selected time coordinate

3.3

average life

AL

mean value of life

4 EIS evaluation

Procedure A (see Clause 6) is intended for EIS with a designed life of 1 500 h or less, subjecting one set of test objects to one-temperature ageing at 10 K above the maximum design temperature. The average life of the set under evaluation shall be at least 1 500 h.

Procedure B (see Clause 6) is intended for EIS with a designed life of 5 000 h or less, subjecting one set of test objects to one-temperature ageing at 10 K above the maximum design temperature. The ageing time in Procedure A may be increased up to 5 000 h to correspond to the designed life of the EIS. The average life of the set under evaluation shall be at least 1 500 h.

Procedure C (see Clause 6) is intended for EIS with a designed life of 5 000 h or less, subjecting two sets of test objects to two-temperature ageing at 20 K to 30 K and 30 K to 35 K above the maximum design temperature.

The test results determined by either Procedure A, Procedure B or Procedure C described in Clause 6 can be expanded to larger full thermal evaluations in accordance with IEC 61857 (all parts), if the additional thermal ageing is started prior to the completion of the thermal ageing according to this document. When expanded to a full thermal ageing, the work undertaken according to this document is referred to as a screening test portion of the full thermal ageing. Also, IEC 61857-1 and IEC TR 61857-2 may require a reference EIS to be included in the evaluation for establishing a relative thermal endurance (RTE) rating. When expansion is needed, an evaluation with regard to other applications shall require the addition of a reference EIS in accordance with an EIS method selected from IEC TR 61857-2.

5 Test objects

The test objects and test equipment shall be in accordance with the appropriate test method selected from IEC TR 61857-2.

6 Test procedures

6.1 Procedure A: Establishing a TE for applications with a designed life of 1 500 h or less: one-temperature ageing

Follow the procedures of the selected test method. For the selected test method, one test cycle consists of:

- thermal ageing subcycle according to IEC 60505,
- conditioning subcycle according to IEC TR 61857-2, for example IEC 61857-21 or IEC 61857-22, and
- diagnostic testing in accordance with the procedures of the test method selected from IEC TR 61857-2. The selected ageing temperature shall be 10 K above the maximum design temperature.

The average life of the set under evaluation shall be at least 1 500 h.

To accumulate at least 1 500 h prior to the breakdown of the EIS the ageing cycle shall be 168 h.

NOTE 168 hours (one week) is used for accumulating more than 1 500 ageing hours in nine ageing cycles.

If the set of test objects exceeds the original test time of 1 500 h the test may be terminated as the target was achieved or the thermal ageing may be continued to achieve an expanded goal.

6.2 Procedure B: Establishing a TE rating for applications with a designed life of 5 000 h or less: one-temperature ageing

The one-temperature ageing described in Procedure A can be extended to accumulate additional hours. The set undergoing thermal evaluation under Procedure A can be extended to a time coordinate of up to 5 000 h.

6.3 Procedure C: Establishing a TE rating for applications with a designed life of 5 000 h or less: two-temperature ageing

For these two-temperature ageing applications, the recommendation is for two sets of the candidate EIS test objects to undergo test cycles at each of two elevated ageing temperatures. One test cycle consists of

- thermal ageing subcycle according to IEC 60505,
- conditioning subcycle, and
- diagnostic testing in accordance with the procedures of the test method selected from IEC TR 61857-2 with the following selected ageing temperatures:
 - the lower temperature shall be 20 K to 30 K above the expected thermal class value, and
 - the higher ageing temperature shall be 30 K to 35 K above the expected thermal class value.

7 Data analysis

7.1 Analysis – Test Procedures A and B (See 6.1 and 6.2)

The thermal classification is evaluated and established when there are no failed test objects and no breakdown of the EIS prior to accumulating the specific number of hours. No projection is needed or made with the accumulated single data point. The application expected life is reached prior to the failure of the EIS undergoing the thermal ageing exposure.

If any specimens have a failure of the EIS prior to accumulation of the selected number of hours, the TE shall be established by using the average life (AL) of the set of test objects. The AL is calculated in accordance with the procedure given in IEC 61857-1.

The EIS TE value assigned to the candidate EIS is defined as EIS TE x/y where

- x is the established thermal class (expressed in °C),
- y is the specified time interval for this rating (expressed in hours).

EXAMPLE: EIS TE 180 °C/1 200 h or EIS TE 155 °C/1 200 h or EIS TE 200 °C/1 500 h.

7.2 Analysis – Test Procedure C (See 6.3)

To establish a pattern, the life of the set of test objects aged at the higher ageing temperature shall be completed. The set at the lower temperature can be completed or discontinued while still under ageing. When the higher ageing temperature is completed with the lower ageing temperature discontinued, the TE value is a conservative value.

Use the test results from both ageing temperatures. Project the results using both sets of results and project to the time coordinate needed.

The EIS TE value assigned to the candidate EIS is defined as EIS TE x/y where

x is the calculated thermal class (expressed in °C),

y is the specified time interval for this rating (expressed in hours).

EXAMPLE: EIS TE 180 °C/2 000 h or EIS TE 155 °C/3 000 h or EIS TE 200 °C/3 500 h.

8 Test report

The report of the results of this test shall include all records, relevant details of the test, and analysis, including:

- reference to this document;
- description of the EIS tested;
- ageing temperatures and ageing periods;
- prediagnostic conditioning and diagnostic tests used with applied test or stressed levels, for each EIS;
- number of test objects at each temperature for each EIS;
- method of obtaining the ageing temperatures (including oven type, etc.);
- rate of air replacement, if applicable;
- individual times to end-of-life, and mode of failure;
- mean log times to end-of-life for each ageing temperature;
- EIS RTE/thermal class of the candidate EIS.