

Edition 3.0 2017-03

INTERNATIONAL STANDARD

Low voltage electrical installations – 2000 Part 7-704: Requirements for special installations or locations – Construction and demolition site installations

Document Preview

IEC 60364-7-704:2017

https://standards.iteh.ai/catalog/standards/iec/228c5dfa-1a39-4c91-88a6-e31c462b0088/iec-60364-7-704-2017





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office Tel.: +41 22 919 02 11 3, rue de Varembé Fax: +41 22 919 03 00

CH-1211 Geneva 20 info@iec.ch Switzerland www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

EC 60364-7-704:2017

https://standards.iteh.ai/catalog/standards/iec/228c5dfa-1a39-4c91-88a6-e31c462b0088/iec-60364-7-704-2017



Edition 3.0 2017-03

INTERNATIONAL STANDARD

Low voltage electrical installations – 200021018

Part 7-704: Requirements for special installations or locations – Construction and demolition site installations

Document Preview

IEC 60364-7-704:2017

https://standards.itch.ai/catalog/standards/iec/228c5dfa-1a39-4c91-88a6-e31c462b0088/iec-60364-7-704-2017

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 29.020; 91.140.50 ISBN 978-2-8322-4020-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.	3	
INTRODUCTION	ON5	
704 Construct	tion and demolition site installations6	
704.1	Scope6	
704.2	Normative references6	
704.3	Terms and definitions7	
704.30	Assessment of general characteristics7	
704.31	Purposes, supplies and structure7	
704.313	Supplies7	
704.4	Protection for safety7	
704.41	Protection against electric shock7	
704.410	Introduction7	
704.411	Protective measure: automatic disconnection of supply8	
704.414	Protective measure: Extra-low voltage provided by SELV and PELV8	
704.44	Protection against voltage disturbances and electromagnetic disturbances8	
704.443	Protection against transient overvoltages of atmospheric origin or due to switching	
704.5	Selection and erection of equipment8	
704.51	Common rules8	
704.511	Compliance with standards8	
704.512	Operational conditions and external influences9	
704.52	Wiring systems9	
704.53	Isolation, switching and control9	
704.536	Isolation and switching9	
704.56	Safety services	
704.6	Verification	
Annex A (info	rmative) List of notes concerning certain countries11	
Bibliography	15	

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW VOLTAGE ELECTRICAL INSTALLATIONS -

Part 7-704: Requirements for special installations or locations – Construction and demolition site installations

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- https://6) All users should ensure that they have the latest edition of this publication. 3 1c462b0088/iec-60364-7-704-2017
 - 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
 - 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
 - 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-7-704 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition published in 2005. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) clarification of the Scope;
- b) clarification of compliance with standards;
- c) clarification of devices for isolation.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
64/2155/FDIS	64/2167/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The reader's attention is drawn to the fact that Annex A lists all of the "in-some-countries" clauses on differing practices of a less permanent nature relating to the subject of this standard.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended. (https://standards.iteh.ai)

A bilingual version of this publication may be issued at a later date.

IEC 60364-7-704:2017

https://standards.iteh.ai/catalog/standards/iec/228c5dta-1a39-4c91-88a6-e31c462b0088/iec-60364-7-704-2017

INTRODUCTION

For the purpose of this part of IEC 60364 (IEC 60364-7-704) the requirements of the general parts 1 to 6 of IEC 60364 apply.

The IEC 60364-7-7XX parts of IEC 60364 contain particular requirements for special installations or locations which are based on the requirements of the general parts of IEC 60364 (IEC 60364-1 to IEC 60364-6). These IEC 60364-7-7XX parts are considered in conjunction with the requirements of the general parts.

The particular requirements of this part of IEC 60364 supplement, modify or replace certain of the requirements of the general parts of IEC 60364 being valid at the time of publication of this part. The absence of reference to the exclusion of a part or a clause of a general part means that the corresponding clauses of the general part are applicable (undated reference).

Requirements of other 7XX parts being relevant for installations covered by this part also apply. This part may therefore also supplement, modify or replace certain of these requirements valid at the time of publication of this part.

The clause numbering of this part follows the pattern and corresponding references of IEC 60364. The numbers following the particular number of this part are those of the corresponding parts, or clauses of the other parts of the IEC 60364 series, valid at the time of publication of this part, as indicated in the normative references of this document (dated reference).

If requirements or explanations additional to those of the other parts of the IEC 60364 series are needed, the numbering of such items appears as 704.101, 704.102, 704.103 etc.

In the case where new or amended general parts with modified numbering were published after this part was issued, the clause numbers referring to a general part in this 704 part may no longer align with the latest edition of the general part. Dated references should be observed.

https://standards.iteh.ai/catalog/standards/iec/228c5dfa-1a39-4c91-88a6-e31c462b0088/iec-60364-7-704-2017

LOW VOLTAGE ELECTRICAL INSTALLATIONS -

Part 7-704: Requirements for special installations or locations – Construction and demolition site installations

704 Construction and demolition site installations

704.1 Scope

The requirements of this part of IEC 60364 apply to installations for construction and demolition sites for use during the period of the construction or demolition work which are intended to be taken out of service upon completion of the works. Examples include the following:

- construction work of new buildings;
- repair, alteration, extension or demolition of existing buildings or parts of existing buildings;
- engineering works;
- earthworks;
- work of similar nature.

The requirements apply to fixed or moveable installations.

The requirements do not apply to installations in administrative locations of construction sites (e.g. offices, cloakrooms, meeting rooms, canteens, restaurants, dormitories, toilets).

704.2 Normative references IEC 60364-7-7042017

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60245-4, Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 4: Cords and flexible cables

IEC 60309-1, Plugs, socket-outlets and couplers for industrial purposes – Part 1: General requirements

IEC 60309-2, Plugs, socket-outlets and couplers for industrial purposes – Part 2: Dimensional interchangeability requirements for pin and contact-tube accessories

IEC 60364 (all parts), Low voltage electrical installations

IEC 60364-4-41:2005, Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock

IEC 60364-5-53:2001¹, Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control

IEC 60364-5-53:2001/AMD1:2002

IEC 60364-5-53:2001/AMD2:2015

IEC 61439-4, Low-voltage switchgear and controlgear assemblies – Part 4: Particular requirements for assemblies for construction sites (ACS)

704.3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

704.30 Assessment of general characteristics

704.30.101 The clearances for overhead lines above construction sites shall be agreed with the owner of the overhead power line, on the basis of the dimensions of the construction site machines, such as cranes, and equipment, such as ladders and scaffolding, to be used.

704.31 Purposes, supplies and structure

704.313 Supplies

The following note is added:

NOTE A single construction site can be served by several sources of supply, including generating sets; see IEC 60364-5-55:2011, Clause 551.

704.4 Protection for safety

- 704.41 Protection against electric shock
- 704.410 Introduction
- 704.410.3 General requirements

704.410.3.5 Replace with the following:

The protective measures:

- obstacles, and
- · placing out of reach

as specified in IEC 60364-4-41:2005, Annex B shall not be used.

704.410.3.6 Replace with the following:

The protective measures

A consolidated version of this publication exists, comprising IEC 60364-5-53:2001, IEC 60364-5-53:2001/AMD 1:2002 and IEC 660364-5-53:2001/AMD 2:2015.

- · non-conducting location,
- · earth-free equipotential bonding, and
- electrical separation for the supply of more than one current-using equipment

as specified in IEC 60364-4-41:2005, Annex C shall not be used.

704.410.3.101 Circuits supplying socket-outlets with rated current up to and including 32 A and other circuits supplying hand-held electrical equipment with rated current up to and including 32 A shall:

- be protected by automatic disconnection of supply together with additional protection by the use of residual current devices having a rated residual operating current not exceeding 30 mA (see IEC 60364-4-41:2005, 415.1.1), or
- be supplied by SELV or PELV (see IEC 60364-4-41:2005, 414), or
- have electrical separation of circuits (see IEC 60364-4-41:2005, 413), each socket-outlet and hand-held electrical equipment being supplied by an individual isolating transformer or by separate windings of an isolating transformer.
- 704.411 Protective measure: automatic disconnection of supply
- 704.411.3 Requirements for fault protection
- 704.411.3.2 Automatic disconnection in case of a fault
- **704.411.3.2.101** For circuits supplying socket-outlets with a rated current exceeding 32 A, residual current devices shall be used as disconnection devices.
- 704.414 Protective measure: Extra-low voltage provided by SELV and PELV
- 704.414.4 Requirements for SELV and PELV circuits
- 704.414.4.5 Replace the subclause with the following:

Irrespective of the nominal voltage, in AC and DC circuits, the requirement for basic protection shall be provided by the following:

- insulation in accordance with IEC 60364-4-41:2005, Clause A.1, or
- barriers or enclosures in accordance with IEC 60364-4-41:2005, Clause A.2.
- 704.44 Protection against voltage disturbances and electromagnetic disturbances
- 704.443 Protection against transient overvoltages of atmospheric origin or due to switching
- 704.443.1 General
- **704.443.1.101** Cranes, lifts, cement mixers and similar items of equipment are liable to produce switching overvoltages. Where such equipment is present, consideration should be given to the need for protection against switching overvoltages.
- 704.5 Selection and erection of equipment
- 704.51 Common rules
- 704.511 Compliance with standards
- **704.511.1** Add the following:

All assemblies on construction and demolition sites (ACS) for the distribution of electricity shall be in compliance with the requirements of IEC 61439-4.